



Dashiell 2022





Keith Hill
Principal Engineer
Doble Engineering Company



Doble Power Factor Training Objectives

1. Basic understanding of Doble Power Factor Theory
 1. Current
 2. Watts
 3. Power Factor
 4. Capacitance
 5. Dielectric constant
 6. AC versus DC testing
2. Basic understanding of Doble Power Factor Basics
 1. Construction of high voltage lead
 2. Identify GST Ground connections
 3. Identify GST Guard connections
 4. Identify UST connections
3. Basic understanding of bushing construction
4. The student will be able to perform Power Factor testing on:
 - a. Bushings
 1. Overall
 2. C1
 3. C2
 4. Inverted UST /C1
 5. C1 + C2
 6. Hot Collar
 - b. Transformers
 1. Two Winding Transformers
 2. Shielded transformer
 3. Wye-Wye with H0 and X0 internally connected
 4. Three Winding Transformers
 5. Auto-transformers with tertiary
 6. Auto-transformers without tertiary
 - c. Breakers
 1. Oil Circuit Breakers
 2. Gas Circuit Breakers
 3. Vacuum Circuit Breakers
 4. Air Magnetic Breakers
 5. Live tank breakers

Doble Power Factor Training Objectives

- d. Miscellaneous equipment
 - 1. Arresters
 - 2. PTs
 - 3. CTs
 - 4. CCVTs
 - 5. Oil
 - 6. Wood members
 - 7. Oil test cell
- 5. The student will be able to safely make all connections on Doble Power Factor Test Set.
- 6. The student will be able to perform diagnostic tests on M4000 equipment
- 7. The student will have a basic understanding of DTA Field software.
- 8. Interpretation of case studies.

REVIEW OF SAFE TEST PRACTICES

SECTION:	PAGE:
Contact Information	7
Basic Insulation & Power Factor Theory	11
Safety	46
Test Modes of Doble Test Equipment	57
Doble Testing Power Apparatus Bushings	81
Doble Testing Transformer	167
Doble Testing Oil Circuit Breaker	340
Doble Testing Grounded Tank SF6 Breakers	377
Doble Testing Live Tank Breakers	395
Doble Testing Vacuum Breakers	407
Doble Testing Air Magnetic Breakers	422
Doble Testing Surge Arresters	432
Doble Testing Potential Transformers	467
Doble Testing Current Transformers	520
Doble Testing Metering Outfits	542
Doble Testing CCVT's	559
Testing Insulating Oil	607
Case Studies	626

1-9-2020



Power Factor Training

Keith Hill





Your Doble Engineers Are

Keith Hill

Office: 617-393-3000

Email: *khill@doble.com*

Carl Pankratz

Office: 617-393-3002

Email: *cpankratz@doble.com*



Your Doble Engineers Are

Chad Brown

Office: 617-393-3123

Email: cbrown@doble.com

Arturo Oropeza

Office: 617-393-3004

Email: AORopeza@doble.com

After Hours and Emergency Number:

1-617-926-4900

Confidential Notice

Doble Engineering (Doble) hereby grants the recipient (you) the right to retain this presentation and materials included within (the Presentation) for private reference. No other rights, title, or interest, including, but not limited to, the rights to copy, make use of, distribute, transmit, display or perform in public (or to third parties), edit, translate, or reformat any portion of the Presentation are hereby or otherwise granted and shall remain expressly reserved by Doble. You acknowledge and agree that such limited license is expressly conditioned upon your acceptance of the terms herein. You further agree that, in the event of your breach, Doble will suffer irreparable damage and injury for which there is no adequate remedy at law. As such, Doble, in addition to any other rights and remedies available, shall be entitled to seek injunction by a tribunal of competent jurisdiction restricting you from committing or continuing any breach of these terms.


We Learn



- **10% of what we read**
- **20 % of what we hear**
- **30% of what we see**
- **50% of what we both see and hear**
- **70% of what is discussed with others**
- **80% of what we personally experience**
- **95% of what we **TEACH** to someone else**



Basic Insulation Theory



Basic Insulation & Power Factor Theory


Topical Guide Objectives

- Review the Basic Insulation Models
- Review Capacitance and it's Properties
- Review A-C dielectric Loss
- Define Power Factor


Insulation



Insulation is basically two plates separated by one or more dielectrics. One plate is at a high potential and the other at a lower or ground potential.



Current generated by polar contaminants in the dielectric shows up as Watts.





Examples of Material With Insulating Properties

Gaseous

High Vacuum

Air

Sulfur Hexafluoride
(SF₆)

Liquid

Hydrocarbon-
Based Oil

Silicone Oil

Distilled Water


Solid

Cellulose


Porcelain

Phenolics

Simplified Equivalent Circuits of an Insulation Specimen




Series Circuit (a)



Parallel Circuit (b)

The Capacitor



Two conducting plates with area “A” separated by a dielectric with a thickness of “d” and dielectric constant ϵ


Capacitance

$$C = \frac{A\epsilon}{d}$$

C = Capacitance

ϵ = dielectric constant


d = Distance between plates



All the variables are Physical parameters

Dielectric Constant

- In 1836, Michael Faraday (the father of the Capacitance -- Just look at his name) discovered that when the plates between a capacitor were filled with another insulating material, the capacitance would change.
- This factor is the dielectric constant ϵ
- By definition the dielectric constant of a Vacuum is 1.0. All other dielectric constants are referenced to this standard.




Dielectric Constants

<u>Material</u>	<u>Constant</u>
Vacuum	1.0
Air	1.000549
Mica	5.4
Paper	2
Porcelain	7
Oil	2.2
Silicone Fluid	2.75
Water (20° C)	80

SF6 is not listed as the dielectric is dependent on temperature and pressure

Typical Insulation System



Test Mode-GST
Ground



Oil $\epsilon = 2.2$




Porcelain $\epsilon = 7.0$




Paper $\epsilon = 2.0$

Example: Oil leaking from an Insulation System

-  Oil = 2.2
-  Porcelain = 7.0
-  Paper = 2.0
-  Air = 1.0

Given three dielectrics in series the dielectric constant ϵ is:




$$\epsilon_{\text{before}} = 1/2.2 + 1/7.0 + 1/2.0 = 1/T = 1.097$$

If the Oil leaks out and is replaced by air...

$$\epsilon_{\text{after}} = 1/1 + 1/7 + 1/2.0 = 1/T = 0.608$$


 $C \downarrow \Rightarrow I_t \downarrow$

Example: Oil leaking from an Insulation System




H1 mA < H2 mA

Example: Oil leaking from an Insulation System



$$H1 \text{ mA} = H2 \text{ mA}$$


Example: Oil leaking from an Insulation System



$$H1 \text{ mA} < H2 \text{ mA}$$

Dielectric Constant of Air is Less than Oil

Hot Collar Test – Comparing Currents



Conclusion: The oil level in the H3 bushing is somewhere between the locations used for tests hot-collar tests 2 and 3.

Dielectric Loss



Dielectric Loss is the time rate at which electric energy is transformed into heat in a dielectric when it is subjected to an electric field. The heat generated is given in terms of Watts.

$$i_R \approx \text{Watts} \quad (\text{from vector diagram})$$

$$\text{Watts} = E I_R \quad (\text{from dielectric model circuit, parallel R/C network})$$

$$\text{Watts} = \textit{Normal losses} + \textit{Contamination} + \textit{Deterioration}$$

$$\textit{Contamination} = \textit{Water} + \textit{Carbon} + \textit{Dirt}$$

$$\textit{Deterioration} = \textit{Carbon} + \textit{Corona}$$

Watts



- Is the current created by polar contaminants in a dielectric that are influenced by electrical stress.
- Is the energy expended on these contaminants in the form of HEAT
- Is a function of Volume. The more insulation the more area there is to dissipate watts (from contamination, deterioration, and normal losses).
- To analyze Watts-Loss you need to be able to compare the dimension of the insulation tested -- difficult.
- If you had perfect insulation the testing current would be purely capacitive

The Term *Power Factor*

Describes:


- The phase angle relationship between the applied voltage across and the current through a specimen
- The ratio of the real or average power to the apparent power
- The efficiency of a power system in terms of real and reactive power flows

Basic Equation



Power = Voltage \times Current \times
Cosine(θ)


$$P = VI \cos(\theta) \quad C_P$$



Typical Insulation System

Good Insulation:
Has a very low
power factor

- $I_R \ll I_C$ for most insulation systems, $I_C \sim I_T$



Basic Power Factor




I_T = Total Current

I_C = Capacitive Current


I_R = Resistive Current

E = Applied Voltage

θ = Power Factor Angle



=



Power Factor Is:

$$\text{Watts} = E \times I_R$$

$$\text{Watts} = E \times I \times \text{Cosine } \Theta$$

$$\text{PF} = \text{Cosine } \Theta = \frac{\text{Watts}}{E \times I_T} =$$

$$\frac{E \times I_R}{E \times I_T} = \frac{I_R}{I_T}$$

What Is Power Factor (PF)?

$$\text{Power Factor} = \frac{W}{I_T * E} = \frac{\text{Real Power}}{\text{Apparent Power}}$$

To express power factor in percent (% PF), multiply by 100:

$$\% PF = \frac{W}{mA \times 10^{-3} * 10 \times 10^3} \times 100$$

$$= \frac{W \times 10}{mA}$$

10 kV equivalent values

Power Factor Is:

- Independent of specimen size

Useful for tabulations and comparisons

- Temperature sensitive

Needs to be corrected for liquid-filled apparatus


- Performed at or near apparatus frequency

Similar to normal operation

Basic Principals of Testing:




Always test the smallest piece possible



- Power factor testing measure the average condition of an insulation system
- Contamination would affect the total insulation system, but not to a large degree

Always break an insulation system into the Smallest possible part in order to detect insulation faults.



The contamination becomes a “bigger piece” of the insulation and is easier to see

Dielectric Loss and Power Factor:



What are they good for...

The Dielectric Loss and Power Factor are sensitive to soluble polar, ionic or colloidal materials:

Moisture (free, in cellulose, with particles in oil)

Products of Oxidation or mineral oil

Carbon (with moisture)


Metal Soaps

At Higher voltage:

Ionization in solid insulation



Is the Doble Test Effective for Detecting Defective Insulation?




$$PF_{\Sigma} = \frac{.5 + .5 + .5 + .5}{4} = .5\%$$

$$\frac{1}{c} = \frac{1}{2} + \frac{1}{2} + \frac{1}{2} + \frac{1}{2} = 2 \quad c = \frac{1}{2} pF$$

Is the Doble Test Effective for Detecting Defective Insulation?


2)



$$PF_{\Sigma} = \frac{.5 \times 3 + 2.5}{4} = 1.0 \quad c = \frac{1}{2} pF$$

Power Factor increases from 0.5% to 1.0%
no change in capacitance

Is the Doble Test Effective for Detecting Defective Insulation?




$$P F = \frac{.5 + .5 + .5}{3} = .5 \%$$

$$\frac{1}{c} = \frac{1}{2} + \frac{1}{2} + \cancel{\frac{1}{2}} + \frac{1}{2} \quad c = .667 \text{ pF}$$

Power Factor remains 0.5% with a 33% change in current


Changes in Power Factor

Case 1
Starting Condition




$W_{\text{Loss}} = 10$
 $C = 26,500 \text{ pF}$
 $\text{PF} = 1.00\%$
 $I_T \cong I_C$

Case 2
Contamination



$W_{\text{Loss}} = 100$
 $C = 26,500 \text{ pF}$
 $\text{PF} = 9.95\%$
 $I_T \cong I_C$

Case 3
Change in A , d , or ϵ




$W_{\text{Loss}} = 10$
 $C = 21,200 \text{ pF}$
 $\text{PF} = 1.25\%$
 $I_T \cong I_C$

Except for extreme cases, contamination has only a small effect on the measured current I_T .

A significant change in I_T is usually related to a change in capacitance; $I_T \cong I_C = E\omega C$.

Power Factor is affected by both contamination (watts) and capacitance (mA).

Power Factor Vs. Dissipation Factor



$$\text{Power Factor} = \cos \theta = \frac{I_R}{I_T}$$

$$\text{Dissipation Factor} = \tan \delta = \frac{I_R}{I_C}$$

θ°	% PF (%COS θ)	δ°	% DF (% TAN Δ)
90	0	0	0
89.71	<u>.500</u>	.29	<u>.500</u>
84.26	<u>10.00</u>	5.74	<u>10.05</u>
0	100.00	90	INFINITY




Comparison of Percent Power Factor With Percent Dissipation Factor for Various Phase Angles of Q and d

θ	% PF (% cos)	δ	% DF (% tan)
90	0	0	0
89.71	.50	.29	.50
87.13	5.00	2.87	5.00
84.26	10.00	5.74	10.05
81.37	15.00	8.63	15.18
53.13	60.00	36.87	75.00
45.00	70.71	45.00	100.00
0	100	90	infinity

Voids and the Power Factor Tip-Up Test




When we closely examine insulation, very small gaps or “voids” exist. These voids develop an electrostatic potential on their surfaces. These small gaps become ionized: Partial Discharge/Corona.



Power Factor Vs. Test Voltage

Tip-Up = Power Factor at Line-to-ground voltage -
Power Factor at 25% Line-to-ground voltage

As test voltage is increased, the power factor will increase depending on the void density.



Tip-up occurs in dry-type insulation specimens such as Dry Type Transformer, rotating machinery, and cables.

Calculation of Results

For 10 kV sets:

Calculation of Percent (%) Power Factor

% Power Factor = Watts x 10/Milliamperes

Calculation of Capacitance

Capacitance (pf) = 265 x Milliamperes (60 Hz)

Capacitance (pf) = 318 x Milliamperes (50 Hz)

Calculation of Parallel AC Resistance

R_P (Megaohms) = 100/Watts


(Equivalent 10kV values)



Safety



- ***Do Not Hold the High Voltage Cable While Test Voltage is Applied***
 - Reference: 1995 Doble Conference Paper, Page 1-2.1



Voltage is only on the ground shield when there is an abnormal condition.

Safety Issues


- One safety switch is for use by the test set operator; but since he cannot watch the apparatus while operating the test set, the other safety switch should be used by a designated safety observer
- Be aware that induced voltages or trapped charges may be present on the equipment to be tested, and be sure to drain these charges by applying grounds prior to making test connections
- ***Do not stand on equipment while testing is being performed.***

Safety Issues

- Be familiar with the M4000 manual's safety section in chapter one. Note, however, that your company rules and government regulations take precedence over Doble recommendations

Safety Features

- ✓ **Ground Relay**: two grounds connected to the M4000, assure continuity between them.
- ✓ **Safety Switches** : In good condition and both in use.
- ✓ **Safety Strobe** : Visible in the working area.
- ✓ **Safety Beeper**



NEVER place a jumper from the ground to the “chassis” ground on the test set

Safety

Prepare the Specimen for Testing

Safety meetings, de-energize, ground, isolate, safeguard, etc., observe your company's safety policy and in compliance with applicable safety regulations (OSHA, NFPA, etc).

Grounding the Test Equipment

The ground lead should always be the first test lead connected and the last test lead removed. This ensures that the test set chassis is safely grounded, and it removes touch potential hazards.

Safety

Static and Induced Voltages

To avoid exposure to static or induced voltages:

- **Ground before making test lead connections**
 - **Connect test leads to M4100 first and then to specimen**
 - **Ground before removing test lead from specimen**
 - **Remove test leads from specimen first and then from M4100**
- * Note: Proper protective equipment and live line tools must be utilized while applying and removing grounds.**

Safety

During Tests

Good Communication to avoid confusion, example of communication:

1. Operator - “Ready?”
2. Safety Lookout – Responds “Ready” if the connections are made and the work area is safe, or “No” if not ready and safe.
3. Operator – “Going hot.”
4. Safety Lookout – Echoes “Going hot” to acknowledge the operator.
5. Test is initiated ... completes.
6. Operator – “All Clear.” Operator extends the operators safety switch at arms length with the button released for all to see.

Safety


During Tests (continued)

Safety Lookout. The Safety Lookout should position himself in an area where he can observe all terminals and access points to the apparatus under test.

Safety Switches. The Safety Switches can be released at any time to terminate a test. This may be necessary if unauthorized personnel enter the area or if some other undesirable situation develops.

Testing with Personnel on the Specimen. Testing with personnel on the specimen is strongly discouraged.

Equipotential






Test Modes




Doble High-Voltage Test Cable



Outboard Pothead



Test Set Shielding System, GST Mode



Five Pieces of Information



- 1) Current
- 2) Watts Loss
- 3) Power Factor
- 4) Capacitance
- 5) Power Factor Vs. Voltage Characteristic

Basic Laws of Electricity



- A Difference in Potential Must Exist Between Two Points in order for current to flow
- Current Always Returns to It's Source!
- Current Always Takes the Path of Least Resistance (but current is on each path)

Components of Simplified Test Circuits

- Power Source
 - Current & Loss Meter
 - High-Voltage Test Cable
 - Low-Voltage Test Cable
 - Insulation Specimen
 - Test Ground
- Test Set Operation is Based on the Relative Positions of the Power Source, Current & Loss Meter, and the Insulation Specimen With Respect to the Various Test Leads.

Basic Test Circuits



- GST - Grounded-Specimen Test
 - The Grounded Specimen Tests Measures Current Flowing to Ground
- UST - Ungrounded Specimen Test
 - The Ungrounded Specimen Test Measures Current Flowing to an Ungrounded (Floating) Meter Circuit

• **GST** – The Low Voltage Lead can be **Grounded** or **Guarded**

• **UST** – The Low Voltage lead can be **Measured** or **Grounded**

Basic Test Circuits




GST - Grounded-Specimen Test

- In the GST, All Current Going to Ground is Measured

• UST - Ungrounded Specimen Test

- In the UST, No Ground Current is Being Measured

Test Modes




Kirchoff's Current Law – All current leaving must return. Therefore, by KCL all current leaving the test set through the HV Cable must return to it ... either through the LV Test Leads (red or blue) or the Ground Lead.

Internal to the M4100, test leads that are connected to the METER will be measured, and test leads that are connected to GUARD will not be measured.

We can choose to measure the RED LEAD, the BLUE LEAD, the GROUND LEAD, or ANY COMBINATION (any two, or all three) by specifying the correct TEST MODE.


The **TEST MODE** is specified in the DTAF software. It is an instruction that tells the M4100 which test leads to connect to the meter and which leads to connect to guard circuit.

Simplified Doble Test Circuit




Grounded-Specimen Test Mode (GST-Ground)

Doble Test Circuit




Simplified Doble Test Circuit




Grounded-Specimen Test Mode (GST-Guard)


Doble Test Circuit




Doble Test Circuit



Doble Test Circuit




Simplified Doble Test Circuit




Ungrounded-Specimen Test Mode (UST)


Doble Test Circuit




Doble Test Circuit




Doble Test Circuit




Doble Test Circuit



Doble Test Circuit



Doble Test Circuit



Analysis Of Data (General)

- Compare to nameplate data
- Compare to previous tests
- Compare to tests on identical apparatus type
- Review not only percent power factor, but current, watts, and capacitance as well
- Percent power factor that is much lower than expected is just as unacceptable as that which is much higher.
- A change in current or capacitance of 5% or more is cause for concern.
- If current is less than about 300 μ amps, do not calculate percent power factor; use watts instead. This applies at least to arresters, live tank breaker support columns, some breakers without grading capacitors, and the UST test across the contacts on vacuum and SF6 breakers.


Troubleshooting When Data Is Unacceptable

- Check all connections, including the ground lead. Make sure there is solid metal-to-metal contact
- Clean and dry porcelain surfaces and retest
- Check leads (using ohmmeter, expect less than one ohm conductor resistance; on LV Leads, measure between clip and pin 3)
- Check test set using self-diagnostic program
- Check test procedure and repeat test
- See M4000 manual for further tests



Power Apparatus Bushings






Major Bushing Types


- **Bulk Bushings**
 - A single bulk material provides the insulation
 - Bulk material may be porcelain, epoxy, polymer concrete, etc.
- **Gas Insulated**
 - Insulation provided by compressed gas (usually SF₆), and electrodes shaped for field control
 - Special type - usually a part of a circuit breaker, etc.
- **Condenser Bushings**
 - Insulation comprised of a condenser to control field distribution
 - These are the main topic of this presentation

A Typical Bulk Bushing



Gas Insulated Bushing


1. HV Terminal
2. Top closing plate
3. Inner conductor
4. Insulator
5. SF6 gas zone
6. Internal shield
7. Flange
8. Transport cover



Why Use a Condenser Bushing?

- In a **bulk type** bushing, the electrical field is **not evenly distributed** (very non-linear).
- On the outside of the bushing, the voltage **stress will be more concentrated** near the flange.
- Inside the bushing, the voltage **stress will be more concentrated** near the conductor, or in an oil gap.
- The **condenser provides control** over the distribution of the electric field, and therefore the electric stress levels.


Graded Bushing – Electrical Characteristics




Voltage stress is evenly distributed across the insulation.

As capacitive layers (i.e., C_A , C_B , etc.) are shorted out the overall capacitance, C_1 , increases.

Adding Capacitors in Series



Case 1: 3 Capacitors in Series




$$\frac{1}{C_{T1}} = \frac{1}{2} + \frac{1}{2} + \frac{1}{2} = \frac{3}{2}$$

$$C_{T1} = \frac{2}{3} \text{ .667pF}$$

$C_{T2} > C_{T1}$
 Shorting out
 a capacitor
 results in an
 increase in
 capacitance.

Case 2: Shorted Capacitor



$$\frac{1}{C_{T2}} = \frac{1}{2} + \frac{1}{2} = \frac{2}{2}$$


$$C_{T2} = 1$$

How the Condenser Works


- AC voltage fields essentially distribute according to the capacitances of the surroundings
- DC voltage fields distribute according to resistivities
- Discussion here is limited to AC voltages
- Condenser is an old term for a capacitor and it “condenses” the bushing
- Any two conductors, separated by an insulator, form a capacitor
- Each section in the condenser forms a capacitor
- These capacitances are much more significant than the stray capacitances of the surroundings
- The entire condenser then is comprised of several cylindrical capacitors in series

Voltage Distribution


- With and Without Capacitance Grading




Electric Field: Non-condenser & Condenser Bushing



Graded Bushing - Core Construction



Common Construction



**Distributed Capacitance
GE Type U**

Graded Bushing - Core Construction

- Alcohol-based conductive ink applied at winding stage of condenser




ABB O + C Construction





ABB O + C, 27 kV




Conductors


Components of a Typical Oil-Impregnated Capacitance-Graded Bushing



Typical Bushing Potential Tap Construction



Typical Bushing Test Tap Construction



Difference Between Power Factor Test and Potential Taps



Power Factor Test Tap

- Bushing Rated to ≤ 69 kV
- $C2$ (PF) $\sim C1$ (PF)
Except Lapp PRC >00-189100
- Doble Test Voltage: 500 V
Except Ohio Brass Class G and L
Bushing Taps, to which no more
than 250 Volts should be applied
- Tap cover 1 1/2 " or smaller
- Grounded in Service

Potential Tap

- Bushing Rated > 69 kV
- $C2$ (pF) $\sim C1 \times 10$ (pF)
or $C2 \gg C1$
- Doble Test Voltage: 2 kV
- Tap cover 2 1/2 " or larger
- In Service: Floating Supply
Voltage or Grounded





LAPP PRC BUSHING NEW DESIGN

Lapp PRC Bushing New Design



- Design Introduced February 2000
- Design Modification
 - Extra Grounded Layer
 - Shorts Out Epoxy Potting Compound
- Bushings With Serial Numbers 00-189100 And Higher

Lapp Type PRC Bushing Design Change



Bushing Tests



- Ungrounded-Specimen Test
 - Center Conductor to Tap, C_1
- Tap Insulation Test
 - Tap to Flange, C_2
- Hot Collar Test
 - Externally Applied Collar to Center Conductor
- Overall
 - Center Conductor to Flange

Investigative Bushing Tests




- Inverse Ungrounded-Specimen Test
 - Tap to Center Conductor, C1
 - Do Not Exceed Tap Voltage Rating
- Tip-up Test
 - Repeat C1 Test at 2 and 10 kV or 2 and L-G kV if Less Than 10kV
- Alternate C2 Test
 - GST Ground Test
 - Tap to Center Conductor (C1 + C2)
- Supplemental Hot Collar Tests

Bushing Test Set-Up



- Short-Circuit All Windings
- Clean Bushings to Minimize Surface Leakage
- Ground Opposite Winding
- Remove Test Tap Cover From Bushing Under Test Only
- Performed C1, Main Core Insulation Test in UST Mode
- Perform C2, Tap Test in GST-Guard Mode
- Replace Test Tap Cover


Test Connections for Bushing C1 Test



Transformer Bushings

- Prior to Bushing Tests, Ensure
 - High Side Winding Shorted
 - Low Side Winding Shorted Including Neutral
- WHY???

Higher Than Normal Power Factor Values
May Be Obtained




- NOTE Remove Only One Tap Cover at a time....


Bushing Test Set-Up




Test Setup: Which Bushing Under Test is Connected With the Winding Short-Circuited?

Procedure:	Power Factor	
	Incorrect	Correct
		
Phase A	0.60%	0.39%
Phase B	0.65%	0.40%
Phase C	0.56%	0.39%

Main-Insulation/C1 Test Standard Method



Dielectric Circuit - Main Insulation C1 Test



Typical C1 Test Data



Description	Current (mA)	Watts	%PF
Typical Good Bushing	1.08	0.03	.28
Same Bushing, Contaminated	1.09	0.06	.55
Same Bushing, Shorted Condenser layers	1.19	0.04	.34

C1 Test Result Analysis



Power Factor

- Modern Condenser Type Bushings
 - Generally of the Order of **0.5%**
 - Temperature Correction to 20 Degrees C
- Deteriorated Bushings
 - Generally Between **0.5% to 1.0%**
- Investigate Bushings
 - Above **1.0%**

EXCEPTIONS...

C1 Test Result Analysis



Current/Capacitance

- Suggested Limits
 - + 5% - Investigate
 - + 10% - Investigate/Remove From Service

General Electric Company



Type	Description	Typical PF	Questionable PF
*A	Through Porcelain	3.0%	5.0%
**A	High Current	1.0%	2.0%
*B	Flexible Cable, Compound Filled	5.0%	12.0%
D	Oil Filled Upper Portion, Sealed	1.0%	2.0%
F	Oil Filled, Sealed	0.7%	1.5%
L	Oil Filled Upper Portion, Sealed	1.5%	3.0%
LC	Oil Filled Upper Portion, Sealed	0.8%	2.0%
OF	Oil Filled Expansion Chamber	0.8%	2.0%
*S	Force C & CG, Rigid Core, Compound Filled	1.5%	6.0%

* Type S, Form F, DF & EF (flexible cable) redesigned as Types B, BD, and BE, respectively. Type S, no Form letter (through porcelain) redesigned as Type A

LAPP Insulator Division



	Typical C1 <u>PF</u>	Questionable C1 <u>PF</u>
Type ERC (Epoxy-Resin-Core, Plastic or Oil Filled)	0.8%	1.5%
Type PRC and PRC-A (Paper-Resin-Condenser Core)	0.8%	1.5%

Typical C2 power factors for older PRC design range from 4-15% due to injected compound used during manufacturing.

Ohio Brass Company



<hr/>	<u>Typical %PF</u>	<u>Questionable %PF</u>
Class LK-Type A, 23 to 69 kV	0.4	1.0
ODOF, Class G, and Class L Oil-Filled:		
Prior to 1926 and after 1938	1.0-5.0	Change of 22% from initial
Between 1926 and 1938	2.0-4.0	Change of 16% from initial
Type S, OS, and FS	0.8	2.0
On OCB and Inst. Trans. 69 kV and below (except Types S, OS, and FS)	1.5	3.0

Westinghouse




	<u>Typical %PF</u>	<u>Questionable %PF</u>
On OCB and Inst. Trans. 92 kV to 139 kV (except Types O, O-A1, OC and O Plus)	1.5	3.0
On Power and Dist Trans of all rating, and OCB & Inst. Trans. 161 kV to 288 kV (except Types O, O-A1, OC, and O Plus)	1.0	2.0
All Type D Transformer Bushings (Semi-Condenser)	1.5	3.0
Type RJ (Solid Porcelain)	1.0	2.0

Negative Power Factor Value




- Typically Created Due to a High Resistance Leakage Path to Ground
- Conditions:
 - Extensive Surface Contamination
 - Lower Porcelain
 - Upper Porcelain
 - Poor Grounding of Bushing Flange
 - Tracking Over the Internal Insulation to the Bushing

$$I_{T'} = I_T - I_L$$



$I_{R\ UST} = \text{Real Component of } I_T,$





$$W_{UST} = I_{R\ UST} * E$$

but, $I_{R\ UST}$ is negative

Resistive Path-to-Ground Negative Power Factor

ABB Type O+C Bushing, Surface Contamination



Test / Mode	Test KV	mA	W	%PF
C1 / UST	10	1.313	-0.007	-0.053


Haefely Tap Used During Factory Tests




- Some Haefely Bushings, 115kV and Above
 - Factory Measures C1 Capacitance With a Special Tap Only Available at Factory
 - Variance in Test Procedure Results in Field Test Results Being 5% or Higher Than Nameplate Values
 - The C1 Capacitance in the Field Must be Modified by Using the Equation Below:

$$\underline{C1(\text{Doble Test})} = \frac{(C1(\text{Haefely}) * C2(\text{Haefely}))}{(C2(\text{Haefely}) - C1(\text{Haefely}))}$$


Haefely Tap Used During Factory Tests




Haefely Tap Used During Factory Tests




Tap-Insulation - C2 Test - Standard Method



Dielectric Circuit - Tap Insulation C2 Test



C2 Tap Adapters



Westinghouse Type O

**Various ASEA
GO Types**


**Westinghouse
Types OS, S**

**Westinghouse
Type O Plus**



Westinghouse Type 0, C2 Tap Adapter



Westinghouse Type 0S and S, C2 Tap Adapter



Westinghouse Type 0 +, C2 Tap Adapter



ASEA Type GO



Environment: Factors Affecting Capacitance Tests




- Length of Outer Grounded Condenser Layer
- Physical Movement of Paper Core
- Condition of Tap Connection
- Distance From Bushing to Grounded Tank Wall

Bushing With Test Tap In Testing Tank versus In Transformer Tank



Capacitance C_2 varies depending on the length of the grounded outer condenser layer, and is made up of C_2 , C_2' , etc

$$C_2 = C_2 + C_2'$$



- **Why Perform C2 Tests ??????**



C2 TESTS



- Internal Flashover Around the Main Core is a **Real and Serious Threat** to all Sealed Capacitance Graded Bushings
- The C2 Power Factor Test has Been Shown, in Some Cases, to be a More Apparent Indicator of Internal Fluid Contamination Than the C1 Test


C2 TESTS



GE Type U 230kV Bushing:

Date	C1		C2	
	%PF	Cap	%PF	Cap
1/6/82	.31	508.8	.28	4134
5/1/96	.58	510.2	2.26	4138

1/30/97 Failed in service



C2 TESTS



Example:

McGraw-Edison Type PA 23kV Bushings

<u>Bushing #</u>	<u>C1(%PF)</u>	<u>C2(%PF)</u>
X1	0.46	0.50
X2	0.60	2.78
X3	0.45	0.50

- X2 was removed from service and found to have highly contaminated fluid with low dielectric-breakdown strength

Spare Bushings



- Do Not Test Bushings in Wooden Crate or Stand
- Support Bushing on a Metal Stand if Possible
- Web Slings May be Used for Tests
 - Cleanliness of Sling May Affect Test Results
 - Sling Should be Kept Clear of Energized Points

Spare Bushings



- Connect Ground Lead Directly to Bushing Flange
- Ground Both Test Set and Specimen to Substation Ground
- Clean Upper and Lower Surfaces Before Testing

DTA Spare Bushing Test Screen



Overall Test Setup													
Connections						Inputs			Test Results				
#	Test	HV Lead	Ground	Red Measure Lead	Test Mode	Skirt #	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1	C1	Conductor	Flange	Tap	UST RB		10.000	1.06	1.489	0.038	0.255	0.271	394.9
2	C2	Tap	Flange	Conductor	GAR RB		1.999	1.00	15.786	0.435	0.276	0.276	4187.2
3	Overall	Conductor	Flange	Unused	GND RB		10.000	1.06	1.501	0.041	0.273	0.290	398.1
4	C1+C2	Tap	Flange	Conductor	GND RB		2.000	1.00	17.276	0.444	0.257	0.257	4582.5
5	Inverted-UST	Tap	Flange	Conductor	UST RB		1.999	1.00	1.489	0.042	0.282	0.282	395.0
Hot Collar Tests													
6	Hot Collar	Collar	Flange	Conductor	GND RB		10.000	1.00	0.111	0.030	2.703	2.703	29.5
Miscellaneous Tests													

Note that Tests 1 & 2 add up to match Test 4

17.275 mA 0.473 watts

Note that Tests 1 & 5 are “equal”


DTA Spare Bushing Test Screen



Overall Test Setup															
Connections						Inputs			Test Results					Ratings	
#	Test	HV Lead	Ground	Red Measure Lead	Test Mode	Skirt #	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™	Manual
1	C1	Conductor	Flange	Tap	UST RB		10.000	1.06	1.489	0.038	0.255	0.271	394.9	Good	Unrated
2	C2	Tap	Flange	Conductor	GAR RB		1.999	1.00	15.786	0.435	0.276	0.276	4187.2	Good	Unrated
3	Overall	Conductor	Flange	Unused	GND RB		10.000	1.06	1.501	0.041	0.273	0.290	398.1	Good	Unrated
4	C1+C2	Tap	Flange	Conductor	GND RB		2.000	1.00	17.276	0.444	0.257	0.257	4582.5	Good	Unrated
5	Inverted-UST	Tap	Flange	Conductor	UST RB		1.999	1.00	1.489	0.042	0.282	0.282	395.0	Good	Unrated
Hot Collar Tests															
6	Hot Collar	Collar	Flange	Conductor	GND RB		10.000	1.00	0.111	0.030	2.703	2.703	29.5	Good	Unrated
Miscellaneous Tests															

FRANK Provides Ratings!

Bushing Overall Test





Bushing Hot-Collar Test – When To Perform

1. Compound-Filled Bushings
2. Solid Porcelain Bushings
3. Gas-Filled Bushings
4. Oil Filled Bushings Not Equipped With Taps and Overall Test Cannot be Performed:
 - a) Single Hot-Collar Test on Small Bushings 15 kV and Below
 - b) Several Single Hot-Collar Tests for Bushings Rated Above 15 kV



Bushing Hot-Collar Test

When To Perform

5. Check Oil Level on all Liquid-Filled Bushings Without Liquid-Level Gauges or Sight Glass
6. Check Bushing With Liquid-Level Gauges Whenever the Gauge is Suspect
7. As Supplementary Test When Overall, UST, Tap Tests Indicate Possible Problem

Doble Hot Collar Test



Test Voltage: 10 kV

Recommended Acceptable Limits:


Watts

Current

≤ 0.1 Watts

Similar for Same
Type Bushings


Single Hot Collar Test - UST Mode



Test Includes

- Portion of Insulating Weathershed
- Sight-Glass
- Core Insulation in Upper Area
- Liquid or Compound Filler in the Upper Area


Single Hot Collar Test - GST-Ground Mode



Test Includes

- Portion of Insulating Weathershed
- Sight-Glass
- Core Insulation in Upper Area
- Liquid or Compound Filler in the Upper Area
- Surface leakage from Collar to LV lead & to bushing flange

Hot Collar Test – Comparing Currents



Conclusion: The oil level in the H3 bushing is somewhere between the locations used for tests hot-collar tests 2 and 3.

Hot Collar Test Result Analysis



Hot Collar Test Results

- Increased Watt-Losses
 - Contamination of the Insulation
 - Maximum Acceptable Limit, 0.1 W
- Decreased Current (Amperes)
 - Voids
 - Low Liquid or Compound Level

Typical Hot-Collar Test Data



Description	Current (mA)	Watts
Typical Good Bushing	.090	0.02
Same Bushings, Contaminated	.095	0.31
Same Bushing, Low Liquid Level	.070	0.02

Hot Collar Test Results Westinghouse, Type "S"



Good Condition

Bushing	Current	Watts
X1	110 μ A	0.06
X2	110 μ A	0.04
X3	110 μ A	0.05

General Contamination

Bushing	Current	Watts
X1	110 μ A	0.16
X2	110 μ A	0.18
X3	110 μ A	0.17

Physical Changes (X2)

Bushing	Current	Watts
X1	110 μ A	0.06
X2	80 μ A	0.05
X3	110 μ A	0.05

Defective Bushing (X3)

Bushing	Current	Watts
X1	110 μ A	0.06
X2	110 μ A	0.05
X3	120 μ A	0.20

Bushing Diagnostic Tests

Low Voltage Lead


Test Includes

- Main C1 Core Insulation


**UST
Inverted C1 Test Method**

Caution: See C2 Test Voltages!

High Voltage Cable



Inverted C1 Test



Low Voltage Lead


Test Includes

- Tap Insulation
- Core Insulation between tapped Layer and Bushing Ground Sleeve
- Portion of Liquid or Compound Filler
- Portion of Weathershed near Flange
- C1 Insulation

Test Mode: GST-Ground

High Voltage Cable

Tap-Insulation/C2 Test Alternate Method




Guard

C1+ C2

Ground Lead

C1 + C2 Test



Power Factor Tip Up Tests



- Perform C1 Test at 2 kV
- Perform C1 Test at 10 kV
- Compare Power Factor Values at 2kV and 10kV

Factory VS Field Test Results



REMEMBER:

- The Test Circuits Used are Generally the Same, BUT NOT ALWAYS
- The Environment is More Controlled in the Factory Setting
- Bushing Placement May Different
- Grounding May be Different

Client Recommended Bushing Cleaners

•Client Recommendations:

- Dry Clean Cloth
- Water & Soap
- Collonite™
- PF Solvent (LPS)
- Windex™ with Ammonia
- Apply Heat to Fully Dry all Surfaces



Do Not Use Evaporative Materials



Field Technique Problems

- **Drying Tap Area With Heat**
 - May Result in Power Factor Values Affected by Temperature
- **Cleaning Porcelain Surface With Alcohol-Based or Evaporative Cleaner**
 - May Cool Surface When Cleaner Evaporates, Resulting in Further Condensation
- **Leads Used to Short-Circuit Bushings**
 - To Avoid Stray Capacitive Currents to Ground, Leads Should Not Sag Near Tank Surface

When Bushing Tests Are Doubtful



- Re-Check All Connections, Including Ground Lead and Bushing Flange Ground
- Check Test Circuit Used
- Check Test Set and Test Set Leads
- Visually Inspect Bushing Sheds and Oil
- Clean and Dry All Surfaces

When Bushing Tests Are Doubtful



- Compare and Analyze Results of Identical Bushings
- Research Bushing History of Flashovers or Line Surges
- Verify Temperature Correction Factor Was Used for C1 and Overall Tests *
- Verify the Necessary Fields in the Nameplate Were Used in Order for DTA to Identify the Correct Limit File.

* Note C2 Power Factors Are Not Temperature Corrected

Bushing Temperature Correction



**TABLE OF MULTIPLIERS FOR USE IN CONVERTING POWER FACTORS
AT TEST TEMPERATURES TO POWER FACTORS AT 20°C**

BUSHINGS													
ABB		ASEA	BROWN BOVERI		TEST TEMPERATURES		GENERAL ELECTRIC					HAEFELY	
Type T	Type O + C	All GO Types 25-765 kV	Types CTF, CTKF 20-60 kV	Types CTF, CTKF 85-330 kV	°C	°F	Type B	Type F	Types L, LC, LI, LM	Types OF, OFI, OFM	Types S, SI, SIM (Cpd.-Filled)	Types TandU	Types COT, COS, SOT
1.02	.87	.79	1.24	1.00	0	32.0	1.09	.93	1.00	1.18	1.26	1.02	—
1.02	.89	.81	1.22	↑	2	35.6	1.09	.95	1.00	1.16	1.24	1.02	—
1.02	.91	.83	1.20	↑	4	39.2	1.09	.97	1.00	1.15	1.21	1.02	—
1.01	.92	.85	1.17	↑	6	42.8	1.08	.98	1.00	1.13	1.19	1.01	—
1.01	.93	.87	1.15	↑	8	46.4	1.08	.99	1.00	1.11	1.16	1.01	—
1.01	.94	.89	1.12	↑	10	50.0	1.07	.99	1.00	1.10	1.14	1.01	0.88
1.01	.95	.92	1.10	↑	12	53.6	1.06	.99	1.00	1.08	1.11	1.01	0.90
1.01	.96	.94	1.08	↑	14	57.2	1.05	1.00	1.00	1.06	1.08	1.01	0.93
1.00	.98	.95	1.05	↑	16	60.8	1.04	1.00	1.00	1.04	1.06	1.00	0.95
1.00	.99	.98	1.03	↑	18	64.4	1.02	1.00	1.00	1.02	1.03	1.00	0.98
1.00	1.00	1.00	1.00	1.00	20	68.0	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.00	1.01	1.03	.98	↓	22	71.6	.97	.99	.99	.97	.97	1.00	1.02
1.00	1.02	1.05	.96	↓	24	75.2	.93	.97	.99	.94	.93	1.00	1.04
.99	1.03	1.07	.94	↓	26	78.8	.90	.96	.98	.91	.90	.99	1.07
.99	1.04	1.09	.91	↓	28	82.4	.85	.94	.97	.88	.87	.99	1.09
.98	1.05	1.12	.88	↓	30	86.0	.81	.92	.96	.86	.84	.98	1.11
.97	1.06	1.14	.86	↓	32	89.6	.77	.89	.95	.83	.81	.97	1.13
.97	1.07	1.17	.84	↓	34	93.2	.73	.87	.94	.80	.77	.97	1.15
.96	1.07	1.19	.82	↓	36	96.8	.69	.84	.93	.77	.74	.96	1.17
.95	1.08	1.21	.80	↓	38	100.4	.65	.81	.91	.74	.70	.95	1.19
.94	1.08	1.23	.78	↓	40	104.0	.61	.78	.89	.70	.67	.94	1.21
.93	1.09	1.26	.76	↓	42	107.6	—	.74	.87	.67	.63	.93	1.22
.91	1.10	1.28	.74	↓	44	111.2	—	.70	.85	.63	.60	.91	1.24
.89	1.10	1.30	.72	↓	46	114.8	—	.64	.83	.61	.56	.89	1.25
.87	1.11	1.31	.70	↓	48	118.4	—	.58	.82	.58	.53	.87	1.26
.86	1.11	1.33	.68	↓	50	122.0	—	.52	.80	.56	.50	.86	1.27
.84	1.11	1.34	.66	↓	52	125.6	—	—	.79	.53	.47	.84	1.28
.82	1.11	1.36	.64	↓	54	129.2	—	—	.78	.51	.44	.82	1.29
.79	1.11	1.37	.62	↓	56	132.8	—	—	.77	.49	.41	.79	1.30
.77	1.12	1.37	.60	↓	58	136.4	—	—	.76	.46	.38	.77	1.29
.75	1.12	1.38	.58	↓	60	140.0	—	—	.74	.44	.36	.75	1.27

DTA - Fields Required To Activate Temperature Correction Factor



- Manufacturer
- Type
- Ambient Temperature (Probe)
- Apparatus Temperature
 - Transformer - Oil Temperature
 - Oil Circuit Breaker - Ambient Temperature

DTA - Fields Required To Identify Correct Limit File



- Manufacturer
- Type
- KV

Resistive Coatings on Bushings



- **Semi-Conductive Glaze Coating**

- **Reason:**

- To Control Voltage Distribution
- To Reduce Flashover Problems Under Contaminated Conditions

- **Power Factor Tests Affected by Highly Resistive Surface Leakage**

- Refer to the 1974 Doble Client Conference paper “Doble Tests on Bushings Equipped with Resistance-Graded Porcelains.
(Section 4-101)



Transformers




Transformer Outline



- Introduction
- Safety
- Test Procedures

Free Breather Tank Transformer




Breather,
often has
desiccant
material to
dry the air.

Sealed Tank Transformer

A volume of gas is above the oil and is sealed from the atmosphere.

Reference:
GEI-28013D
GEI-70369



← Pressure-vacuum bleeder.


For safety, normally does not operate.

Reference:
GEI-54928D

Gas (Nitrogen) Blanketed Tank Transformer Automatic Gas Seal System

A volume of dry nitrogen is maintained above the oil and is sealed from the atmosphere.

Reference:
GEI-70366
GEK-19695B




High nitrogen pressure may operate a relief valve during times of high oil expansion due to heating. Nitrogen enters as the oil cools and reduces in volume. There is a low pressure alarm.

Gas-Oil Sealed Tank Transformer



A volume of gas is above the oil in the main tank which can move in and out of an expansion tank. The oil in the expansion tank isolates the gas above the oil from the atmosphere.


Reference:
GEI-28012A



Open Conservator Tank Transformer Conservator Oil-Preservation System, COPS

The atmosphere is in contact with a small portion of oil in the conservator tank.


Reference
GEI-70368C



Modern Sealed Conservator Tank Transformer Atmosseal Oil Preservation System

The atmosphere is separated from the oil by an expandable bladder. A breather is provided directly into the bladder to allow for the expansion.

Reference
GEI-70367
GEK-29290



Apparatus and Personal Safety




- Connect the Doble Test Set Safety Ground Cable First
Connect the Safety Ground Cable to the Apparatus Ground Point, Then Connect to the Doble Test Instrument
- The Order of Connection of the Remaining Test Set Cables is Not Critical; However, All Cables Should be Connected to the Test Instrument Before Connecting to the Apparatus Under Test



Two Winding Transformers



Physical Representation of a Three-Phase Two-Winding Transformer



Dielectric Circuit: Two Winding Transformer

- C_H** - Insulation between the High-Voltage Winding Conductors and the Grounded Tank & Core
- High Voltage Bushings
 - Winding Insulation
 - Structural Insulating Members
 - DETC Insulation
 - Insulating Fluid

Dielectric Circuit: Two Winding Transformer

- C_L** - Insulation Between the Low-Voltage Winding Conductors and Grounded Tank & Core
- Low Voltage Bushings
 - Winding Insulation
 - Structural Insulating Members
 - LTC
 - Insulating Fluid

Dielectric Circuit: Two Winding Transformer

C_{HL} - Insulation between the High and Low-Voltage Windings

- Winding Insulation Barriers
- Insulating Fluid

Review of Test Sheet



Overall Test Setup													
Connections					Inputs		Test Results					Ra	
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™	
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0		
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6		Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7		Good
4	Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265	0.247	5158.4		
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9		
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4		Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0		
8	Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270	0.252	5159.5		Good
Winding without Attached Bushing Calculation													
	CH-C1			CH'		0.93	5.319	0.085	0.160	0.150	1410.8		
	CL-C1			CL'		0.93	43.375	2.424	0.559	0.522	11505.4		



Transformer Overall Tests




Important – LTC Must Be Off Neutral


Load Tap Changers

If the transformer contains a LTC, then it should be ***moved to any non-neutral tap position*** for/during overall power factor testing.


Certain LTC schemes contain ***non-linear resistor elements*** (surge protection) that may cause abnormal test results (high or negative power factors) if tested in the neutral tap position.




Transformer Overall Tests



Test Connections - Primary




Test Procedure - Test #1: Measure $C_H + C_{HL}$




GST – GROUND RED/BLUE

Test Procedure - Test #2: Measure C_H



GST – GUARD RED/BLUE

Test Procedure - Test #3: Measure C_{HL}



UST – MEASURE RED/BLUE

Verify that the Primary tests were performed correctly

Overall Test Setup													
Connections					Inputs		Test Results					Remarks	
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™	
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0		
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6	G	Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7	G	Good
4	Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265	0.247	5158.4		
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9		
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4	D	Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0		
8	Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270	0.252	5159.5	G	Good
Winding without Attached Bushing Calculation													
	CH-C1			CH'		0.93	5.319	0.085	0.160	0.150	1410.8		
	CL-C1			CL'		0.93	43.375	2.424	0.559	0.522	11505.4		

$$\text{Test 2 mA} + \text{test 3 mA} = \text{Test 1 mA}$$

$$(\text{CH}) + (\text{CHL}) = (\text{CH} + \text{CHL})$$

Same for the Watts

Verify that the Primary tests were performed correctly


Overall Test Setup													
Connections					Inputs		Test Results					Rat	
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™	
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0		
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6	G	Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7	G	Good
4	Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265	0.247	5158.4		
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9		
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4	D	Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0		
8	Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270	0.252	5159.5	G	Good
Winding without Attached Bushing Calculation													
	CH-C1			CH'		0.93	5.319	0.085	0.160	0.150	1410.8		
	CL-C1			CL'		0.93	43.375	2.424	0.559	0.522	11505.4		

Test1 – Test 2 = Calculated UST (Test 4)


Test 3 and Test 4 should be equal

Same for the Watts


Test Connections - Secondary



Test Procedure-Rotate Test Leads




Test Procedure-Test #5: Measure C_L+C_{HL}




GST – GROUND RED/BLUE

Test Procedure-Test #6: Measure C_L



GST - GUARD RED/BLUE

Test Procedure-Test #7: Measure C_{HL}



UST – MEASURE RED/BLUE



Verify that Secondary tests were performed correctly

Overall Test Setup												
Connections					Inputs		Test Results					Re
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0	
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6	Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7	Good
4	Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265	0.247	5158.4	
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9	
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4	Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0	
8	Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270	0.252	5159.5	Good
Winding without Attached Bushing Calculation												
	CH-C1			CH'		0.93	5.319	0.085	0.160	0.150	1410.8	
	CL-C1			CL'		0.93	43.375	2.424	0.559	0.522	11505.4	

Test 6 ma + Test 7 ma = Test 5 mA

$$(CL) + (CHL) = (CL + CHL)$$

Same for the Watts



Verify that Secondary tests were performed correctly

Overall Test Setup												
Connections					Inputs		Test Results					Ask FRANK™
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0	
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6	G Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7	G Good
4	Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265	0.247	5158.4	
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9	
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4	D Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0	
8	Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270	0.252	5159.5	G Good
Winding without Attached Bushing Calculation												
	CH-C1			CH'		0.93	5.319	0.085	0.160	0.150	1410.8	
	CL-C1			CL'		0.93	43.375	2.424	0.559	0.522	11505.4	

Test 5 – Test 6 = Calculated UST (Test 8)

Test 7 and Test 8 should be equal

Same for the watts



Verify that Secondary tests were performed correctly

Overall Test Setup												
Connections				Inputs		Test Results					Remarks	
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0	
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6	Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7	Good
4	Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265	0.247	5158.4	
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9	
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4	Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0	
8	Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270	0.252	5159.5	Good
Winding without Attached Bushing Calculation												
				CH'		0.93	5.319	0.085	0.160	0.150	1410.8	
				CL'		0.93	43.375	2.424	0.559	0.522	11505.4	

Tests (lines) 3, 4 , 7 and 8 should be equal as all are the CHL insulation



Two-Winding Transformer Overall Test Sheet

Overall Test Setup

		Connections			Inputs		Test Results				Rate	
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™
1				CH+CHL	10.001	0.93	28.817	0.682	0.237	0.221	7644.0	
2	HV Winding	LV Winding	Unused	CH	10.001	0.93	9.371	0.167	0.179	0.167	2485.6	G Good
3				CHL(UST)	10.001	0.93	19.448	0.513	0.264	0.247	5158.7	G Good
4				Test 1 - Test 2 (calculated)			CHL		0.93	19.447	0.515	0.265
5				CL+CHL	10.002	0.93	62.826	2.948	0.469	0.439	16664.9	
6	LV Winding	HV Winding	Unused	CL	10.002	0.93	43.375	2.424	0.559	0.522	11505.4	D Deteriora...
7				CHL(UST)	10.002	0.93	19.449	0.515	0.265	0.247	5159.0	
8				Test 5 - Test 6 (calculated)			CHL		0.93	19.451	0.525	0.270

Winding without Attached Bushing Calculation

CH-C1	CH'	0.93	5.319	0.085	0.160	0.150	1410.8	
CL-C1	CL'	0.93	43.375	2.424	0.559	0.522	11505.4	



CH' and CL' on OVERALL

After bushing tests, CH' and CL' can be calculated.

CH' Calculations



	N	ENG	GND	GAR	UST	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Meas	Rtg	Rtg
1	<input type="checkbox"/>	H	L			10	30.980	0.829	0.27	0.22	0.81	8219	CH + CHL		
2	<input type="checkbox"/>	H		L		10	11	0.248	0.23	0.19	0.81	2918	CH	G	G
3	<input type="checkbox"/>	H			L	10	19.970	0.578	0.29	0.23	0.81	5299	CHL(UST)	G	G
4	<input type="checkbox"/>	(1-2)					19.980	0.581	0.29	0.23	0.81	5301.0	CHL	G	G
5	<input type="checkbox"/>	L	H			10	65.410	1.907	0.29	0.23	0.81	17351	CL + CHL		
6	<input type="checkbox"/>	L		H		10	45.430	1.328	0.29	0.23	0.81	12051	CL	G	G
7	<input type="checkbox"/>	L			H	10	19.970	0.576	0.29	0.23	0.81	5299	CHL(UST)	G	G
8	<input type="checkbox"/>	(5-6)					19.980	0.579	0.29	0.23	0.81	5300.0	CHL	G	G
9	<input type="checkbox"/>	CH-C1					5.677	0.128	0.23	0.19	0.81	1506.4	CH'	G	G
10	<input type="checkbox"/>	CL-C1					36.843	1.111	0.30	0.24	0.81	9773.5	CL'	G	G

Line 9 is the CH without the bushings

C1				C2										
N	BH	Serial Number	NP %PF	NP Cap.	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Rtg	Rtg	
<input type="checkbox"/>	H1	▼ 1766473	.23	360	10	1.333	0.030	0.23	0.23	1.00	353.40	G	G	
<input type="checkbox"/>	H2	▼ 1766470	.23	359	10	1.333	0.030	0.23	0.23	1.00	353.60	G	G	
<input type="checkbox"/>	H3	▼ 1766471	.23	357	10	1.323	0.030	0.23	0.23	1.00	350.80	G	G	
<input type="checkbox"/>	H0	▼ 1766472	.23	359	10	1.334	0.030	0.22	0.22	1.00	353.80	G	G	
<input type="checkbox"/>	X1	▼ 2093510	.27	564	10	2.114	0.054	0.26	0.26	1.00	560.80	G	G	
<input type="checkbox"/>	X2	▼ 2093509	.26	571	10	2.138	0.053	0.25	0.25	1.00	567	G	G	

CH' Calculations



C1				C2									
N	BH	Serial Number	NP %PF	NP Cap.	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Rtg	Rtg
<input type="checkbox"/>	H1	1766473	.23	360	10	1.333	0.030	0.23	0.23	1.00	353.40	G	G
<input type="checkbox"/>	H2	1766470	.23	359	10	1.333	0.030	0.23	0.23	1.00	353.60	G	G
<input type="checkbox"/>	H3	1766471	.23	357	10	1.323	0.030	0.23	0.23	1.00	350.80	G	G
<input type="checkbox"/>	H0	1766472	.23	359	10	1.334	0.030	0.22	0.22	1.00	353.80	G	G
<input type="checkbox"/>	X1	2093510	.27	564	10	2.114	0.054	0.26	0.26	1.00	560.80	G	G
<input type="checkbox"/>	X2	2093509	.26	571	10	2.129	0.052	0.25	0.25	1.00	567	G	G

Sum of the H bushings C1 tests currents

$$1.333 + 1.333 + 1.323 + 1.334 = 5.323 \text{ mA}$$

CH' Calculations



	N	ENG	GND	GAR	UST	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Meas	Rtg	Rtg
1	<input type="checkbox"/>	H	L			10	30.980	0.829	0.27	0.22	0.81	8219	CH + CHL		
2	<input type="checkbox"/>	H		L		10	11	0.248	0.23	0.19	0.81	2918	CH	G	G
3	<input type="checkbox"/>	H			L	10	19.970	0.578	0.29	0.23	0.81	5299	CHL(UST)	G	G
4	<input type="checkbox"/>	(1-2)					19.980	0.581	0.29	0.23	0.81	5301.0	CHL	G	G
5	<input type="checkbox"/>	L	H			10	65.410	1.907	0.29	0.23	0.81	17351	CL + CHL		
6	<input type="checkbox"/>	L		H		10	45.430	1.328	0.29	0.23	0.81	12051	CL	G	G
7	<input type="checkbox"/>	L			H	10	19.970	0.576	0.29	0.23	0.81	5299	CHL(UST)	G	G
8	<input type="checkbox"/>	(5-6)					19.980	0.579	0.29	0.23	0.81	5300.0	CHL	G	G
9	<input type="checkbox"/>	CH-C1					5.677	0.128	0.23	0.19	0.81	1506.4	CH'	G	G
10	<input type="checkbox"/>	CL-C1					36.843	1.111	0.30	0.24	0.81	9773.5	CL'	G	G

Line 9 is the CH without the Primary Bushings

Sum of the Primary Bushings C1 tests currents

$$1.333 + 1.333 + 1.323 + 1.334 = 5.323 \text{ mA}$$

$$\text{Line 2 mA} - \text{Sum of C1 mA} = \text{Line 9 mA}$$

$$11\text{mA} - 5.323 \text{ mA} = 5.677 \text{ mA}$$

CL' Calculations



C1			C2										
N	BH	Serial Number	NP %PF	NP Cap.	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Rtg	Rtg
<input type="checkbox"/>	X1	2093510	.27	564	10	2.114	0.054	0.26	0.26	1.00	560.80	G	G
<input type="checkbox"/>	X2	2093509	.26	571	10	2.138	0.053	0.25	0.25	1.00	567	G	G
<input type="checkbox"/>	X3	2093508	.27	584	10	2.189	0.054	0.25	0.25	1.00	580.50	G	G
<input type="checkbox"/>	X0	2093505	.26	574	10	2.146	0.056	0.26	0.26	1.00	569.20	G	G
<input type="checkbox"/>													
<input type="checkbox"/>													

Sum of the Secondary Bushings C1 tests currents

$$2.114 + 2.138 + 2.189 + 2.146 = 8.587 \text{ mA}$$

CL' Calculations



	N	ENG	GND	GAR	UST	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Meas	Rtg	Rtg
1	<input type="checkbox"/>	H	L			10	30.980	0.829	0.27	0.22	0.81	8219	CH + CHL		
2	<input type="checkbox"/>	H		L		10	11	0.248	0.23	0.19	0.81	2918	CH	G	G
3	<input type="checkbox"/>	H			L	10	19.970	0.578	0.29	0.23	0.81	5299	CHL(UST)	G	G
4	<input type="checkbox"/>	(1-2)					19.980	0.581	0.29	0.23	0.81	5301.0	CHL	G	G
5	<input type="checkbox"/>	L	H			10	65.410	1.907	0.29	0.23	0.81	17351	CL + CHL		
6	<input type="checkbox"/>	L		H		10	45.430	1.328	0.29	0.23	0.81	12051	CL	G	G
7	<input type="checkbox"/>	L			H	10	19.970	0.576	0.29	0.23	0.81	5299	CHL(UST)	G	G
8	<input type="checkbox"/>	(5-6)					19.980	0.579	0.29	0.23	0.81	5300.0	CHL	G	G
9	<input type="checkbox"/>	CH-C1					5.677	0.128	0.23	0.19	0.81	1506.4	CH'	G	G
10	<input type="checkbox"/>	CL-C1					36.843	1.111	0.30	0.24	0.81	9773.5	CL'	G	G

Line 10 is the CL without the Secondary Bushings

Sum of the Secondary Bushings C1 tests currents

$$2.114 + 2.138 + 2.189 + 2.146 = 8.587 \text{ mA}$$

$$\text{Line 6 mA} - \text{Sum of C1 mA} = \text{Line 10 mA}$$

$$45.430\text{mA} - 8.587 \text{ mA} = 36.843 \text{ mA}$$



Overall Test Temperature Correction

LIQUID-FILLED TRANSFORMERS, SHUNT REACTORS, AND VOLTAGE REGULATORS													
POWER TRANSFORMERS (Above 500 kVA)				DISTRIBUTION TRANSFORMERS (500 kVA and Below)									PTs/VT
Askarel-Filled Trans.	Oil-Filled Transformers			Silicone	Askarel	Oil-Filled		Silicone	TEST TEMPERATURES		HV/EHV Shunt Reactors (Oil-Filled)	Voltage Regulators (Oil-Filled)	Askarel
	Free Breathing and Older Conservator Types	Sealed, Gas-blanketed and Modern Conservator Types	161 kV			Prior to 1950	Modern		°C	°F			
						≤161 kV	161 kV						
—	1.56	1.57	.95	—	—	1.56	1.57	—	0	32.0	.95	1.56	—
—	1.52	1.50	.96	—	—	1.52	1.50	—	2	35.6	.96	1.52	—
—	1.48	1.44	.98	—	—	1.48	1.44	—	4	39.2	.98	1.48	—
—	1.45	1.37	.98	—	—	1.45	1.37	—	6	42.8	.98	1.45	—
—	1.43	1.31	.99	—	—	1.43	1.31	—	8	46.4	.99	1.43	—
—	1.38	1.25	.99	—	—	1.38	1.25	—	10	50.0	.99	1.38	—
—	1.31	1.19	1.00	—	—	1.31	1.19	—	12	53.6	1.00	1.31	—
—	1.24	1.14	1.01	—	—	1.24	1.14	—	14	57.2	1.01	1.24	—
—	1.16	1.09	1.01	—	—	1.16	1.09	—	16	60.8	1.01	1.16	—
—	1.08	1.05	1.00	—	—	1.08	1.05	—	18	64.4	1.00	1.08	—
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	20	68.0	1.00	1.00	1.00
.90	.91	.96	.99	.96	.90	.91	.96	.96	22	71.6	.99	.91	.90
.81	.83	.92	.98	.92	.81	.83	.92	.92	24	75.2	.98	.83	.81
.72	.76	.88	.97	.88	.72	.76	.88	.88	26	78.8	.97	.76	.72
.64	.70	.84	.96	.84	.64	.70	.84	.84	28	82.4	.96	.70	.64
.56	.63	.80	.95	.80	.56	.63	.80	.80	30	86.0	.95	.63	.56
.51	.58	.76	.94	.76	.51	.58	.76	.76	32	89.6	.94	.58	.51
.46	.53	.73	.93	.73	.46	.53	.73	.73	34	93.2	.93	.53	.46
.42	.49	.70	.91	.70	.42	.49	.70	.70	36	96.8	.91	.49	.42
.39	.45	.67	.90	.67	.39	.45	.67	.67	38	100.4	.90	.45	.39
.35	.42	.65	.89	.65	.35	.42	.65	.65	40	104.0	.89	.42	.35
.33	.38	.62	.87	.62	.33	.38	.62	.62	42	107.6	.87	.38	.33
.30	.36	.59	.86	.59	.30	.36	.59	.59	44	111.2	.86	.36	.30
.28	.33	.56	.84	.56	.28	.33	.56	.56	46	114.8	.84	.33	.28
.26	.30	.54	.83	.54	.26	.30	.54	.54	48	118.4	.83	.30	.26
.24	.28	.51	.81	.51	.24	.28	.51	.51	50	122.0	.81	.28	.24
.22	.26	.49	.79	.49	.22	.26	.49	.49	52	125.6	.79	.26	.22
.21	.23	.47	.77	.47	.21	.23	.47	.47	54	129.2	.77	.23	.21
.19	.21	.45	.75	.45	.19	.21	.45	.45	56	132.8	.75	.21	.19
.18	.19	.43	.72	.43	.18	.19	.43	.43	58	136.4	.72	.19	.18

Other types of 2 winding Transformers




Shielded Transformers

Wye-Wye Internally Tied Together



Testing Transformers with Inter-Winding Shield






← Inter-Winding Shield

(not always shown on nameplate)

Inter-winding Shield





Physical Representation of a Three-Phase Two-Winding Transformer




One of Three
Phases Shown

Inter-Winding Shield







2 winding transformer




2 winding transformer with grounded electrostatic shield




Test 1: Ground
Measures $C_H + C_{HL}$



Test 1: Ground
Measures $C_H + 1/2 C_{HL}$



Test 3 and 5: UST
Measures CHL



Test 3 and 5: UST

Current takes the path of least resistance therefore most of the current flows to ground. There is, however, a small amount of current that is measured for the UST test. Lines 3,4,7 and 8 of the overall test will be similar.



Inter-Winding Shield

Overall Test Setup											
Connections					Inputs		Test Results				
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1	HV Winding	LV Winding	Unused	CH+CHL	2.000	1.00	42.053	2.619	0.623	0.624	11154.6
2				CH	2.000	1.00	42.051	2.631	0.626	0.627	11154.1
3				CHL(UST)	2.000	*	0.000	0.000	*	*	0.0
4	Test 1 - Test 2 (calculated)			CHL		1.00	0.002	-0.012	60.000	60.149	0.5
5	LV Winding	HV Winding	Unused	CL+CHL	2.000	1.00	154.020	4.796	0.311	0.312	40854.6
6				CL	2.001	1.00	153.470	4.796	0.313	0.313	40708.9
7				CHL(UST)	2.000	*	0.552	0.000	0.000	0.000	146.4
8	Test 5 - Test 6 (calculated)			CHL		1.00	0.550	0.000	0.000	0.000	145.7




Wye-Wye Transformers Internally Connected




**Wye – Wye
Internally
Grounded**

**How Many
Windings?**

1



Test Connections – Wye – Wye Internally Connected







Three Winding Transformers



Dielectric Circuit Three-Winding Transformers



Dielectric Circuit Three-Winding Transformers



Dielectric Circuits of Transformers

$C_H : C_L : C_T$

Insulation between the Winding Conductors
and the Grounded Tank & Core

- Winding Insulation
- High, Low, Tertiary Voltage Bushings
- Structural Insulating Members
- DETC Insulation
- LTC
- Insulating Fluid

Dielectric Circuits of Transformers



$$C_{HL} : C_{HT} : C_{LT}$$

Insulation Between Two Windings; Interwinding Insulation


- Winding Insulation Barriers
- Insulating Liquid



Three Winding Transformer Overall Tests


Overall Test Setup											
Connections					Inputs		Test Results				
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.007	1.00	43.800	1.796	0.410	0.409	11618.1
2	HV Winding	LV Winding	TV Winding	CH	10.006	1.00	17.452	0.616	0.353	0.352	4629.1
3				CHL(UST)	10.006	1.00	26.356	1.156	0.439	0.438	6991.2
4	Test 1 - Test 2 (calculated)			CHL		1.00	26.348	1.180	0.448	0.447	6989.0
5				CL+CLT	10.004	1.00	51.199	1.886	0.368	0.368	13580.9
6	LV Winding	TV Winding	HV Winding	CL	10.003	1.00	22.519	0.819	0.364	0.363	5973.3
7				CLT(UST)	10.003	1.00	28.689	1.036	0.361	0.361	7610.0
8	Test 5 - Test 6 (calculated)			CLT		1.00	28.680	1.067	0.372	0.371	7607.6
9				CT+CHT	7.503	1.00	51.188	2.259	0.441	0.441	13577.9
10	TV Winding	HV Winding	LV Winding	CT	7.503	1.00	50.320	2.258	0.449	0.448	13347.7
11				CHT(UST)	7.503	1.00	0.867	0.010	0.115	0.115	229.9
12	Test 9 - Test 10 (calculated)			CHT		1.00	0.868	0.001	0.012	0.012	230.2
13	All			CH+CL+CT	10.006	1.00	90.272	3.735	0.414	0.413	23945.2

Three Winding Transformer – Tests #1, 2 & 3 Setup




Lead Selection Screen

Select if Red LV is on Low and Blue LV is on Tertiary
Or if Blue LV is on Low and Red LV is on Tertiary




Test Procedure - Test #1: Measure $C_H + C_{HL}$



GST – GROUND RED - GUARD BLUE

Test Procedure - Test #2: Measure C_H




GST – GUARD RED & BLUE




Three Winding Transformer Overall Tests

Overall Test Setup											
Connections					Inputs		Test Results				
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.007	1.00	43.800	1.796	0.410	0.409	11618.1
2	HV Winding	LV Winding	TV Winding	CH	10.006	1.00	17.452	0.616	0.353	0.352	4629.1
3				CHL(UST)	10.006	1.00	26.356	1.156	0.439	0.438	6991.2
4	Test 1 - Test 2 (calculated)			CHL		1.00	26.348	1.180	0.448	0.447	6989.0
5				CL+CLT	10.004	1.00	51.199	1.886	0.368	0.368	13580.9
6	LV Winding	TV Winding	HV Winding	CL	10.003	1.00	22.519	0.819	0.364	0.363	5973.3
7				CLT(UST)	10.003	1.00	28.689	1.036	0.361	0.361	7610.0
8	Test 5 - Test 6 (calculated)			CLT		1.00	28.680	1.067	0.372	0.371	7607.6
9				CT+CHT	7.503	1.00	51.188	2.259	0.441	0.441	13577.9
10	TV Winding	HV Winding	LV Winding	CT	7.503	1.00	50.320	2.258	0.449	0.448	13347.7
11				CHT(UST)	7.503	1.00	0.867	0.010	0.115	0.115	229.9
12	Test 9 - Test 10 (calculated)			CHT		1.00	0.868	0.001	0.012	0.012	230.2
13	All			CH+CL+CT	10.006	1.00	90.272	3.735	0.414	0.413	23945.2


Test Procedure-Rotate Test Leads



Test Procedure-Rotate Test Leads




Test Procedure-Rotate Test Leads




Lead Selection Screen

Select if Red HV is on Tert and Blue LV is on High
Or if Blue LV is on Tert and Red LV is on High




Test Procedure-Test #5: Measure C_L+C_{LT}




GST – GUARD RED – GROUND BLUE

Test Procedure-Test #6: Measure C_L



GST - GUARD RED & BLUE

Test Procedure-Test #7: Measure C_{LT}




UST – MEASURE BLUE - GROUND RED




Three Winding Transformer Overall Tests

Overall Test Setup											
#	Connections				Inputs		Test Results				
	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.007	1.00	43.800	1.796	0.410	0.409	11618.1
2	HV Winding	LV Winding	TV Winding	CH	10.006	1.00	17.452	0.616	0.353	0.352	4629.1
3				CHL(UST)	10.006	1.00	26.356	1.156	0.439	0.438	6991.2
4	Test 1 - Test 2 (calculated)			CHL		1.00	26.348	1.180	0.448	0.447	6989.0
5				CL+CLT	10.004	1.00	51.199	1.886	0.368	0.368	13580.9
6	LV Winding	TV Winding	HV Winding	CL	10.003	1.00	22.519	0.819	0.364	0.363	5973.3
7				CLT(UST)	10.003	1.00	28.689	1.036	0.361	0.361	7610.0
8	Test 5 - Test 6 (calculated)			CLT		1.00	28.680	1.067	0.372	0.371	7607.6
9				CT+CHT	7.503	1.00	51.188	2.259	0.441	0.441	13577.9
10	TV Winding	HV Winding	LV Winding	CT	7.503	1.00	50.320	2.258	0.449	0.448	13347.7
11				CHT(UST)	7.503	1.00	0.867	0.010	0.115	0.115	229.9
12	Test 9 - Test 10 (calculated)			CHT		1.00	0.868	0.001	0.012	0.012	230.2
13	All			CH+CL+CT	10.006	1.00	90.272	3.735	0.414	0.413	23945.2


Three Winding Transformer – Tests #9, 10 & 11 Setup




Test Procedure-Rotate Test Leads



Test Procedure-Rotate Test Leads




Test Procedure-Rotate Test Leads




Lead Selection Screen



Select if Red HV is on High and Blue LV is on Low
Or if Blue LV is on High and Red LV is on Low




Test Procedure-Test #9: Measure C_T+C_{HT}



GST – GROUND RED – GUARD BLUE

Test Procedure-Test #11: Measure C_{HT}



UST – MEASURE RED – GROUND BLUE



Three Winding Transformer Overall Tests

Overall Test Setup											
Connections					Inputs		Test Results				
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.007	1.00	43.800	1.796	0.410	0.409	11618.1
2	HV Winding	LV Winding	TV Winding	CH	10.006	1.00	17.452	0.616	0.353	0.352	4629.1
3				CHL(UST)	10.006	1.00	26.356	1.156	0.439	0.438	6991.2
4	Test 1 - Test 2 (calculated)			CHL		1.00	26.348	1.180	0.448	0.447	6989.0
5				CL+CLT	10.004	1.00	51.199	1.886	0.368	0.368	13580.9
6	LV Winding	TV Winding	HV Winding	CL	10.003	1.00	22.519	0.819	0.364	0.363	5973.3
7				CLT(UST)	10.003	1.00	28.689	1.036	0.361	0.361	7610.0
8	Test 5 - Test 6 (calculated)			CLT		1.00	28.680	1.067	0.372	0.371	7607.6
9				CT+CHT	7.503	1.00	51.188	2.259	0.441	0.441	13577.9
10	TV Winding	HV Winding	LV Winding	CT	7.503	1.00	50.320	2.258	0.449	0.448	13347.7
11				CHT(UST)	7.503	1.00	0.867	0.010	0.115	0.115	229.9
12	Test 9 - Test 10 (calculated)			CHT		1.00	0.868	0.001	0.012	0.012	230.2
13	All			CH+CL+CT	10.006	1.00	90.272	3.735	0.414	0.413	23945.2




Three Winding Transformer Overall Tests

Overall Test Setup											
#	Connections				Inputs		Test Results				
	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.007	1.00	43.800	1.796	0.410	0.409	11618.1
2	HV Winding	LV Winding	TV Winding	CH	10.006	1.00	17.452	0.616	0.353	0.352	4629.1
3				CHL(UST)	10.006	1.00	26.356	1.156	0.439	0.438	6991.2
4	Test 1 - Test 2 (calculated)			CHL		1.00	26.348	1.180	0.448	0.447	6989.0
5				CL+CLT	10.004	1.00	51.199	1.886	0.368	0.368	13580.9
6	LV Winding	TV Winding	HV Winding	CL	10.003	1.00	22.519	0.819	0.364	0.363	5973.3
7				CLT(UST)	10.003	1.00	28.689	1.036	0.361	0.361	7610.0
8	Test 5 - Test 6 (calculated)			CLT		1.00	28.680	1.067	0.372	0.371	7607.6
9				CT+CHT	7.503	1.00	51.188	2.259	0.441	0.441	13577.9
10	TV Winding	HV Winding	LV Winding	CT	7.503	1.00	50.320	2.258	0.449	0.448	13347.7
11				CHT(UST)	7.503	1.00	0.867	0.010	0.115	0.115	229.9
12	Test 9 - Test 10 (calculated)			CHT		1.00	0.868	0.001	0.012	0.012	230.2
13	All			CH+CL+CT	10.006	1.00	90.272	3.735	0.414	0.413	23945.2

Three Winding Transformer Overall Tests



Where Did We See
This Type of Results?



Three Winding Transformer Overall Tests




Shielded Transformer

But Is It Really Shielded?

Dielectric Circuit Three-Winding Transformers

Transformer tertiary configurations - Tertiary inside the low voltage winding closer to core not on same insulation tube






Three Winding Transformer Overall Tests


Overall Test Setup											
#	Connections				Inputs		Test Results				
	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.010	0.97	67.225	3.461	0.515	0.498	17831.6
2	HV Winding	LV Winding	TV Winding	CH	10.004	0.97	41.992	2.692	0.641	0.620	11138.4
3				CHL(UST)	10.004	0.97	25.220	0.747	0.296	0.287	6689.8
4	Test 1 - Test 2 (calculated)			CHL		0.97	25.233	0.769	0.305	0.295	6693.2
5				CL+CLT	10.003	0.97	47.884	1.864	0.389	0.376	12701.4
6	LV Winding	TV Winding	HV Winding	CL	10.002	0.97	12.726	0.597	0.469	0.454	3375.6
7				CLT(UST)	10.002	0.97	35.153	1.286	0.366	0.354	9324.6
8	Test 5 - Test 6 (calculated)			CLT		0.97	35.158	1.267	0.360	0.348	9325.8
9				CT+CHT	10.003	0.97	42.976	1.261	0.293	0.284	11399.6
10	TV Winding	HV Winding	LV Winding	CT	10.002	0.97	12.763	0.572	0.448	0.433	3385.4
11				CHT(UST)	10.002	0.97	30.207	0.717	0.237	0.230	8012.7
12	Test 9 - Test 10 (calculated)			CHT		0.97	30.213	0.689	0.228	0.221	8014.1
13	All			CH+CL+CT	10.004	0.97	68.200	7.302	1.071	1.035	18089.5

Dielectric Circuit Three-Winding Transformers

Transformer tertiary configurations - Tertiary stacked on top of low voltage winding on same insulation tube



Test Procedure-Test #13: Measure $C_H + C_L + C_T$



GST - GROUND



Three Winding Transformer Overall Tests

Overall Test Setup											
#	Connections				Inputs		Test Results				
	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1				CH+CHL	10.007	1.00	43.800	1.796	0.410	0.409	11618.1
2	HV Winding	LV Winding	TV Winding	CH	10.006	1.00	17.452	0.616	0.353	0.352	4629.1
3				CHL(UST)	10.006	1.00	26.356	1.156	0.439	0.438	6991.2
4	Test 1 - Test 2 (calculated)			CHL		1.00	26.348	1.180	0.448	0.447	6989.0
5				CL+CLT	10.004	1.00	51.199	1.886	0.368	0.368	13580.9
6	LV Winding	TV Winding	HV Winding	CL	10.003	1.00	22.519	0.819	0.364	0.363	5973.3
7				CLT(UST)	10.003	1.00	28.689	1.036	0.361	0.361	7610.0
8	Test 5 - Test 6 (calculated)			CLT		1.00	28.680	1.067	0.372	0.371	7607.6
9				CT+CHT	7.503	1.00	51.188	2.259	0.441	0.441	13577.9
10	TV Winding	HV Winding	LV Winding	CT	7.503	1.00	50.320	2.258	0.449	0.448	13347.7
11				CHT(UST)	7.503	1.00	0.867	0.010	0.115	0.115	229.9
12	Test 9 - Test 10 (calculated)			CHT		1.00	0.868	0.001	0.012	0.012	230.2
13	All			CH+CL+CT	10.006	1.00	90.272	3.735	0.414	0.413	23945.2

17.452

22.519

50.320

90.321




Auto Transformers




Auto-Transformer With Accessible Tertiary Winding

High and Low



Auto XFMR With Accessible Tertiary – Test #1, 2, & 3 Setup




Auto-Transformer With Accessible Tertiary Winding



Overall Test Setup											
Connections					Inputs		Test Results				
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1	HV Winding	TV Winding	Unused	CH+CHT	10.000	0.98	103.110	2.161	0.210	0.205	27349.7
2				CH	10.000	0.98	49.436	0.924	0.187	0.182	13113.0
3				CHT(UST)	10.000	0.98	53.657	1.243	0.232	0.226	14232.7
4	Test 1 - Test 2 (calculated)			CHT		0.98	53.674	1.237	0.230	0.225	14236.7
5	TV Winding	HV Winding	Unused	CT+CHT	10.000	0.98	165.700	3.567	0.215	0.210	43951.3
6				CT	9.999	0.98	112.030	2.249	0.201	0.196	29717.0
7				CHT(UST)	9.999	0.98	53.652	1.270	0.237	0.231	14231.8
8	Test 5 - Test 6 (calculated)			CHT		*	53.670	1.318	0.246	0.240	14234.3


Test as a Two Winding

Auto-Transformer - With Accessible Tertiary Winding




Auto-Transformer Without Tertiary Winding (Tertiary Winding Not Accessible)

Remove
Ground from
H0/X0 while
Testing



Auto-Transformer Without Tertiary Winding (Not Accessible)





Auto-Transformer Without Tertiary Winding (Tertiary Winding Not Accessible)

Overall Test Setup											
Connections					Inputs		Test Results				
#	HV Lead	Red Measure Lead	Blue Measure Lead	Insulation	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1	All	Unused	Unused	CH	10.006	0.98	164.965	3.525	0.214	0.209	43757.6

One Test to Ground
(No LV lead is Required)

Transformer Overall Tests



Updated Recommended Doble Power-Factor Test Voltages for Liquid-Filled Power and Distribution Transformers

Winding Rating L-L (kV)

17.32 kV and Above
Below 17.32 kV

Test Voltage (kV)

10 kV
Line - Ground

Transformer Overall Tests



Examples of common winding voltages and their calculated line to ground voltages. These are general guidelines.

Winding Rating L-L (kV)	Line to Ground Voltage
17.32 kV	10,000
13.8 kV	7967
12.47 kV	7200
4.16 kV	2401
2.4 kV	1385
.48 kV	277

Transformer Overall Tests



Recommended Doble Power-Factor Test Voltages for Liquid-Filled Type Power and Distribution Transformers Tested in the **Absence Of Insulating Fluid** and Under Atmospheric or Greater Absolute Pressure

- **Determine - By Direct Measurement - That the Gas space and fluid contain safe combustible gas levels for testing as prescribed by your company**
- **Purge with dry nitrogen to obtain <2% oxygen**
- **Never apply test voltage to a transformer whose windings are under vacuum or partial vacuum**

Transformer Overall Tests



Recommended Doble Power-Factor Test Voltages for Liquid-Filled Type Power and Distribution Transformers Tested in the **Absence Of Insulating Fluid** and Under Atmospheric or Greater Absolute Pressure

- **Low test voltage is sufficient to assess the general level of dryness of a transformer insulation system**
- **Maintain adequate clearance between all energized, floating and grounded conductors when testing with some or all of the transformer leads, core, and coils out of the insulating fluid**

Transformer Overall Tests



Recommended Doble Power-Factor Test Voltages for Liquid-Filled Type Power and Distribution Transformers Tested in the **Absence Of Insulating Fluid** and Under Atmospheric or Greater Absolute Pressure

- **Do not apply test voltages that exceed those recommended for transformers with the insulating fluid removed**



Transformer Overall Tests

Recommended Doble Power-Factor Test Voltages for Liquid-Filled Type Power and Distribution Transformers Tested in the **Absence Of Insulating Fluid** and Under Atmospheric or Greater Absolute Pressure

Transformer Winding Rating L-L (kV)	Test Voltage (kV)
<i>Delta Windings</i>	
<u>161 and Above</u>	<u>10</u>
115 to 138	5
34 to 69	2
12 to 25	1
Below 12	0.5

Transformer Overall Tests



Recommended Doble Power-Factor Test Voltages
for Dry-Type Power and Distribution Transformers

Transformer Winding Rating L-L (kV) Test Voltages (kV)

Delta and ungrounded Wye Windings

Above 14.4

2 and 10

12 to 14.4

2, L-to-G, 10

5.04 to 8.72

2 and 5

2.4 to 4.8

2

Below 2.4

1

Grounded Wye Windings

2.4 and Above

2

Below 2.4


1

Doble dielectric-loss & power factor testing as applied to transformers is a comprehensive test for insulation assessment, detecting:

- **Moisture**
- **Carbonization**
- **Mechanical Failure**

Test techniques makes it possible to separate the transformer into major components for more effective analysis of test results.

Data Interpretation of Modern Oil-Filled Power Transformers (Temperature Corrected)



•Less Than 0.5%	--	GOOD
•>0.5% but < 0.7%	--	DETERIORATED
•>0.5% but <1.0% & increasing	--	INVESTIGATE
•Greater than 1.0%	--	BAD

GENERAL GUIDELINES!



Transformer Limit Guidelines

Rating	Type	New	Used
0 - 500 KVA	Distribution	1.0%	2.0%
> 500 KVA	Power	0.5%	1.0%

THESE ARE GENERAL GUIDELINES!

<u>Change in Charging Current</u>	<u>Rating*</u>
0 - 3%	G
3 - 5%	D
5 - 10%	I
> 10%	B

Analysis of Dry Type Transformers

- Limits Are Determined Based on Manufacturer and Rating
- Based on a Recent Tabulation (1999), the Following General Guidelines Can Be Used:

Ventilated Transformers

$$C_{HL} \leq 2.0\%$$

$$C_H \leq 3.0\%$$

$$C_L \leq 4.0\%$$

Epoxy-Encapsulated Transformers

$$C_{HL} \leq 1.0\%$$

$$C_H \leq 3.0\%$$

$$C_L \leq 2.0\%$$

Considerations



- NEVER rely only on power factor when reviewing data. Tests can be performed incorrectly and still have an “acceptable” power factor.
- Overall power factor will not reveal shorted turns or an open.
- Always review current, watts, power factor and capacitance.
- Review bushing test data, excitation current, turns ratio and winding resistance.

Considerations



- Previous Test Results (Rate of Change)
- Test Temperatures
- Reason for Test: Acceptance, Routine or Suspect
- Other Test Results, e.g.
 - High P.F. Readings \Rightarrow Lab Results (DGA, Moisture in Oil)
 - High P. F. Readings \Rightarrow P. F. Tip-Up
 - Change in Capacitance \Rightarrow LRT and/or SFRA



Exciting Current Tests



Excitation Current Principles



With the LTC On NEUTRAL – We measure the exciting current of the Transformer


With The LTC on an EVEN Tap – The Exciting current may include additional components such as a Series Transformer or Preventative autotransformer.

With the LTC on an ODD tap – The Exciting current in almost all cases includes any Series Transformer or Preventative autotransformer and anything else that will affect it.

Excitation Current Principles




No Load



- 1) When an AC Voltage Source, such as a Doble Test Set, is placed on a transformer, a small current will flow.
- 2) This small current is the *Magnetizing Current*: the current required to magnetize the Transformer core with the *Magnetic Flux* ϕ_{mag} . This Magnetizing Current is the Excitation Current we measure and record.
- 3) This Magnetic Flux will induce a voltage across the secondary windings: V_2

Excitation Current Principles

Load Added




- 1) When a Load is placed on the secondary windings a current will flow

$$I_2 = V_2 / R_2 \text{ [Ohm's Law]}$$

- 2) The Current I_2 will in-turn create an Opposing Magnetic Flux ϕ_2 .
- 3) The Generator, which regulates voltage at a set level, will provide more current to maintain the core magnetized equal to the opposing flux

$$I_{excitation} = I_{mag} + I_2$$

Turn to Turn Fault




- 1) If a fault develops in the secondary windings, this fault will act as a load across the faulted windings drawing a current I_{fault} .
- 2) As a result, the Excitation Current will go up due to the opposing flux created by the fault [ϕ_{fault}].

Result: A Fault will cause Excitation Current to Increase

Excitation Current Principles




Grounded Winding



- 1) If the secondary winding has a grounded neutral and one of the windings develops a fault to ground, grounded windings will draw a fault current.
- 2) As a result, the Excitation Current will go up due to the opposing flux created by the fault [ϕ_{fault}].

Result: A grounded winding on a transformer with a grounded neutral will cause the Excitation Current increase.

Preventative Autotransformer



When an autotransformer is connected across two taps it acts as a load and the primary current goes up.

Result: When the Autotransformer is in the bridging position the Excitation Current increase.



Transformer Excitation Current Test Procedure - Single Phase

Note :

It is recommended to ground one terminal of each low voltage winding so that excessive voltage in the winding will not be developed from electrostatic coupling.

Transformer Excitation Current Test



Test Voltage Guidelines

- Do Not Exceed Test Voltages Recommended For Over-All Winding Test Procedures
- Use the Highest, Whole Number, Voltage in kV, That the Test Set Can Deliver Up To the Maximum Recommended Test Voltage

Transformer Excitation Current Test




Test Voltage Guidelines

- The Relationship Between Excitation Current and Applied Test Voltage is Non-Linear
- For Historical Comparisons it is Necessary to Use the Same Test Voltage For Each Test on a Given Transformer

Wye Winding Excitation Current Tests

Transformer Nameplate




Transformer Excitation Current Test

Test 1: Measure H1 to H0

Energize: H1, UST: H0, Float: H2,H3,X1,X2,X3


Note: If Low Voltage Winding is Wye-Connected - Ground X0



Test 2: Measure H2 to H0

Energize:H2, UST: H0, Float: H1,H3,X1,X2,X3


Note: If Low Voltage Winding is Wye-Connected - Ground X0



Test 3: Measure H3 to H0

Energize: H3, UST: H0, Float: H1,H2,X1,X2,X3

Note: If Low Voltage Winding is Wye-Connected - Ground X0



Transformer Excitation Current Test




Summary


Test No.	Measures	Test Mode	Energize	UST	Ground	Float
1	H1-H0	UST	H1	H0	*	H2,H3,X1,X2,X3
2	H2-H0	UST	H2	H0	*	H1,H3,X1,X2,X3
3	H3-H0	UST	H3	H0	*	H1,H2,X1,X2,X3

- If Low-Voltage Winding is Wye-Connected, Ground X0
- This Procedure is for Transformers With H2 and H0 Bushings Associated With Center Leg of Core


Transformer Excitation Current Test 3-Phase Wye Connected Windings




Transformer Excitation Current Test 3-Phase Wye Connected Windings



Transformer Excitation Current Test 3-Phase Wye Connected Windings



Transformer Excitation Current Test 3-Phase Wye Connected Windings



Current and Watts Pattern - - HLH - Why?

- Test Voltage, E, Applied to Winding - Same For Each Test
- $E = 4.44 f N \Phi$
- $f =$ Alternating Current Frequency (Constant)
- $N =$ Number of Turns of Conductor (Constant)
- The Magnetic Flux Φ In the Core Within the Conductor Coils - Same for Each Test

Current and Watts Pattern – HLH - Why?



- Magnetic flux, Φ - Same for Each Test
- $NI = \Phi \mathfrak{R}$
- N = Number of Turns of Conductor (Constant)
- Current, I , Through the Conductor - Affected Only by \mathfrak{R} , Reluctance of the Core
- Larger Reluctance, \mathfrak{R} , Larger Current
- Smaller Reluctance, \mathfrak{R} , Smaller Current

Current and Watts Pattern - HLH - Why?



Summary


- $E = 4.44 f N \Phi$
 - Must Keep E Constant to Keep Φ in the Core Constant
- $NI = \Phi \mathcal{R}$
 - N and Φ Are Constant,
 - I (current) Will Vary With \mathcal{R} (Reluctance)
 - Higher \mathcal{R} Then Higher I
 - Lower \mathcal{R} Then Lower I

Current and Watts Pattern - HLH - Why?



- Larger Reluctance, \mathfrak{R} , Larger Current
- Smaller Reluctance, \mathfrak{R} , Smaller Current


Current and Watts Pattern - HLH - Why?



Outer Cores

$$\mathcal{R}_E = (1+3+1) + [3(1+3+1)/(3+1+3+1)] = 6.875$$

Current and Watts Pattern - HLH - Why?



Inner Core

$$\mathcal{R}_E = 3 + (5 \times 5) / 10 = 5.5$$

Delta Winding Excitation Current Tests



Transformer Excitation Current Test

3 Phase, Delta Connected


H1-H2 in Center Phase

Test 1: Measure H3 to H1



Energize: H3, UST: H1, Ground: H2, Float: X1,X2,X3

Note: If Low Voltage Winding is Wye-Connected - Ground X0




Test 2: Measure H1 to H2



Energize: H1, UST: H2, Ground: H3, Float: X1,X2,X3

Note: If Low Voltage Winding is Wye-Connected - Ground X0




Test 3: Measure H2 to H3



Energize: H2, UST: H3, Ground: H1, Float: X1,X2,X3

Note: If Low Voltage Winding is Wye-Connected - Ground X0





Transformer Excitation Current Test 3 Phase, Delta Connected, H1-H2 in Center Phase


Summary

Test No.	Measures	Test Mode	Energize	UST	Ground	Float
1	H3-H1	UST	H3	H1	H2 *	X1,X2,X3
2	H1-H2	UST	H1	H2	H3 *	X1,X2,X3
3	H2-H3	UST	H2	H3	H1 *	X1,X2,X3

- This Procedure is For Transformers That Have H1 and H2 Bushings Associated With the Center Leg of Core
- Note: If Low Voltage Winding is Wye-Connected - Ground X0


Transformer Excitation Current Test

3 Phase, Delta Connected, H1-H2 in Center Phase




Transformer Excitation Current Test

3 Phase, Delta Connected, H1-H2 in Center Phase




Transformer Excitation Current Test

3 Phase, Delta Connected, H1-H2 in Center Phase




Transformer Excitation Current Test

3 Phase, Delta Connected, H1-H2 in Center Phase



Transformer Excitation Current Test

3 Phase, Delta Connected, H1-H2 in Center Phase



Application of Excitation Current Test



For New or Questionable Transformers

- Test Positions of the LTC:

All positions

or

1R-16R, N, 1L

or

1L-16L, N, 1R

- Test Each Position of the DETC:

A,B,C,D,E with the LTC in Neutral

Application of Excitation Current Test



On a Routine Basis

- Test Positions of the LTC

16R, 1R, N, 1L, 16L

- Leave the DETC in the Nominal Position or the Position to be left on for operation.



Analysis, Excitation Current and Watts Phase Patterns

Two Similar (SS)
Single Phase Transformers



Analysis, Excitation Current and Watts Phase Patterns

DTA Field System - [Auxiliary Transformer Tests - Excitation Tests]

File Edit Operations Test Layout

Location: TCY TRACY 500 YARD Special ID: KT2A1
 Serial No: 04873T10015-1 CCT Desig: KT2A Date: May 31 2002

De-Energized Tap Changer

Mfr: Type:

Steps: Boost: + % Buck: - %

PSN-Fnd: PSN-Left:

On-Load Tap Changer

Mfr: Type:

Steps: Boost: + % Buck: - %

PSN-Fnd: PSN-Left:

Connections

H - H H - H H - H

	N	I	Detc		Test	H <input type="text" value="1"/> - H <input type="text" value="0"/>		H <input type="text" value="0"/> - H <input type="text" value="1"/>		H <input type="text"/> - H <input type="text"/>		INS
			Posn	Posn		mA	watts	mA	watts	mA	watts	
1			1	1	10	36.330	110.90	36.880	130			
2			1	2	10	36.360	110.60	36.960	130			
3			1	3	10	36.370	110.50	36.960	130.30			
4			1	4	10	36.380	110.40	36.980	130			
5			1	5	10	36.380	110.40	36.940	129.70			
6			2	1	10	37.700	116.50	38.280	135.40			
7			2	2	10	37.690	116.50	38.320	135.50			
8			2	3	10	37.690	116.50	38.340	135.80			
9			2	4	10	37.690	116.50	38.360	136			

Analysis, Excitation Current and Watts Phase Patterns



Two Similar and One Lower (HLH)

Most Common.

Three Legged Core.

Shell Form with Delta Secondary Winding.

Regular Test Procedure.

Analysis, Excitation Current and Watts Phase Patterns



DTA Field System
File Edit Operations Test Layout

Auxiliary Transformer Tests - Excitation Tests

Location: Serial No: Special ID: 609-TH-5
CCT Desig: 609-TH-5 Date: Aug 26 1999

De-Energized Tap Changer
Mfr: W Type: OFF-LINE
Steps: 5 Boost: + % Buck: - %
PSN-Fnd: 3 PSN-Left: 1

On-Load Tap Changer
Mfr: Type:
Steps: Boost: + % Buck: - %
PSN-Fnd: PSN-Left:

Connections
H 1 - H 2 H 2 - H 3 H 3 - H 1

	N	I	Detc Psn	Ltc Psn	Test kV	H 1 mA	H 2 watts	H 2 - H 3 mA	H 2 - H 3 watts	H 3 mA	H 3 - H 1 watts	INS RTG
1			1		10	49.080	392.10	17.960	147.90	47.660	385.30	
2			2		10	48.260	393.10	17.420	145.90	49.260	399.20	
3			3		10	50.400	410.90	18.150	152.20	51.370	417.10	
4			4		10	52.480	428.90	18.890	158.70	53.480	435.20	
5			5		10	54.890	449.60	19.740	166.20	55.930	456.20	
6												
7												
8												
9												

Arrester DR-HL Jump To Prev Date Next Date Save Exit

Appears that H1 and H3 are rolled




Excitation Test

Delta Wye Transformer Example

13 Raise and 5 Raise indicate trouble on H1-H2


DETC	LTC	Test kV	H2 - H3			H3 - H1			H1 - H2	
			mA	Watts	X	mA	Watts	X	mA	Watts
C	16R	10	12.296	78.44	L	12.658	79.492	L	5.687	34.371
C	15R	10	58.192	85.977	L	58.575	86.383	L	52.597	42.547
C	14R	10	12.041	76.574	L	12.346	77.386	L	5.592	33.684
C	13R	10.004	57.945	84.218	L	58.399	84.737	L	18.88	64.341
C	12R	10	11.806	74.91	L	12.095	75.705	L	5.508	33.08
C	11R	10	57.814	82.606	L	58.126	82.778	L	52.498	41.292
C	10R	10	11.603	73.513	L	11.793	73.903	L	5.431	32.559
C	9R	10	57.674	81.387	L	57.976	81.384	L	52.423	40.84
C	8R	10	11.427	72.348	L	11.614	72.692	L	5.367	32.118
C	7R	10	57.55	80.469	L	57.828	80.187	L	52.376	40.52
C	6R	10	11.315	71.439	L	11.455	71.578	L	5.314	31.765
C	5R	10	57.433	79.813	L	57.67	79.299	L	52.263	40.295
C	4R	10	11.202	70.714	L	11.33	70.783	L	5.272	31.504
C	3R	10.001	57.338	79.241	L	57.514	78.788	L	52.236	40.205
C	2R	10	11.124	70.27	L	11.227	70.238	L	5.245	31.299
C	1R	10	56.972	79.277	L	57.203	78.823	L	51.893	40.315
C	N	9.999	11.094	70.122	L	11.202	70.039	L	5.238	31.235
C	1L	10.001	57.121	78.981	L	57.364	78.354	L	52.068	39.925
C	2L	10	11.125	70.181	L	11.242	70.213	L	5.254	31.308
C	3L	10.001	57.334	78.933	L	57.467	78.394	L	52.258	39.901
C	4L	10	11.205	70.706	L	11.268	70.548	L	5.29	31.474
C	5L	10	57.415	79.564	L	57.586	78.935	L	18.82	63.081
C	6L	9.999	11.343	71.481	L	11.383	71.247	L	5.331	31.736
C	7L	10	57.626	80.416	L	57.687	79.703	L	52.381	40.389
C	8L	10	11.485	72.475	L	11.483	72.073	L	5.385	32.101

Graph



Delta Wye Transformer Example 1

The nameplate was examined. 13R and 5L steps shared the same contact.





Analysis, Excitation Current and Watts Phase Patterns

Determining Phase Patterns:

- The Doble Test Assistant Considered Measurements similar if:
 - (1) Currents are between 0 and 50 mA and are within 10% of each value
 - (2) Currents are greater than 50 mA and are within 5% of each value

Analysis, Excitation Current and Watts Phase Patterns



- **Three Similar Phase Currents (SSS)**
 - 4 or 5 Legged Cores
 - Shell Form with Non Delta Connected
Secondary
 - 3 Single Phase Transformers Connected as a
Three Phase Transformer.



Analysis, Excitation Current and Watts Phase Patterns

Two Similar and One Higher (LHL)

- Delta Connected Primary Performed Using the Alternate Method
- Wye Connected Primary, Neutral is Not Accessible, Measuring Two Phases in Series
- High Capacitance Windings and Low Loss Core



Analysis, Excitation Current and Watts Phase Patterns

Transformer Excitation Current Test Procedure 3 Phase, Wye Connected Windings Without an Accessible H0 Bushing

Test No.	Measure	Test Mode	Energize	UST	Float
1	H3-H0+H0-H1	UST	H3	H1	H2,X1,X2,X3
2	H1-H0+H0-H2	UST	H1	H2	H3,X1,X2,X3
2	H2-H0+H0-H3	UST	H2	H3	H1,X1,X2,X3


Note: If Low Voltage Winding is Wye-Connected - Ground X0

Wye Connected Windings
Without
Accessible H0 Bushing

Test 1: Measure H3 to H1

Energize: H3, UST: H1, Float: H2,X1,X2,X3


Note: If Low Voltage Winding is Wye-Connected - Ground X0



Test 2: Measure H1 to H2

Energize H1, UST H2, Float H3, X1, X2, X3


Note: If Low Voltage Winding is Wye-Connected - Ground X0



Test 3: Measure H2 to H3

Energize: H2, UST: H3, Float: H1,X1,X2,X3

Note: If Low Voltage Winding is Wye-Connected - Ground X0





Wye Connected Windings Without Accessible H0 Bushing

DTA Field System
File Edit Operations Test Layout

Auxiliary Transformer Tests - Excitation Tests

Location: 66HS Special ID: 36781
Serial No: 9908401203 CCT Desig: HST2 Date: Oct 03 2000

De-Energized Tap Changer

Mfr: Type:

Steps: Boost: + % Buck: - %

PSN-Fnd: PSN-Left:

On-Load Tap Changer

Mfr: Type:

Steps: Boost: + % Buck: - %

PSN-Fnd: PSN-Left:

Connections

H - H H - H H - H

	N	I	Detc Psn	Ltc Psn	Test kV	H 1 mA	H 2 watts	H 1 mA	H 3 watts	H 2 mA	H 3 watts	INS RTG
1			3	N	10	39.370	247.10	53.110	342.10	37	235.20	
2			3	1L	10	142.20	264.40	153	361.60	138.90	252.80	
3			3	2L	10	39.030	245.60	53.260	342.50	37.240	236.10	
4			3	3L	10	142.50	266.10	153.30	363.60	139.30	254.50	
5			3	4L	10	39.420	247.80	53.770	345.40	37.640	238.30	
6			3	5L	10	142.50	268.70	153.30	367.10	139.30	257.30	
7			3	6L	10	39.420	251.10	54.000	349.80	38.000	241.60	
8			3	7L	10	142.50	272.50	153.30	372.10	140.20	261	
9			3	8L	10	40.620	255.40	55.380	355.60	38.840	246	



Transformer Excitation Current and Watts, Test Procedure, Three Phase

LHL Pattern - When HLH Pattern Expected

M4000 for Windows - Clipboard - EX_C_CAP

File Mode Edit View Configuration Test Diagnostics Help

Company: Date: 05/09/01

Location: Time: 08:08

Equipment:

Special ID: Circuit Designation:

Current is Capacitive instead of Inductive

No.	Serial No. / Test ID	LC	Circuit Desc.	kV	mA	Watts	Meas %PF	Corr. Fact.	Corr. %PF	Cap. / Ind.	R T	N T
1	H3-H1	A	UST-R	10.000	4.316	31.073	72.00	1.00	72.00	783.7 pF	<input type="checkbox"/>	<input type="checkbox"/>
2	H1-H2	A	UST-R	10.000	6.368	14.854	23.33	1.00	23.33	1640.3 pF	<input type="checkbox"/>	<input type="checkbox"/>
3	H2-H3	A	UST-R	10.000	4.936	36.497	73.94	1.00	73.94	868.1 pF	<input type="checkbox"/>	<input type="checkbox"/>
4		A		0.000				1.00			<input type="checkbox"/>	<input type="checkbox"/>




Transformer Excitation Current and Watts, Test Procedure, Three Phase

LHL Pattern When **HLH** Pattern Expected

Added Capacitance Current of the Winding = I_C

Watts (I_R) has the HLH Pattern



Windings

- Turn-To-Turn Winding Insulation Failure Causing a Short Circuit or Resistive Connection
- Winding to Ground Short for a Grounded Winding
- Open Windings (Main, Tap, Reactor)
- High Resistance Conductor Connections
- Phase-To-Phase Electrical Tracking



Tap Changer


- Misalignment
- Mechanical Problems
- Coking and Wear of LTC and DETC Contacts

Core

- Abnormal Circulating Currents in the Core From:
 - Clamping Components
 - Multiple Core Grounds
- Core Lamination Insulation Damage
- Core Joint Dislocations



Oil Circuit Breakers



Dead-Tank Oil Circuit Breaker



Recommended Tests:

Power-Factor

Time & Travel

Contact Resistance

**CGE, 260 kV
type FGK**

Oil Circuit Breaker Tests



In Simplified Terms:

Two Bushings Per Phase


Contact Assembly (Interrupter)

Operating Rod (Vertical or Rotary)

Insulated Guide Assembly (Operating Rod)

A Volume of Oil


Tank Liner



Oil Circuit Breaker Tests




Dead Tank Oil Circuit Breaker



Doble Recommended Tests (Minimum)

- Overall Circuit Breaker Test
 - a. Six Open Breaker (GST)
 - b. Three Closed Breaker (GST)
- Tank Loss Index
- Bushing Tests
- Oil Sample Test
- Miscellaneous
- Diagnostic



Recommended Doble Test Voltages Oil Circuit Breakers



**Use Line to Ground Voltages
for the Line to Line Voltage Rating of the
Breaker**



Transformer Overall Tests

Examples of voltages and their calculated line to ground voltages.


These are general guidelines.

Line to Line kV	Line to Ground Voltage
17.32 kV	10,000
13.8 kV	7967
12.47 kV	7200
4.16 kV	2401
2.4 kV	1385
.48 kV	277


Overall Test Procedure

Tests 1-6

Breaker is Open



Open Circuit Breaker Test





Open Breaker Test

Major Contribution of Watts-Loss:

- Bushing
- Contact Assembly (Interrupter)
- Lift-Rod Guide
- Upper Lift-Rod


Lesser Contribution of Watts-Loss:

- Tank Liner
- Oil


Overall Test Procedure

Tests 7-9

Breaker is Closed



Closed Breaker Test



Closed Breaker Test



Major Contribution of Watts-Loss:

- Bushing (2)
- Oil
- Lower Lift-Rod
- Tank Liner

Lesser Contribution of Watts-Loss:

- Contact Assembly (Interrupter)
- Lift-Rod Guide

Tank Loss Index(TLI)



- Bushings Comprise the Largest Portion of the Oil Circuit Breaker Insulation System
- A Bad Bushing Will Be Indicated in the Open and Closed Breaker Tests.
- To Analyze the Condition of the Internal Parts of the OCB, Tank Loss Index (TLI) was Developed

$$\text{TLI} = \text{Closed Breaker Watts} - (\Sigma \text{ Open Breaker Watts })$$

(For Each Phase)

Tank Loss Index(TLI)



Closed Breaker – Sum of the Open Breaker

$$\text{TLI} = \mathbf{2 \text{ Bushings} + \text{Lower Lift Rod} + \text{Oil} + \text{Tank Liner}} \\ - (\mathbf{2 \text{ Bushings} + 2 \text{ Lift Rod Guides} + 2 \text{ Top of Lift Rods} + 2 \\ \text{Interrupters})$$

$$= \mathbf{\text{Lower Lift Rod} + \text{Oil} + \text{Tank Liner} - 2 \text{ Interrupters} - \\ \text{Lift Rod Guides} - 2 \text{ Top of Lift Rods}}$$

As a General Rule: TLI Tends to Be Negative

Tank Loss Index: Component Failures

$$\text{TLI} = \text{Lower Lift Rod} + \text{Oil} + \text{Tank Liner} - 2 \text{ Interrupters} - \text{Lift Rod Guides} - 2 \text{ Top of Lift Rods}$$

What would happen to TLI if:

- Water Content of the Oil Increases.....
- Carbon is Collecting on the Interrupters...
- Tank Liner Becomes Saturated With Water
- Lift Rod Guide is Deteriorating Due to Corona Activity...



Guideline Tank-Loss Indexes (TLI) Oil Circuit Breakers

Tank Loss Index					
2.5 kV	Above -15 mW	Between -10 mW and -15 mV	-10 mW to +7.5 mW	Between +7.5 mW and +15 mW	Above +15 mW
10 kV	Above -0.20 W	Between -0.10 W and -0.20 W	-0.10 W to +0.05 W	Between +0.05 W and +0.10 W	Above +0.10 W
	Investigate Immediately	Retest on a more frequent basis.	Normal for most breaker types. Place on a normal routine test schedule.	Retest on a more frequent basis.	Investigate Immediately
	Lift-Rod guide assembly, contact assembly (Interrupter), and upper portion of lift rod.			Lift rod, Tank Oil, tank liner, and auxiliary contact support insulation.	



Calculating Tank Loss Index

DTA Field System

File Edit Operations Test Layout

Oil Circuit Breaker Insulation Test - Overall Tests

Location: VAIL Special ID: VL152C
Serial No: 0139A6663-204 CCT Desig: VL152C Date: Jul 07 2000

	N	I	Bush Brk	Bus Ener Ft	Ins #	P H	Test kV	Equiv. 10 kV mA	10 kV watts	% PWR meas	FCTR corr	corr fctr	INS RTG		
1			O	1	25	1	A	10	2.402	0.161	0.67	0.66	0.99	G	
2			P	2	25	2	A	10	2.333	0.227	0.97	0.96	0.99	G	
3			E	3	25	3	B	10	2.403	0.271	1.13	1.12	0.99	G	
4			N	4	25	4	B	10	2.337	0.106	0.45	0.45	0.99	G	
5				5	25	5	C	10	2.294	0.071	0.31	0.32	1.03	G	
6				6	25	6	C	10	2.334	0.091	0.39	0.39	0.99	G	
TLI's															
7			C	1.2	50	1	A	10	4.535	0.236	0.52	0.51	0.99	-0.152	I
8			L	3.4	50	2	B	10	4.537	0.214	0.47	0.47	0.99	-0.163	I
9			S	5.6	50	3	C	10	4.435	0.153	0.34	0.34	1.01	-0.009	G

$$TLI_A = CBW_7 - (OBW_1 + OBW_2) = 0.236 - (0.161 + 0.227) = -0.152W$$

$$TLI_B = CBW_8 - (OBW_3 + OBW_4) = 0.214 - (0.271 + 0.106) = -0.163W$$

$$TLI_C = CBW_9 - (OBW_5 + OBW_6) = 0.153 - (0.071 + 0.091) = -0.009W$$

Analysis of Oil Circuit Breaker Condition

Currents Do Not Add Up



DTA Field System
File Edit Operations Test Layout

Oil Circuit Breaker Insulation Test - Overall Tests

Location: DCB 8A Special ID:
Serial No: 1-37Y5139 CCT Desig: Date: Mar 10 1983

	N	I	Brk	Bush Ener	Bus Ft	Ins #	P H	Test kV	Equiv. mA	10 kV watts	% PWR meas	FCTR corr	corr fctr	INS RTG	
1			O	1	0	0	A	10	2.200	0.240	1.09	1.05	0.96	G	
2			P	2	0	0	A	10	2	0.240	1.20	1.15	0.96	G	
3			E	3	0	0	B	10	2.100	0.240	1.14	1.09	0.96	G	
4			N	4	0	0	B	10	2.200	0.280	1.27	1.22	0.96	G	
5				5	0	0	C	10	2.200	0.280	1.27	1.22	0.96	G	
6				6	0	0	C	10	2.100	0.220	1.05	1.01	0.96	G	
TLI's															
7			C	1,2	0	0	A	10	2	0.240	1.20	1.15	0.96	-0.240	I
8			L	3,4	0	0	B	10	4.300	0.520	1.21	1.16	0.96	0.0000	G
9			S	5,6	0	0	C	10	4.200	0.440	1.05	1.01	0.96	-0.060	G

ID Score

Check If Breaker was Open

Note: Nun other bushings must be floating.

Bushing Problem Identified



DTA Field System

File Edit Operations Test Layout

Oil Circuit Breaker Insulation Test - Overall Tests

Location: VAIL Special ID: VL152C
 Serial No: 0139A6663-204 CCT Desig: VL152C Date: Jun 29 2000

	N	I	Brk	Bush Ener	Bus Ft	Ins #	P H	Test kV	Equiv. mA	10 kV watts	% PWR meas	FCTR corr	corr fctr	INS RTG	
1			O	1	25	1	A	10	2.414	0.197	0.82	0.81	0.99	G	
2			P	2	25	2	A	10	2.338	0.109	0.47	0.47	0.99	G	
3			E	3	25	3	B	10	2.401	0.145	0.60	0.59	0.99	G	
4			N	4	25	4	B	10	2.338	0.126	0.54	0.53	0.99	G	
5				5	25	5	C	10	2.534	3.413	13.47	13.3	0.99	I	
6				6	25	6	C	10	2.336	0.120	0.51	0.50	0.99	G	
TLI's															
7			C	1.2	50	1	A	10	4.547	0.276	0.61	0.60	0.99	-0.030	G
8			L	3.4	50	2	B	10	4.553	0.260	0.57	0.56	0.99	-0.011	G
9			S	5.6	50	3	C	10	4.659	3.548	7.62	7.54	0.99	0.015	I

Note: Numbers in BUSH ENER column indicate bushings that are grounded. All other bushings must be floating.

GE Type U Bushings

Bushing Problem Identified



DTA Field System

File Edit Operations Test Layout

Oil Circuit Breaker Insulation Test - Bushing Tests

Location: VAIL Special ID: VL152C
 Serial No: 0139A6663-204 CCT Desig: VL152C Date: Jun 29 2000

	N	I	Nameplate Serial #	C(pF)	%PF	Test kV	Equiv. 10kV mA	10kV watts	% PWR meas	FCTR corr	corr fctr	meas C(pF)	INS RTG
			C1										
1			1727917	363	.33	10	1.350	0.061	0.45	0.45	0.99	358.20	G
2			1727916	363	.32	10	1.349	0.041	0.30	0.30	0.99	357.80	G
3			1727915	362	.33	10	1.340	0.067	0.50	0.50	0.99	355.40	G
4			1727914	363	.32	10	1.355	0.059	0.44	0.44	0.99	359.40	G
5			1727918	363	.33	10	1.365	0.266	1.95	1.93	0.99	362	I
6			1727913	364	.34	10	1.353	0.046	0.34	0.34	0.99	358.90	G
1			1727917	2550		2	9.652	0.353	0.37	0.37	1.00	2560	G
2			1727916	2818		2	10.750	0.360	0.33	0.33	1.00	2852	G
3			1727915	2883		2	10.860	0.404	0.37	0.37	1.00	2882	G
4			1727914	2889		2	10.590	0.349	0.33	0.33	1.00	2809	G
5			1727918	2827		2	52.080	505.80	97.12	97.1	1.00	3208	I
6			1727913	2826		2	10.670	0.339	0.32	0.32	1.00	2832	G

GE Type U Bushings

Overall Hot Collar Jump To Prev Date Next Date Save Exit

Check Condition of Bushings



- **Bushings Comprise the Largest Portion of the Oil Circuit Breaker Insulation System**
- **A Bad Bushing Will Show Up in Both the Open and Closed Circuit Breaker Tests**

Tank-Loss Index



EXAMPLE # 1	I (mA)	Watts	% PF
1 (Open)	1.150	0.07	0.61
2 (Open)	1.150	0.07	0.61
7 (Closed)	2.300	0.11	0.50

$$\text{TLI} = 0.11 - (0.07 + 0.07) = - 0.03 \text{ watts}$$

Comments: Test results are normal.



Tank-Loss Index

<u>Example #2</u>	<u>I(mA)</u>	<u>Watts</u>	<u>%PF</u>
1(OPEN)	1.15	0.07	0.61
2(OPEN)	1.2	0.22	1.83
7(CLOSED)	2.3	0.13	0.56

$$\text{TLI} = 0.13 - (0.07 + 0.22) = -0.16$$

Comments:

High Negative TLI “Wet” Interrupter on Bushing No. 2
or High Losses Near Bushing No. 2

May be the Lift Rod Guide Assembly

High Power Factor on Bushing No. 2, Test Bushing to Confirm



Tank-Loss Index

Example #3	I(mA)	Watts	%PF
1(OPEN)	1.15	0.07	0.61
2(OPEN)	1.2	0.22	1.83
7(CLOSED)	2.35	0.26	1.11

$$\text{TLI} = 0.26 - (0.07 + 0.22) = -0.03$$

Comments:

Normal TLI

Bushing No. 2 May Be Contaminated.

Test Bushing to Confirm.

Tank-Loss Index



<u>Example #4</u>	<u>I(mA)</u>	<u>Watts</u>	<u>%PF</u>
1(OPEN)	1.2	0.15	1.25
2(OPEN)	1.2	0.15	1.25
7(CLOSED)	2.3	0.11	0.48

$$\text{TLI} = 0.11 - (0.15 + 0.15) = -0.19$$

Comments:

High Negative TLI

Bushing May Be OK -Test to Confirm

Possible Problems:

- Deteriorated Operating-Rod Guide
- Upper Portion of Lift Rod
- Contaminated Interrupter Assemblies

Tank-Loss Index Example - DTA



DTA Field System

File Edit Operations Test Layout

Oil Circuit Breaker Insulation Test - Overall Tests

Location: Bluewater Substation Special ID: CB-W
 Serial No: 0139A5382-201 CCT Desig: Date: JUL 26 1988

	N	I	Brk	Bush Ener	Bus Ft	Ins #	P H	Test kV	Equiv. mA	10 kV watts	% PWR meas	FCTR corr	corr fctr	INS RTG	
1			O	1			1	10	2.400	0.300	1.25	1.23	0.98	G	
2			P	2			1	10	2.400	0.300	1.25	1.23	0.98	G	
3			E	3			2	10	2.400	0.240	1	0.98	0.98	G	
4			N	4			2	10	2.350	0.340	1.45	1.42	0.98	G	
5				5			3	10	2.350	0.250	1.06	1.04	0.98	G	
6				6			3	10	2.350	0.290	1.23	1.21	0.98	G	
TLI's															
7			C	1.2			1	10	4.500	0.530	1.18	1.16	0.98	-0.070	G
8			L	3.4			2	10	4.500	0.420	0.93	0.91	0.98	-0.160	L
9			S	5.6			3	10	4.450	0.500	1.12	1.10	0.98	-0.040	G

Expert System Analysis Output

Line: 8

ov_2100 cl_t1
 The high negative TLI may reflect contamination of the interrupter, lift rod guide, and/or upper part of the lift rod.

An immediate internal investigation is recommended. Contact your supervisor or Doble.

Detailed Limit Information

Line	TLI
8	
Low	Below -0.110000
High	Above 0.060000

Note: Number other bu

Limits Close

General Electric
 FK-115-5000-Y
 3 Tanks


Oil Circuit Breaker Test Summary



- Measure I, W and %PF
- Calculate Tank-Loss Index (TLI)
- $TLI = \text{Closed OCB Watts} - \text{Sum 2 Open OCB Watts}$
- %PF Corrected Using Bushing Type and Ambient Temperature
- Interpret Test Results on a Per Phase Basis

- The Insulating Properties of Wood or Other Insulating Members Can Be Measured
- This Dielectric Measurement is a Valuable Tool When Investigating High Power Factors From Other Dielectric Tests
 - Example: High Negative TLI Which May Indicate a Breaker Lift Rod Problem

Wood and Other Insulating Members



Wood and Other Insulating Members



Recommended Power Factor Test Limits:

Used

Breaker Lift-Rods:

0.20 Watts/3” @ 10 kV


Plastic Coated Members:

0.15 Watts/3” @ 10 kV

New or Excellent Condition

0.02 Watts/3” @ 10 kV

Interrupters - Investigative Tests



Power Factors for Interrupters (General Guideline)

Good:	10-30%
Questionable/Grey area:	30-50%
Bad:	>50%


- **Alternate Test Method:**

Wrap Additional Tin Foil Around the Bottom of the Interrupter With the Breaker in the Open Position


Recloser Tests

- Reclosers Are Tested as Oil Circuit Breakers
- If Unexpected Results are Obtained, Recloser May Have a Resistor Assembly Between Lower Bushing Terminals
 - Perform Alternate Tests 1-6 by Guarding One Bushing and Energizing the Opposite Bushing on the Same Phase
 - Alternate Tests Include Three UST Tests - One Per Phase

Alternate Recloser Tests 1-6



Alternate Recloser Tests 10-12





SF6 Dead Tank Breakers



Grounded Tank SF6 Breaker




ABB 169-PM-40-20

Grounded Tank SF6 Breaker



Overall Test Procedure:

- Disconnect Bus-work
- Record I, W, & C
- Record %PF if $I > 300 \mu\text{A}$
- Test Results Should Compare:
 - Between Phases
 - Previous Tests
 - Similar Units
 - Limit Files

Test Procedure:

- Overall Tests
- Bushing Hot-Collar Tests
- Capacitor
- Miscellaneous
- Diagnostic

Grounded Tank SF6 Circuit Breakers



Test Voltage

Rated 15 kV and above: 10 kV for all overall tests

Rated <15 kV:

Initial Test:

1. 2 kV
2. Rated Operating L-G Voltage
3. 10% and 25% Above Rated Operating L-G Voltage

Routine Follow-Up Tests:

1. 10% and 25% above rated L-G voltage


Single Contact Grounded Tank Breakers



Circuit Breaker Layout

- Look at the drawings as not all layouts are the same
- Most common layouts for which bushing designation is based on cabinet location but not always

Dielectric Circuit Single Contact Dead Tank Breaker



Insulation Components

C_B – Bushing

C_{GC} – Grading Capacitor

R_{OR} – Operating Rod

C_{SI} – Support Insulator

C_{IE} – Interrupter Envelope

Test Procedure for Single Contact Breaker


Test No.	Breaker Position	Test Mode	Terminal Energized	Terminal Floating	Terminal UST	Insulation Measured
1	OPEN	GST-GROUND	1	2	-	$C_B + C_{SI} + R_{OR}$
2	OPEN	GST-GROUND	2	1	-	$C_B + C_{SI}$
3	OPEN	GST-GROUND	3	4	-	$C_B + C_{SI} + R_{OR}$
4	OPEN	GST-GROUND	4	3	-	$C_B + C_{SI}$
5	OPEN	GST-GROUND	5	6	-	$C_B + C_{SI} + R_{OR}$
6	OPEN	GST-GROUND	6	5	-	$C_B + C_{SI}$
7	OPEN	UST	1	-	2	$C_{IE} + C_{GC}$
8	OPEN	UST	3	-	4	$C_{IE} + C_{GC}$
9	OPEN	UST	5	-	6	$C_{IE} + C_{GC}$

Dead Tank SF6 Breaker Tests



Tests No. 1 - 6

High Voltage Lead



Dead Tank SF6 Breaker Tests



Tests No. 1 - 6


- Stresses
 - Bushings
 - Support Insulators

- Test Mode: GST-Ground

Dead Tank SF6 Breaker Tests



Tests No. 7 - 9



Dead Tank SF6 Breaker Tests




Tests No. 7 - 9

- Stresses
 - SF6 Gas
 - Grading Capacitors and Resistors
- Test Mode: UST

Multi-Contact Grounded Tank Breakers



Dielectric Circuit for Multi-Contact Design for Dead Tank Breaker



Insulation Components

C_B – Bushing

C_{GC} – Grading Capacitor

R_{OR} – Operating Rod

C_{SI} – Support Insulator


C_{IE} – Interrupter Envelope

Test Procedure for Multiple Contact Breaker

Test No.	Breaker Position	Test Mode	Terminal Energized	Terminal Floating	Terminal UST	Insulation Measured
1	Open	GST-Ground	1	2	-	CB + CSI
2	Open	GST-Ground	2	1	-	CB + CSI
3	Open	GST-Ground	3	4	-	CB + CSI
4	Open	GST-Ground	4	3	-	CB + CSI
5	Open	GST-Ground	5	6	-	CB + CSI
6	Open	GST-Ground	6	5	-	CB + CSI
7	Open	UST	1	-	2	CIE 1&2 + CGC 1&2
8	Open	UST	3	-	4	CIE 1&2 + CGC 1&2
9	Open	UST	5	-	6	CIE 1&2 + CGC 1&2
10	Closed	GST-Ground	1 or 2	-	-	(2)CB + (3)CSI + ROR
11	Closed	GST-Ground	3 or 4	-	-	(2)CB + (3)CSI + ROR
12	Closed	GST-Ground	5 or 6	-	-	(2)CB + (3)CSI + ROR

Grounded Tank SF6 Breaker - Closed Position

Tests No. 10, 11 & 12



GST-Ground
Measures Support Insulators

Grounded Tank SF6 Breaker – Closed Position



***Note:**

To Test the Intermediate Support Insulator The Breaker Must Be Tested In The Closed Position With The GST-Ground Circuit




Live Tank Breakers



Live Tank Circuit Breakers







1 – Support column and
operating rod
2 – Interrupter
chamber
3 – Grading
capacitors

4 – Insertion resistors
5 – Line or bus
connections

Test Procedure for T and Y Type Live Tank Breakers



Dielectric Circuit for Type T Live Tank Circuit Breaker




Insulation Components

C_{GC} – Grading Capacitor C_{IE} – Interrupter Envelope
C_{RE} – Resistor Envelope C_{SI} – Support Insulator
R_{OR} – Operating Rod

Candlestick or “I” Type Live Tank Breaker



Dielectric Circuit for Candlestick Live Tank Breaker



Insulation Components

C_{GC} – Grading Capacitor C_{IE} – Interrupter Envelope
 C_{RE} – Resistor Envelope C_{SI} – Support Insulator
 R_{OR} – Operating Rod

Test Procedure for Candlestick or I Type Live Tank Breakers

Test No.	Breaker Position	Test Mode	Terminal Energized	Terminal Guarded	Terminal UST	Insulation Measured
1	OPEN	UST	B	-	A	CIE + CGC + CRE
2	OPEN	GST- GUARD	B	A	-	CSI + ROR



Open Breaker Tests

- Evaluate I, W, %PF
- For Charging Current of less than 300 micro-amps, Power Factor May Not Be Significant and More Emphasis is Given to Watts-loss Values
- Due to the Wide Range of Contacts, Grading Capacitors, Grading Resistors That Are Available in SF6 Breakers, Data Should be Compared To
 - The Doble Test-Data-Reference-Book
 - Similar Units
 - Previous Results



Closed Breaker Tests

- Evaluate I, W, and %PF
- Results Are Compared With
 - The Doble Test Data Reference Book
 - Previous Results on a Per Phase Basis
 - Similar Units



- If Moisture is Suspect Due to High Watts and %PF, Cycling the Breaker Several Times May Improve the Test Result
 - Conduct a DEW POINT Analysis to Confirm the Presence of Moisture
- If Bushings Are Equipped With Potential Taps or Test Taps, Perform the Following Bushing Tests
 - C1(Main Core Insulation)
 - C2 (Bushing Tap Insulation)


- SF6 Filled Bushings Should be Tested by the Single-Hot Collar Method or by the Multiple-Hot Collar Method
 - The Presence of Contamination or Cracks Along the Inside Weathershed Could be Detected
 - Compare Test Results to Similar Units
 - Single Hot Collar Test Results Should Yield 0.1 Watts or Less for Acceptable Test Results
 - Consider Performing the Test at Multiple Voltages to See if a Problem is Voltage Sensitive



Vacuum Breakers



Vacuum Circuit Breaker



Power Factor Test Procedure

SAME TEST PROCEDURE AS SF6

Switch gear Cubicle

- Open-Breaker Tests (6 Tests)
- Open-Breaker UST Tests (3 Tests)
- Diagnostic (Questionable Results)

Vacuum Circuit Breakers



Power Factor Test Procedure

Free-Standing

- Bushings (Hot-Collar)
- Open-Breaker Tests (6 Tests)
- Open-Breaker UST Tests (3 Tests)
- Diagnostic (Questionable Results)

Test Voltage

Rated 15 kV and Above: 10 kV for all Overall Tests

Rated <15 kV:

Initial Test:

1. Low Voltage (2 kV). (Basic Insulation Power Factor)
2. Rated L-G Voltage
3. 10% and 25% above rated. L-G voltage

Routine Follow-Up Tests:

1. 10% and 25% above rated L-G voltage

NOTE: Test Voltage

For 15 kV Vacuum Breakers Operating at 13.8 kV

- Initial Test

- Tests Should be Conducted at 2, 8, 8.8, to 10 kV

- Future Tests


- The Highest Test Voltage Without Appreciable Corona



Overall Test Procedure Vacuum Circuit Breakers/Reclosers

Test No.	Breaker Position	Test Mode	Bushing Energized	Bushing Floating	Bushing UST
1	OPEN	GST	1	2	-
2	OPEN	GST	2	1	-
3	OPEN	GST	3	4	-
4	OPEN	GST	4	3	-
5	OPEN	GST	5	6	-
6	OPEN	GST	6	5	-
7	OPEN	UST	1	-	2
8	OPEN	UST	3	-	4
9	OPEN	UST	5	-	6

Outdoor Vacuum Breaker Tests






Outdoor Vacuum Breaker Tests

Open Breaker Tests 1-6:

- Energize each of the six phase bushings
- Test Mode: GST-Ground

Outdoor Vacuum Breaker Tests





Outdoor Vacuum Breaker Tests

Open Breaker Tests 7-9:

- Energize One Bushing of Each Phase
- Low Voltage Lead Connected to Opposite Bushing of Energized Phase
- Test Mode: UST

Test 1-6 Stresses

- Bushings
- Support Insulators
- Phase Barriers
- Operating Rod

Test 7-9 Stresses

- Vacuum Interrupter



Vacuum Circuit Breaker- Test Analysis

Open Breaker Tests:

- Tests 1-6 dominated by bushings. Also includes operating rod, any support insulation, and any phase barriers
- I, W (Charging Current is expected to be small so Power Factor is not calculated)
- The current and watts for Tests 1-6 are compared with each other, with previous results, and other similar breakers on the system
- The Watts-Loss should be compared to the Test Data Reference Book
- Under Dry Conditions Vacuum Bottles should have losses approaching zero for tests 7-9. Compare phases to each other
- If High UST losses are present, a defective bottle or surface conditions



Vacuum Circuit Breaker- Test Analysis

Open Breaker Tests: (Contd.)

- The Watts-Loss Should Be Compared to the Doble Test Data Reference Book
- Under Dry Conditions Vacuum Bottles Normally Have Losses Approaching Zero for Tests 7-9. Compare Phases to Each Other
- High UST Losses Indicate a Defective Bottle or a Contaminated Surface Condition Exists

Troubleshooting Steps:


- Clean the surface of the bottle
- Apply Heat to the bottle
- Use a guard collar




Air Circuit Breakers




Air-Magnetic Circuit Breaker



Air-Magnetic Circuit Breaker



Air-Magnetic Circuit Breaker



Air-Magnetic Circuit Breaker



- Open Breaker tests 7-9:
 - Energize One Bushing of a Phase
 - Place the Low Voltage Lead On the Opposite Phase Bushing
 - Test Mode: UST



DTAPro Test Procedure Air-Magnetic Circuit Breaker

Overall Test Setup

#	Connections			Inputs			Test Results				
	Breaker	HV Lead	Red Measure Lead	Phase	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1	Open	1	2	A	*	*	*	*	*	*	*
2		2	1		*	*	*	*	*	*	
3		3	4	B	*	*	*	*	*	*	
4		4	3		*	*	*	*	*	*	
5		5	6	C	*	*	*	*	*	*	
6		6	5		*	*	*	*	*	*	
7		1	2	A	*	*	*	*	*	*	
8		3	4	B	*	*	*	*	*	*	
9		5	6	C	*	*	*	*	*	*	



DTAF Test Procedure Air-Magnetic Circuit Breaker

All Tests - BREAKER OPEN

#	N	Test Mode	ENG	GAR	PH	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Arc Chutes	Rtg	Rtg
1	<input type="checkbox"/>	GAR	1	2									▼		
2	<input type="checkbox"/>	GAR	2	1									▼		
3	<input type="checkbox"/>	GAR	3	4									▼		
4	<input type="checkbox"/>	GAR	4	3									▼		
5	<input type="checkbox"/>	GAR	5	6									▼		
6	<input type="checkbox"/>	GAR	6	5									▼		
7	<input type="checkbox"/>	UST	1	2									▼		
8	<input type="checkbox"/>	UST	3	4									▼		
9	<input type="checkbox"/>	UST	5	6									▼		

Air-Magnetic Circuit Breaker



Test Procedure - Breaker Open

- Record I, W and %PF
- No Temperature Correction
- Tests 1, 3 and 5 Should Compare
- Tests 2, 4 and 6 Should Compare
 - Main Influence - Bushing
- Tests 7 Through 9 Should Compare
 - Condition of the arc chutes



Air-Magnetic Circuit Breaker

Test Data Analysis

- Tests 1 to 6
 - Dominated by Bushings
 - Includes Operating Rod, Puffer Assembly, Phase Barriers
- Tests 7, 8, and 9
 - Condition of Arc-Chute
 - Very Low Current, Evaluate Losses
- Diagnostic Tests Performed With Phase Barriers and Arc-Chutes Removed

Air-Magnetic Circuit Breaker



Test Data Analysis

- If Current is Greater Than 200 μA , Evaluate % PF
- No Temperature Correction
- Compare results:
 - Among Similar Test Specimens (Among Phases)
 - Tests 1, 3, and 5
 - Tests 2, 4, and 6
 - Tests 7, 8, and 9
 - Compare Results to Any Previous Tests, Similar Breakers, and to similar breakers using DTA Web




Surge Arresters



Surge Arresters




Silicon Carbide



Older Designs

Metal Oxide



(MCOV & MOV)
Newer Designs

Surge Arresters Description

Normal Condition \implies Insulator

Instant of Disturbance \implies Conductor

Passing of Disturbance \implies Insulator


Non-Linear Volt-Ampere Characteristic

Dielectric-Loss Test - Not a Test of The Arrester's
Protective Characteristics

Surge Arresters




Silicon Carbide



- Over design ratings it dissipates the impulse
- Drops down to zero
- Generates its own impulse

Metal Oxide



- Over design ratings it dissipates the impulse
- Clamps the voltage
- Doesn't drop to zero
- Doesn't generate its own impulse

Surge Arrester Test Voltages

- To make comparisons meaningful, arresters must be tested at the same voltage levels
- Clean all porcelain surfaces to minimize surface leakage

Surge Arresters Test Voltages




ARRESTER TYPE	KV RATING	10KV	2.5KV
Silicon Carbide	3.0	2.5	2.5
	4.5	4.0	2.5
	6.0	5.0	2.5
	7.5	7.0	2.5
	9.0	7.5	2.5
	12.0 and Above	10	2.5
Metal Oxide	2.7 to 3.0	2.0	2.0
	4.5 to 12.0	2.5	2.5
	15.0 and Above	10	2.5

Refer to Tabulation in the Doble Test Data-Reference Book

Single Unit Arrester




1. Bus must be disconnected from top of unit.
2. Place HV test lead as shown.
3. If discharge counter present, place jumper from bottom of arrester to ground, bypassing the counter.
4. Connect test set ground to grounded structure supporting arrester stack.
5. Use a GST-Ground test circuit.



Two Unit Arrester Stack

1. Place test leads as shown. Colors may be interchanged. Bus must be disconnected from top unit.
2. If discharge counter present, place jumper from bottom of B to ground, bypassing the counter.
3. Connect test set ground to grounded structure supporting arrester stack.




Two Unit Arrester Stack

4. A and B must be measured one at a time as follows:


Choose This Circuit	To Measure
UST Measure Red	A
GST Guard Red	B

5. Use the **multiple** test choice to speed testing.

6. This example uses the Red lead. The blue lead could have been used instead, and all test circuit choices would then have the red replaced by blue.




Test Method 1 - Dual-Stack Arresters




No.	Mode	Energize	Ground	Measure
1	GST	1	2	A

Test Method 1 - Dual-Stack Arresters




No.	Mode	Energize	Ground	Measure
2	GST	2	3	B

Test Method 2 - Dual-Stack Arresters



No.	Mode	Energize	Ground	Guard	UST	Measure
1A	UST	2	3	----	1	A

Test Method 2 - Dual-Stack Arresters




No.	Mode	Energize	Ground	Guard	UST	Measure
2A	GST	2	3	1	----	B

Surge Arresters




Three Arresters:



Three Unit Arrester Stack

Bus Connected To Top & Grounded

1. Place test leads as shown. Colors may be interchanged.
2. If discharge counter present, place jumper from bottom of C to ground, bypassing the counter.
3. Connect test set ground to grounded structure supporting arrester stack.



Three Unit Arrester Stack

Bus Connected To Top & Grounded

4. A, B, and C must be measured one at a time as follows:


Choose This Circuit **To Measure**

GST Guard Red A

UST Measure Red B

5. Use the **multiple** test choice to speed testing.



6. To measure C, remove HV cable and LV leads. Replace **HV cable** between B and C. Replace **Red LV** lead between A and B. Use **GST-Guard Red** circuit. Blue lead may be used instead of red lead. If blue lead used, test circuit would then be GST-Guard Blue.



Testing Multi-Stack Arresters




Test No.	Test Mode	Energize	Ground	Guard	UST	Measure
1	GST	2	1,6	3	----	A
2	UST	2	1,6	----	3	B
3	UST	3	1,6	----	4	C
4	UST	5	1,6	----	4	D
5	GST	5	1,6	4	----	E




Testing Multi-Stack Arresters

Test No.	Test Mode	Energize	Ground	Guard	UST	Measure
1	GST	2	1,6	3	----	A




Testing Multi-Stack Arresters

Test No.	Test Mode	Energize	Ground	Guard	UST	Measure
2	UST	2	1,6	----	3	B




Testing Multi-Stack Arresters

Test No.	Test Mode	Energize	Ground	Guard	UST	Measure
3	UST	3	1,6	----	4	C




Testing Multi-Stack Arresters

Test No.	Test Mode	Energize	Ground	Guard	UST	Measure
4	UST	5	1,6	----	4	D



Testing Multi-Stack Arresters

Test No.	Test Mode	Energize	Ground	Guard	UST	Measure
5	GST	5	1,6	4	----	E



Arrester Test Results Analysis

Refer to Published Tabulations

Compare Losses Obtained for Similar Units Tested
Under Same Conditions

Any Deviation, Either Higher or Lower, Should Be
Investigated

Rating Are Based On Watts-Loss Values

%PF Not Calculated

Temperature Correction Unnecessary

Metal Oxide

Higher Than Normal Losses

Contamination by Moisture, Dirt or Dust
Corroded Gaps in Early Designs (newer designs gapless)

Lower Than Normal Losses

Discontinuities in Internal Electrical Configuration

Silicon Carbide

Higher Than Normal Losses

Contamination by Moisture, Dirt or Dust
Corroded Gaps

Lower than Normal Losses

Broken Shunting Resistors
Poor Contact and Open Circuits Between
Elements

Change in Currents

Mechanical Damages



Handling Suspect Arresters

- A damaged seal-gapped arrester should be handled with care. Due to the increased pressure caused by the destruction of internal elements, a defective arrester may be an explosive hazard.
- If the decision is made to disassemble a suspect unit, ensure that the chamber is properly vented.
- Do not simply “throw away” defective arresters.
- Any suspect arrester should be vented and discharged before disposal.

Surge Arresters



ABB ASEA BROWN BOVERI

ABB Power T&D Company Inc.

SURGE ARRESTER CLASS: STATION **TYPE: EXLIM P**

STYLE NOP054XA042A	SERIAL NO. 96E8074	PRESSURE RELIEF 80 kA
DUTY CYCLE RATING 54	MCOV RATING 42.00	WEIGHT 121 Lbs.
UNIT STACKING ORDER		GRADING RING ASSY
BOT	UNIT STYLE	UNIT SERIAL NO.
2ND		MCOV kV
3RD		
4TH		

ALTITUDE UP TO 10000 FT.
BEFORE INSTALLING
READ: IL 38-336-1C

PART 270P284H01A MADE IN BLOOMINGTON, IN USA

Surge Arrester Test Data Examples

Hand-Written Data Sheet



The middle phase OB arrester, type 217598 is rated Good by the technician

									Arrester Type	Rating
		mA				Watts				
HS LA										
Φ1	10	21	10	210	8	.01	.08	ABB	P120XA098A	98KV G
Φ2	↓	18	↓	180	34	↓	.34	OB	217598	98KV
Φ3	↓	21	↓	210	5	↓	.05	ABB	P120XA098A	98KV V

Surge Arrester	μA	Watts	Rating
Φ1- ABB P120XA098A	210	0.08	G
Φ2- OB 217598	180	0.34	G
Φ3- ABB P120XA098A	210	0.05	G

Example:



Original bad data flagged by DTA: This arrester was left in service and subsequently failed .

Auxiliary Transformer Tests - Surge Arrester Tests

Serial Num: YAS85131 Special ID:
Location: Noyes Island CCT Design: Date: May 14 1998

	N	I	Arrester Location	Mfr	Serial #	Rated kV	Test Mode	Test kV	Equiv. 10 kV mA	10 kV watts	INS RTE
1			Phase A	A-BB	F120XA098A	98		10	0.210	0.080	G
2			Phase B	OB	217598	98		10	0.180	0.340	I
3			Phase C	A-BB	F						
4											
5											
6											
7											
8											
9											
10											
11											
12											

Expert System Analysis Output

sa00 W1
The Watt reading is higher than the limit. Higher than normal watt readings maybe caused by internal contamination or deterioration, or external surface leakage. Retest after cleaning or retest using a guard collar. If acceptable readings cannot be obtained, the arrester should be replaced. Contact your supervisor or Doble.

Example of Problem Arresters



DTA Field System

File Edit Operations Test

Auxiliary Transformer Tests - Surge Arrester Tests

Serial Num: 7001933 Special ID: Number One Bank
Location: LON HILL 345/138/69/12 KV CCT Desig: Auto Date: Apr 24 2002

	N	I	Arrester Location	Mfr	Serial #	Rated kV	Test Mode	Test kV	Equiv. 10 kV mA	watts	INS RTG	
1	N		H1	OB	69284-ID	300.	GROUND	10	0.685	5.475	B	
2			H2	OB	69280-ID	300.	GROUND	10	0.371	0.910	B	
3			H3	OB	69275-ID	300.	GROUND	10	0.280	0.247	I	
4			X1	OB	69740-CH	120.	GROUND	10	0.176	0.075	G	G
5			X2	OB	69760-CH	120.	GROUND	10	0.183	0.171	I	D
6			X3	OB	69758-CH	120.	GROUND	10	0.173	0.072	G	G
7			Y1	OB	15MPA51621B	15.0	GROUND	10	0.090	0.167	G	
8			Y2	OB	15MPA51617B	0.0	GROUND	10	0.078	0.374	Q	
9			Y3	OB	15MPA51619B	0.0	GROUND	10	0.077	0.356	Q	
10												
11												
12												

Djag Test Excitation Jump To **Prev Date** Next Date Save Exit

Example of Problem Arresters



DTA Field System

File Edit Operations Test

Auxiliary Transformer Tests - Surge Arrester Tests

Serial Num: 7001933 Special ID: Number One Bank
 Location: LON HILL 345/138/69/12 KV CCT Desig: Auto Date: Apr 24 2002

	N	I	Arrester Location	Mfr	Serial #	Rated kV	Test Mode	Test kV	Equiv. 10 kV mA	watts	INS RTG
1	N		H1	OB	69284-ID	300.	GROUND	10	0.685	5.475	B
2			H2	OB	69280-ID	300.	GROUND	10	0.371	0.910	B
3			H3	OB	69275-ID	300.	GROUND	10	0.280	0.247	I
4			X1				GROUND	10	0.176	0.075	G
5			X2				GROUND	10	0.183	0.171	I
6			X3				GROUND	10	0.173	0.072	G
7			Y1				GROUND	10	0.090	0.167	G
8			Y2				GROUND	10	0.078	0.374	Q
9			Y3				GROUND	10	0.077	0.356	Q
10											
11											
12											

Arrester Detail

Unit Cat#:

Type: MPR300

Rated kV: 300.

Test kV: 10

Overall Cat#: 211345

Misc Data:

Save Selections Change Selections

Djag Test Excitation Jump To Prev Date Next Date Save Exit

Example of Problem Arresters



DTA Field System

File Edit Operations Test

Auxiliary Transformer Tests - Surge Arrester Tests

Serial Num: 7001933 Special ID: Number One Bank
 Location: LON HILL 345/138/69/12 KV CCT Desig: Auto Date: Apr 24 2002

	N	I	Arrester Location	Mfr	Serial #	Rated kV	Test Mode	Test kV	Equiv. 10 kV mA	watts	INS RTG
1	N		H1	OB	69284-ID	300.	GROUND	10	0.685	5.475	B
2			H2	OB	69280-ID	300.	GROUND	10	0.371	0.910	B
3			H3	OB	69275-ID	300.	GROUND	10	0.280	0.247	I
4			X1				GROUND	10	0.176	0.075	G
5			X2				GROUND	10	0.183	0.171	I
6			X3				GROUND	10	0.173	0.072	G
7			Y1				GROUND	10	0.090	0.167	G
8			Y2				GROUND	10	0.078	0.374	Q
9			Y3				GROUND	10	0.077	0.356	Q
10											
11											
12											

Arrester Detail

Unit Cat#:

Type: MPR300

Rated kV: 300.

Test kV: 10

Overall Cat#: 211345

Misc Data:

Save Selections Change Selections

"OB|211345||MPR300|SINGLE|300|10|NO|0.005|0.05



DTA Field System

Note Pad

We found that the two arresters on H1 and H2 bushings tested bad. The arrester on H3 tested high so we are going to change all three of them. X1 and X3 tested good but X2 tested high so were going to change out all three of the low side arresters.

Arrester Tests

Special ID: Number One Bank
CCT Design: Auto Date: Apr 24 2002

	N	I	Location	Mfr	Serial #	Rated kV	Test Mode	Test kV	Equiv. 10 kV mA	watts	INS RTG	
1	N		H1	OB	69284-ID	300.	GROUND	10	0.685	5.475	B	
2			H2	OB	69280-ID	300.	GROUND	10	0.371	0.910	B	
3			H3	OB	69275-ID	300.	GROUND	10	0.280	0.247	I	
4			X1	OI			GROUND	10	0.176	0.075	G	G
5			X2	OI			GROUND	10	0.183	0.171	I	D
6			X3	OI			GROUND	10	0.173	0.072	G	G
7			Y1	OI			GROUND	10	0.090	0.167	G	
8			Y2	OI			GROUND	10	0.078	0.374	Q	
9			Y3	OI			GROUND	10	0.077	0.356	Q	
10												
11												
12												


Arrester Detail

Unit Cat#:
Type: MPR300
Rated kV: 300.
Test kV: 10
Overall Cat#: 211345
Misc Data:

Save Selections Change Selections

"OB|211345||MPR300|SINGLE|300|10|NO|0.005|0.05"

Examples of Problem Arrester



- Arresters could not be replaced. The H1 arrester failed hours after being energized.



Potential Transformers



Potential Transformers (PTs)

H1

H2



H1

H0
(Stubby
bushing)

Why Do We Test?

- Prevent catastrophic failures and loss of apparatus
- Reliability
 - Not only provides for equipment reliability but can often times improve morale of personnel (not always replacing damaged equipment)*
- Avoid injury to personnel
- Prevent collateral damage to other equipment
- Insurance underwriters often require equipment to be tested

Why Do We Test?



Why Do We Test?



Line to Line Potential Transformer

H1



H2



Potential Transformers

Liquid-Filled Line-to-Line PTs Rated Below 15 kV Insulation Class

PT Voltage Rating	Test Voltage (kV)
7.2 to 8.7	5.0
4.2 to 5.0	2.5
2.4	2.0

*For Unit Rated 15 kV and Above, perform test series at 10 kV

Liquid-Filled Line-to-Ground PTs

- a) Perform test series at the rated voltage of the neutral bushing.
- b) Cross-Checks are performed at 10 kV or rated Line-to-Ground Voltage (whichever is lower)

Potential Transformers

Dry-Type Line-to-Line PTs Rated Below 15 kV Insulation Class

PT Voltage Rating	Test Voltage (kV)
Overall	a. 2 kV b. Line-to-Ground Voltage c. 10% to 25% Above Line-to-Ground operating Voltage
Cross-Check	a. 2 kV b. Line-to-Ground Operating Voltage
Exciting Current	a. Line-to-Ground Operating Voltage

Dry-Type Line-to-Ground PTs Rated Below 15 kV Insulation Class

- a) Perform test series at a voltage not to exceed the neutral bushing rating as was outlined in the previous section.
- b) Cross-Checks are performed at 10 kV or rated Line-to-Ground Voltage (whichever is lower)

*For Units rated above 15 kV, the complete test series is performed at 2 and 10 kV

Test Procedure - Single Phase PTs

DTAF Program

	N	Test Mode	ENG	GND	GAR	UST	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)
1	<input type="checkbox"/>	GND	H1,H2	X1,Y1									
2	<input type="checkbox"/>	GAR	H1	X1,Y1	H2								
3	<input type="checkbox"/>	GAR	H2	X1,Y1	H1								
4	<input type="checkbox"/>	UST	H1	X1,Y1		H2							
5	<input type="checkbox"/>	UST	H2	X1,Y1		H1							
6	<input type="checkbox"/>	GND	H1,H2	X1,Y1	@2kV		2.0						


Supplemental Tests

1	<input type="checkbox"/>	UST	H1,H2	Y1		X1							
2	<input type="checkbox"/>	UST	H1,H2	X1		Y1							
3	<input type="checkbox"/>	GAR	H1		H2,X1,Y1								
4	<input type="checkbox"/>	GAR	H2		H1,X1,Y1								




Test Procedure Using DTAF Program

Test #1 : GST Ground - No LV Lead Required
Measure: CH1+CHX+CHY+CH2




Test #2: GST-Guard (Cross-Check Test #1)

• **Measure:** $CH1 + 1/2CHX + 1/2CHY$




Test #3: GST-Guard (Cross-Check Test #2)

•Measure: $CH2 + 1/2CHX + 1/2CHY$




Test #4: Ungrounded Specimen Test (UST)

Measure: Excitation Current



Test #5: Ungrounded Specimen Test (UST)


Measure: Excitation Current



Supplemental Tests

Test #7 : UST


Measure: C_{HY}



Supplemental Tests

Test #8: GST-Guard Red & Blue


Measure: C_{H1}



Supplemental Tests

Test #9: GST-Guard Red & Blue

Measure: C_{H2}



Test Procedure - Single Phase PTs


DTAPro Program

Overall Test Setup										
Connections				Inputs		Test Results				
#	HV Lead	Ground	Red Measure Lead	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)
1	H1, H2	X1, Y1	Unused	*	*	*	*	*	*	*
2				2.000	*	*	*	*	*	*
3	H1		H2	*	*	*	*	*	*	*
4	H2		H1	*	*	*	*	*	*	*
5	H1		H2	*	*	*	*	*	*	*
6	H2		H1	*	*	*	*	*	*	*
Supplemental Tests										
7	H1, H2	Y1	X1	*	*	*	*	*	*	*
8		X1	Y1	*	*	*	*	*	*	*
9	H1	Unused	H2, X1, Y1	*	*	*	*	*	*	*
10	H2		H1, X1, Y1	*	*	*	*	*	*	*




Test Procedure Using DTAPro Program

Test #1 : GST Ground - No LV Lead Required
Measure: CH1+CHX+CHY+CH2




Test #2 : GST Ground - No LV Lead Required
Measure: CH1+CHX+CHY+CH2




Test #3: GST-Guard (Cross-Check Test #1)

• **Measure:** $CH1 + 1/2CHX + 1/2CHY$




Test #4: GST-Guard (Cross-Check Test #2)

•Measure: $CH2 + 1/2CHX + 1/2CHY$




Test #5: Ungrounded Specimen Test (UST)

Measure: Excitation Current



Test #6: Ungrounded Specimen Test (UST)


Measure: Excitation Current



Supplemental Tests

Test #8 : UST


Measure: C_{HY}



Supplemental Tests

Test #9: GST-Guard Red & Blue


Measure: C_{H1}




Supplemental Tests

Test #10: GST-Guard Red & Blue

Measure: C_{H2}



Internally Grounded PT



Neutral Shown Internally Grounded

Internally Grounded PT


Test Procedure

Test No.	Mode	Energize	Ground	Guard	UST
1	UST	H1	HO	----	X1,Y1
2	GST	H1	HO	X1,Y1	----

Test No. 1: Measures Line-End Inter-winding Insulation

Test No. 2: Measure Excitation Current

Line to Ground PT




H1

H0/H2
(Stubby
bushing)

Line to Ground PT

TEST PROCEDURES ARE
THE SAME AS FOR THE 2
BUSHING

**LOWER TEST VOLTAGE
REQUIRED WHEN H0 IS
ENERGIZED**




Line to Ground PT

Note that the H0 bushing is smaller and is grounded!

Ground is removed and a reduced voltage used when the H0 is energized!

NOTE: Test Voltage for Tests 1, 3, 4, 5 Limited by Rating of Neutral Bushing (2/5 kV)




Single Phase Line to Ground PT

Test 1 Overall DTAF
(Tests 1 and 2 for DTAPro)

H1 & H0 Jumpered

GST – no LV lead is
required

The secondary windings are
grounded for tests 1-5




Single Phase Line to Ground PT

Test 2 DTAF
(Test 3 DTAPro)

Cross Check

GST - Guard




Single Phase Line to Ground PT

Test 3 DTAF
(Test 4 DTAPro)

Cross Check

GST - Guard




Single Phase Line to Ground PT

Test 4 DTAF
Test 5 DTAPro)

Excitation

UST




Single Phase Line to Ground PT

Test 5 DTAF
(Test 6 DTAPro)

Excitation

UST




Single Phase Line to Ground PT

Test 6 Overall DTAF
(Tests 1 and 2 for DTAPro)

H1 & H0 Jumpered

GST – no LV lead is
required

The secondary windings are
grounded for tests 1-5



Test Procedure-Single-Phase PT - DTA

	N	Test Mode	ENG	GND	GAR	UST	Test kV	mA	Watts	% PF Meas.	% PF Corr.	Corr. Factor	Cap. (pF)	Rtg	Rtg
1	<input type="checkbox"/>	GND	H1,H2	X1,Y1			0.99	4.518	0.2310	0.51	0.33	0.64	1198.5	G	G
2	<input type="checkbox"/>	GAR	H1	X1,Y1	H2		10.0	1.480	0.0410	0.28	0.18	0.64	392.51	G	G
3	<input type="checkbox"/>	GAR	H2	X1,Y1	H1		1.00	3.036	0.1890	0.62	0.40	0.64	805.25	G	G
4	<input type="checkbox"/>	UST	H1	X1,Y1		H2	0.99	0.1480	1.381					Q	G
5	<input type="checkbox"/>	UST	H2	X1,Y1		H1	1.00	0.1440	1.401					Q	G
6	<input type="checkbox"/>	GND	H1,H2	X1,Y1	@2kV		2.0								

Should be "EQUAL"

Supplemental Tests **1.480 + 3.036 = 4.516 mA** **0.0410 + 0.1890 = 0.230 Watts**


1	<input type="checkbox"/>	UST	H1,H2	Y1		X1									
2	<input type="checkbox"/>	UST	H1,H2	X1		Y1									
3	<input type="checkbox"/>	GAR	H1			H2X1,Y1									
4	<input type="checkbox"/>	GAR	H2			H1X1,Y1									

Analysis of Results: PTs

- Compare Overall Power Factor Test Values to Previous Test Results
- Compare Overall Power Factor Values to Similar Units (Test-Data-Reference-Book)
- Compare Cross-Check Power Factors
 - Most PTs Test Results are Similar


PT #1 – First Test

Test Nomenclature	Test kV	I (mA)	Watts	Measured % PF	Corrected % PF
1 Overall	10	1.323	1.744	13.18	14.6
2 Cross-Check 1	10	1.275	0.029	0.23	0.26
3 Cross-check 2	10	2.393	0.101	0.42	0.47
Summation of Cross-checks		3.668	0.130		




PT # 2 – First Test

Test Nomenclature	Test kV	I (mA)	Watts	Measured % PF	Corrected % PF
1 Overall	10	1.374	1.717	12.5	
2 Cross-Check 1	10	1.325	0.031	0.23	
3 Cross-check 2	10	2.428	0.104	0.43	
Summation of Cross-checks		3.753	0.135		



PT # 3 – First Test


Test Nomenclature	Test kV	I (mA)	Watts	Measured % PF	Corrected % PF
1 Overall	10	3.78	0.835	2.24	
2 Cross-Check 1	10	1.283	0.030	0.23	
3 Cross-check 2	10	2.432	0.107	0.43	
Summation of Cross-checks		3.715	0.137		



- Test voltage should be limited to either 2 or 5 kV for Tests 1 and 3.
- The overall Power Factors are very high and the summation of the current and losses for the Cross-Checks do not agree.
- H1 and H0 bushings were not connected together for the tests.


PT # 1 – As Left

Test Nomenclature	Test kV	I (mA)	Watts	Measured % PF	Corrected % PF
1 Overall	5	3.775	0.134	0.35	0.39
2 Cross-Check 1	10	1.281	0.029	0.23	0.26
3 Cross-check 2	5	2.429	0.105	0.43	0.48
Summation of Cross-checks		3.710	0.134		
4 Excitation Current 1	5	0.197			
5 Excitation Current 2	5	0.205			




PT # 2 – As Left

Test Nomenclature	Test kV	I (mA)	Watts	Measured % PF	Corrected % PF
1 Overall	5	3.823	0.133	0.35	0.42
2 Cross-Check 1	10	1.324	0.031	0.23	0.27
3 Cross-check 2	5	2.426	0.102	0.42	0.50
Summation of Cross-checks		3.750	0.133		
4 Excitation Current 1	5	0.205			
5 Excitation Current 2	5	0.205			



PT # 3 – As Left

Test Nomenclature	Test kV	I (mA)	Watts	Measured % PF	Corrected % PF
1 Overall	5	3.724	0.127	0.34	0.38
2 Cross-Check 1	10	1.275	0.028	0.22	0.24
3 Cross-check 2	5	2.389	0.099	0.41	0.46
Summation of Cross-checks		3.664	0.127		
4 Excitation Current 1	5	0.201			
5 Excitation Current 2	5	0.201			



Analysis of Results: PTs

Examples:

PT #1

Test No.	mA	Watts	%PF
1 (Overall)	2.540	0.104	0.41
2 (H1 Cross-check)	1.256	0.056	0.45
3 (H0 Cross-check)	1.248	0.046	0.37

PT #2


High power factor when the H1 bushing is energized

Test No.	mA	Watts	%PF
1 (Overall)	2.650	0.354	1.32
2 (H1 Cross-check)	1.356	0.313	2.31
3 (H0 Cross-check)	1.248	0.055	0.44

Single Phase Line to Ground PT

Troubleshooting
high power factor

GST – Guard
Guard Collar is
near base of porcelain





Current Transformers



Test Procedure



- Short Primary Windings
- Ground all Secondary Windings
- Perform Overall Test in GST Ground Mode
- Perform Tap Test C1 and C2 (If Test Tap Installed)



CT Test Voltage

Liquid Filled


- 15 kV and Above: 10 kV
- Below 15 kV: Test Voltage Equal to or Below Nameplate Operating Line to Ground (L-to-G) Voltage

Dry-Type

- 15 kV and Above: 2 kV
10 kV*
- Below 15 kV: 2 kV
L-to-G Voltage *
10% to 25% Above Operating
L-to-G Voltage


* Note: Tip-Up Tests

Current Transformers (CTs)




© 2012 Doble Engineering Company
All Rights Reserved.

Current Transformers (CTs)



CT Without Test Tap

Current Transformers (CTs)



CT Without Test Tap

Test Procedure




Test Procedure: CTs Without Test Taps

Test No.	Energize	Ground	UST	Guard
1 (Overall)	Primary	Secondary	----	----

Test Procedure




Test No. 1: GST- Ground




CT Without Test Tap

Current Transformers (CTs)



CT With Test Tap

Current Transformers (CTs)



CT With Test Tap

Test Procedure




Test Procedure: CTs With Test Taps

Test No.	Energize	Ground	UST	Guard
1 (Overall)	Primary	Secondary	----	----
2 (C1)	Primary	Secondary	Tap	----
3 (C2)	Tap	Secondary	----	Primary

Test Procedure




Test No. 1: GST- Ground



CT With Test Tap


Test Procedure

Test No. 2: UST



Test Procedure

Test No. 3: GST-Guard



Current Transformers - DTA



DTA Field System

File Edit Operations Layout Window

Current Transformer Insulation Test - Identification

General Info

Company: Division:
Location: Test Date:
Tested by: Test Set Type: Reason:

Nameplate Data

Manuf: Yr Mfr'd: Serial No:
Max Volt: Amps: Special ID:
CCT Desig:
Type: Insul Type:
Secondary Resistance:
Catalog/Style #:
Current Ratio:

Current Transformers - DTA



DTA Field System

File Edit Operations Test Layout

Current Transformer Insulation Test - Overall Tests

Location: 345 ROB PARK Special ID: CENTER

Serial No: 1 CCT Desig: ARGENTA CB Date: Sep 29 1994

	N	I	Tst Mod	Test Connections	UST	Test kV	Equiv. mA	10 kV watts	% PWR meas	FCTR corr	corr fctr	C(pF) meas	INS RTG
1	N		GND	H1,H2		10	3.775	0.161	0.43	0.46	1.07	998	G
2	N		UST	H1,H2	TAP	10	3.250	0.139	0.43	0.46	1.07	867	I
3			GAR	TAP	H1,H2	2.5	34.900	1.620	0.46	0.49	1.07	9165	I
4			GND	H1,H2		2.0	3.760	0.158	0.42	0.45	1.07	998.50	G
5			Misc Test - Described in Note										
6			Misc Test - Described in Note										
7			Hot Collar Test on H1										
8			Hot Collar Test on H2										

ID Screen Oil Tests Jump To Prev Date Next Date Save Exit

Analysis



- Calculate Power Factor
- Compare Test Results to identical apparatus



Doble Current Transformer Supplemental Tests


Basic Principle

- Basic Theory for Power Transformer Tests and Data Interpretation Also Applies to CT's
- Apply Test Voltage Across Full Winding With the Highest Number of Turns:
 - Minimizes Test Current
 - No Step-Up Voltage
- Excitation Current Tests Can be Performed at Multiple Test Voltages for Saturation Curve



Doble Current Transformer Turn Ratio Test

Doble Transformer Turn Ratio Test




$$C_{True} = \frac{I_C}{10 \text{ kV} \times \omega}$$


$$C_{Apparent} = \frac{I_C/N}{10 \text{ kV} \times \omega}$$

Ratio N \implies $N = C_{True}/C_{Apparent}$

Doble Transformer Turn Ratio Test



C_{True} Measurement



C_{Apparent} Measurement

$$\text{Turns Ratio } N \implies N = C_{\text{True}} / C_{\text{Apparent}}$$

Note: Test Voltage Based on Nameplate



Metering Outfits PT/CT Comibnation





Single-Phase M O - Connections



**Use the same test form as the single phase potential transformer/
Voltage transformer:**

Single Phase Metering Outfit



Single-Phase M O - Connections



M O Connections:

- Base Terminal - One End of PT Primary
- Top Terminals (2) - Connected to the Line
 - Full Line Voltage in Service
 - Terminals Correspond to Either End of CT Primary
 - One Terminal also Corresponds to One End of the PT Primary
- Case Terminal Near Base - Grounded in Service
 - Terminal Designation Varies With Manufacturer

Recommended Test Voltage



Dry-Type MO Rated 15 kV Insulation Class And Below

MO Voltage Rating	Test Voltage (kV)
Overall	<ul style="list-style-type: none">a. 2 kVb. Line-to-Ground Voltage*c. 10% to 25% Above Line-to-Ground operating Voltage
Cross-Check	<ul style="list-style-type: none">a. 2 kVb. Line-to-Ground Operating Voltage
Excitation Current	<ul style="list-style-type: none">a. Line-to-Ground Operating Voltage

*Note: Power Factor Tip Up Test

Test kV Limited by Rating of Neutral Bushing (2/5 kV)



Recommended Test Voltage

Liquid Filled MO's Rated 15 kV Insulation Class and Above

- Perform Over-all Winding Tests at 2 kV
- Perform Over-all Winding Test - 10 kV*
- Perform Cross-Check Tests at 10 kV or Rated Line-to-Ground Voltage, Whichever is Lower

*Note: Tip-Up Test

Test kV Limited by Rating of Neutral Bushing (2/5 kV)

Test Procedure for Metering Outfits



Test Preparation:

- Short Circuit All Primary Windings (Current & Potential)
- Connect One Side of Secondary Windings to Ground
- Ground All Spare Units Under Test
 - Connect External Ground to Unit Housing

Test Procedure -Single Phase M O



Test Test

No.	Mode	Energize	Ground	Guard	UST	Description
1	GST	H ₁ /P ₁ ,H ₂ ,H ₃	X ₁ ,Y ₁ ,Z ₁	-	-	Overall
2	GST	H ₁ /P ₁	X ₁ ,Y ₁ ,Z ₁	H ₃	-	Cross-Check
3	GST	H ₃ *	X ₁ ,Y ₁ ,Z ₁	H ₁ /P ₁	-	Cross-Check
4	UST	H ₁ /P ₁	X ₁ Y ₁ ,Z ₁	-	H ₃	Excitation Test
5	UST	H ₃ *	X ₁ ,Y ₁ ,Z ₁	-	H ₁ /P ₁	Excitation Test

*Test kV Limited by Rating of Neutral Bushing (2/5 kV)

Test Voltage Applied for Tests 4 & 5 Should Be the Same for Comparison

ALL Spare Metering Outfits Tested in Storage - Housing
Must be Grounded Externally


Test Procedure - Single Phase M O



Test 1: GST-Ground

Measure: Overall

**Lower Voltage for
This Test**




Test kV Limited by Rating of Neutral Bushing (2/5 kV)

Test Procedure - Single Phase M O



Test 2: GST-Guard

Measure: #1 Cross-Check




Test Procedure - Single Phase M O



Test 3: GST-Guard

Measure: #2 Cross-Check



Test kV Limited by Rating of Neutral Bushing (2/5 kV)


Test Procedure - Single Phase M O



Test 4: UST

Measure: Excitation I


**Lower Voltage for
This Test**



Test Procedure - Single Phase M O

Test 5: UST


Measure: Excitation I



**Lower Voltage for
This Test**

Test kV Limited by Rating of Neutral Bushing (2/5 kV)

Three Phase Metering Outfit (MOs)



Test Procedure - 3 Phase M O



Test No.	Test Mode	Energize	Ground	Guard	UST	Description
1	GST	I_1, P, I_2	X_1, Y_1	-	-	Overall
2	GST	I_1	X_1, Y_1	P, I_2	-	I_1 Cross-Check
3	GST	P	X_1, Y_1	I_1, I_2	-	P Cross-Check
4	GST	I_2	X_1, Y_1	I_1, P	-	I_2 Cross-Check
5	UST	I_1	X_1, Y_1	-	I_2, P	Excitation Test
6	UST	I_2	X_1, Y_1	-	I_1, P	Excitation Test

* **ALL** Spare Metering Outfits Tested in Storage - Housing
Must be Grounded Externally

Analysis of Results: MO's



- Compare Overall Power Factor Test Values to Previous Test Results
- Compare Overall Power Factor Values to Similar Units (Doble Test-Data-Reference-Book)
- Compare the Sums of Cross-Check Currents & Watt-Loss Values to the Over-All Test Results

Analysis of Results: MO's



- Compare Excitation Current Test Results Performed at Both Ends of The Winding (Test Voltage Must be the Same for Both Tests)



CCVTs





← Single Stack

Two Stack




CCVTs



If you can test a Single Stack then
you can test any CCVT

The difficult part is knowing what to
disconnect in the base



What is a CCVT?

A capacitance coupled voltage transformer (CCVT) is a transformer used in a power system to step down extra high voltage signals and provide a low voltage signal.

CCVTs are typically used for measuring voltages in excess of 100kV where the use of a wound primary winding is not economical.

Disadvantage of this type of transformer is with ferroresonance and over-voltage transient problems

Applications for CCVTs

Accurate transformation of primary system voltage into secondary output voltages suitable for :

- Relaying / Protection **CCVT**
- Metering **CCVT**
- Power Line Carrier Coupling (**CCVT/CC**)

Applications for CCVTs

- TRV Mitigation for CB (CCVT/CC)
- Harmonics monitoring (CCVT/CC)
- Power supply for SS and remote area (CCVT)
- Except HVAC (CCVT)
- Improves SS insulation withstand (CCVT/CC)

Significance of Tests

- Capacitance Pack Deterioration or Failures Indicated by Changes in Capacitance
- Contamination of Capacitance Stack or Base Box Indicated by Changes in Power Factor

Capacitor Nomenclature

- C2, the Auxiliary capacitor is the largest capacitor in picofarads
- C1-1 (B1-POT) sits on top of C2, both are located in the first porcelain unit
- C1-2, C1-3, and so forth are found in additional stacked porcelain units on CCVT's with higher voltage ratings.

Nameplate capacitances may not exist for C1-1; this value may require calculation from the given C_{total} , which is often the series combination of C2 and C1-1 (B1-CAR).

Capacitor Nomenclature

➤ If C1 is provide instead of C1-1 you may have to perform some calculations to determine the value of C1-1


Capacitor section nameplate-Ritz

	TYPE	<input type="text"/>	YEAR	<input type="text"/>
	S/N	<input type="text"/>	SECTION WEIGHT	<input type="text"/>

C_N C_2	<input type="text" value="7 680"/>	pF	MAX. RATED VOLTAGE	<input type="text"/>	kV	D.F.	<input type="text"/>	%	<input type="radio"/>
	<input type="text" value="62 840"/>	pF	RATED FREQUENCY	<input type="text"/>	Hz		<input type="text"/>		<input type="radio"/>

$$\frac{1}{C_{1-1}} = \frac{1}{7680} + \frac{1}{62840}$$

$$C_{1-1} = 8750 \text{ pF}$$




To Measure the following resistors

R1 R2 R3 R4 R1-R3

A-B B-C C-D D-E A-D


Measure the following capacitors



C1 C2 C3 C4 C5

A-B B-C C-D D-E E-F

Measure the
following
capacitors




C4 – C5

D-F

**Now, Let's Rotate this
circuit 90 degrees and
give different
identification to each
capacitor**

4 Stack CCVT

How do we measure



C2

C1-1


C1-2

C1-3


C1-4

C1-1/C2


Test Points and Nomenclature



Capacitor voltage divider



Capacitor voltage divider



2838


Power Factor Testing CCVTs

Materials & Power Factor

- Dielectric: kraft paper and polypropylene film
- Electrode: Aluminum foil
- Connection: Tinned copper tabs

Type of insulation system	Power factor @ V_{rated} [%]	Comment
Paper/Mineral oil	0.40	High polar material content
Polypropylene/paper/synthetic oil	0.080	Low polar material content

Arrangement of mixed dielectric capacitor element




CCVT/CC Construction

Capacitor element

Construction

- Electrode - Aluminum foil
- Dielectric spacer material
 - i) Hazy polypropylene film
 - ii) Kraft paper
- Connection – Tinned Cu tabs
- Synthetic Fluid : PXE, SAS40 or Jarylec



Capacitor Element



Capacitor Stack



Capacitor Nomenclature

- The first step is to gather all of the nameplate information. In this case there are 3 nameplates for a two-stack CCVT.

Nameplates

- 1st On the door where the secondary output is located
- 2nd On the bottom flange of the top stack capacitor (C1-2)
- 3rd On the top flange of the bottom stack of capacitors (C1-1, C2 series)

All of this information needs to be recorded so that it can be entered in the DTAF program.

Nameplate on Door

TRENCH LIMITED MADE IN CANADA

CAPACITOR VOLTAGE TRANSFORMER

TYPE No. TE 1MF BIL kV SER. No.

FOR NOMINAL kV SYSTEM Hz MAX. RATED VOLTAGE kV

PERF. REFERENCE VOLTAGE VOLTS

LOW VOLTAGE TERMINALS	SECONDARY VOLTS	MARKED RATIO (TO 1)	ACCURACY VA @ 50 Hz	VA (NOM)
Y1 - Y3, X1 - X3	<input type="text" value="115"/>	<input type="text" value="1200"/>	<input type="text" value="0.15VA/KV2"/>	<input type="text" value="200"/>
Y2 - Y3, X2 - X3	<input type="text" value="69"/>	<input type="text" value="2000"/>	<input type="text" value="0.15VA/KV2"/>	<input type="text" value="200"/>
Z1 - Z3	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Z2 - Z3	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

THERMAL BURDEN RATING VA @ UPF

USE WITH TE 1MF CAPACITORS SERIAL No's.

CAPACITANCE TOTAL NOMINAL pF C1 pF C2 pF

TOTAL WEIGHT LB YEAR S.O.

Nameplate at Bottom of Top Unit



Nameplate at Top of Bottom Unit




Capacitor Nomenclature

- The C2 capacitor is always the largest capacitor
- The capacitance of the C1-1 in series with the C2 is less than the C1-1

Test Points

- The Top of Each Porcelain Section
- The Potential Grounding Switch
- The Carrier Terminal
- The Transformer Grounding Link (Alternate Test Only)

Modern CCVT



The CAR Terminal

- Older CCVT's
 - Carrier (CAR) Bushing Accessible for Testing
 - Potential (POT) Bushing Accessible for Testing

- Newer CCVT's
 - CAR Bushing Accessible for Testing
 - POT Bushing Not Accessible For Testing
 - Max Test Voltage 2 kV


CAR And POT Bushing (Older Units)




The CAR Terminal (Newer Units)

- CAR Terminal Accesible
- Bushing Not Accessible For Testing
- Max Test Voltage 2 kV

Typical Ritz Junction Box With CAR Lead “HF”



HF wire to connect to
HV cable




X-1


Y-1

Gnd

Typical ABB Junction Box With CAR Lead “L”



Typical Trench Junction Box With CAR Terminal Grounded



Test Procedures For Individual Capacitors

- De-energize capacitor by disconnecting from power line.
- Ground and discharge each porcelain unit.
- Close carrier (S1), if present, and potential (S2) grounding switches.

Test Procedures For Individual Capacitors

- Isolate CAR terminal from ground, drain coil, or carrier accessory lead.
- Test capacitors individually, measuring percent power factor and capacitance.


Analysis of Results

- Capacitance Should Not Vary From Nameplate By More Than 1.0% On Modern Units
- Power Factor on Older Units With Paper/Oil Construction Should Not Exceed 0.5%
- Power Factor on Newer Paper/Film/Synthetic Fluid Units Usually Run Below 0.1% and Should Not Exceed 0.2%

Summary

- Identify and isolate CAR terminal; replace after testing!
- Test capacitors individually with POT switch closed.
- Any series test of C2 and C1-1 combined must be made with POT switch open and transformer ground link removed.
- Observe both capacitance and percent power factor upper limits.

Voltage Ratio



Voltage Ratio

There is another test that is strongly recommended when testing CCVTs. That is the voltage ratio test. A known series of values 1kV to 10kV in 1kV steps is applied via the high voltage hook to the high voltage terminal (4-hole pad) of the CCVT. The secondary output is read by connecting voltmeters on terminals X1 to X3, Y1 to Y3, X2 to X3, and Y2 to Y3.

Voltage Ratio

The actual value should fall well within a $\pm 5\%$ from calculated. Expected would be $\pm 1\%$. The nameplate will give you the nominal applied system voltage, and also the secondary outputs for each of the secondary outputs.

Voltage Ratio

- Apply 10 kV to top of CCVT and measure the following points:
- Perform a voltage ratio test to confirm the ratios of the CCVT
 - ✓ X1-X3, Y1-Y3 ($1200/1 = 10000/1200 = 8.333\text{v}$)
 - ✓ X2-X3, Y2-Y3 ($2000/1 = 10000/2000 = 5.0\text{v}$)

A CCVT with an acceptable power factor can still have a ratio problem. Analyze all data!



Insulating Fluid



Receiving, Storage and Handling of Oil



- Purchase oil as per ASTM-3487 or Doble TOPS
- Stored & transported in dedicated containers
- Test oil before using it in apparatus
- Avoid handling oil during adverse weather conditions to minimize moisture ingress
- Check for material compatibility (hoses, pumps)
- Do not mix oils from different apparatuses
- Do not mix different types of fluids

Sampling of Insulating Mineral Oil



Two different methods from ASTM:

D 923: Standard Method of Sampling Electrical Insulating Liquids

D 3613: Standard method of Sampling Electrical Insulating Oils for Gas Analysis and Determination of Water Content

Sampling of Insulating Mineral Oil



- Protect from outside contamination
- Relative Humidity $< 70\%$
- Flush drain valve prior to sample collection
- Consider specific gravity. If specific gravity < 1 , free water will sink, take sample from bottom of tank
- Avoid sampling below freezing temperature (32°F)
- Consider remaining oil volume in apparatus
- Do not sample if a negative internal pressure exists
- Do not sample from energized instrument transformers

Sampling of Insulating Mineral Oil



- The oil lab is only as “Good” as the sample provided.
- Temperature has to be provided for relative saturation to be calculated

Sampling of Insulating Mineral Oil



Recommended Containers:

General Sampling

glass bottles

polyethylene bottles

aluminum or tin cans

DGA Sampling

glass syringes

stainless steel cylinders

Note: glass containers help visual inspection.

SAMPLE IDENTIFICATION

From Factory Run

Core Type

Shell Type

PCB Content (ppm): greater than 499

Free Breathing

Sealed Conservator

Gas Blanketed

Open Conservator

S/N _____

Syringe # _____

Company _____ Date _____

Substation _____ Transformer _____

Previous Doble Report No. _____ Cable Potential Trans. Current Trans.

Mfr. _____ kV _____ MVA _____ Mfr. Yr. _____

Cooling: FOA, etc. _____ Unit has a LTC: Yes No

Oil Capacity _____ gal. Oil Type: Mineral Silicone Other _____

TEMP: Ambient °C _____ Top Oil °C _____ Humidity % _____

Sampled by: _____ Unit's REF #: _____

Sampling Point: Main Tank-Top or Bottom ; LTC Other _____

LTC Type: Break-in-oil Vacuum Mfr./Model: _____

LTC Tank: Free Breathing Silica Gel Breaker Sealed

Test Requested: Gas H₂O Mini Screen PCB Other _____



Ship To: Doble Engineering Company
85 Walnut Street
Watertown, MA 02472-4037

FOR RUSH SERVICE
PLEASE CHECK HERE

PLEASE RETURN ORIGINAL AND 2 COPIES

OIL FORM 08 Rev. 03 10/09/98



Common Tests used for in-service Transformer Oil

<u>Test</u>	<u>To Detect</u>
Color	Rapid deterioration or serious contamination
Dielectric Strength	Contaminants (water & conducting particles)
Interfacial Tension	Polar contaminants
Neutralization Number	Acid degradation products
Power Factor	Unsatisfactory electrical properties, deterioration by-products
Pour Point	Contamination raising the pour point
Specific Gravity	Solvents, other oils, organic materials



Common Tests used for in-service Transformer Oil

<u>Test</u>	<u>To Detect</u>
Viscosity	Solvents, other oils, organic materials
Water Content	Presence of dissolved water
PCB Content	PCB concentration
Inhibitor Content	Depletion of oxidation inhibitor
Dissolved Gas-in-oil	Incipient transformer faults
Metals-in-oil	Dissolved or particulate metals

Transformer Oil Testing Frequency



Annual (recommended)

Dielectric Strength (D877 or D1816)

Dissolved Gas Analysis

Water Content (D1533B)

Every three to five years

Annual Tests

Interfacial Tension (D971)

Neutralization Number (D974)

Inhibitor Content (D2668)

Power Factor (D924)

Physical Tests

Transformer Oil Screening Tests



Utility:

Color
Dielectric Breakdown
Interfacial Tension
Neutralization Number
Pour Point
Power Factor (25C & 100C)
Specific Gravity
Viscosity
Inhibitor Content
Water Content
PCB Content

Mini Screen:

Inhibitor Content
Neutralization Number
Water Content
Interfacial Tension

Transformer Oil Screening Tests



7-Part Industrial:

Color/Visual

Dielectric Breakdown

Interfacial Tension

Neutralization Number

Power Factor (25C)

Specific Gravity

Water Content

5-Part Industrial:

Color/Visual

Dielectric Breakdown

Neutralization Number

Specific Gravity

Water Content


Limits for in-service oils



	$\leq 69\text{kV}$	$>69\leq 288\text{kV}$	$>288\text{kV}$
Dielectric Breakdown Voltage D877, kV minimum	26	30	*
Dielectric Breakdown Voltage D1816, 0.04" gap, kV minimum	20	20	25
Power factor @ 25 C D924, max.	0.5	0.5	0.5
Water Content D1533B, ppm max.	35	25	20
Visual Exam	clear & bright	clear & bright	clear & bright

* D877 is not as sensitive to dissolved water as D1816, should not be used in EHV apparatus

Oil Cell Test: Connected for Testing





Oil Cell Power Factor Test

Test Voltage: 10 kV

Test Results: New Oil $\leq 0.05\%$

Used Oil $\leq 0.50\%$

After taking Oil Power Factor Test, Immediately
Take the Temperature and apply Temperature
Correction.

Test Set Check: (Dry Oil Cell)

Test Voltage: 5 kV

Current: 400-450 μA

Watts: almost 0 Watts

Dissolved Gas-in-Oil



Gas	Chemical Symbol	Acceptable Limits
Hydrogen	H ₂	100
Oxygen	O ₂	
Nitrogen	N ₂	
Methane	CH ₄	100
Carbon Monoxide	CO	250
Ethane	C ₂ H ₆	60
Carbon Dioxide	CO ₂	
Ethylene	C ₂ H ₄	100
Acetylene	C ₂ H ₂	5

These limits were common to 90% of the transformer population included in the database

Key Gas Analysis



Condition

Key Gas

Arcing

High concentration of hydrogen and acetylene, with minor quantities of methane and ethylene.

Key gas - Acetylene

Corona

Low-energy electrical discharge creates hydrogen and methane, with lesser quantities of ethane and ethylene.

Key gas - Hydrogen

Overheated Oil

Includes ethylene and methane, and lesser quantities of hydrogen and ethane.

Key gas - Ethylene

Overheated Cellulose

Carbon dioxide and carbon monoxide are evolved from over-heated cellulose. Hydrocarbon gasses will be formed if the fault involves an oil-impregnated structure.

Key gas - Carbon Monoxide

Gases Produced during Overheating



<u>Temperature of Overheating</u>	<u>Gas</u>	<u>Chemical Symbol</u>
Low Temperature ($\sim 120^\circ$)	Methane	CH_4
	Ethane	C_2H_6
	Ethylene	C_2H_4
High Temperature ($>700^\circ \text{C}$)	Acetylene	C_2H_2



CASE STUDIES





CASE STUDIES

Transformers



Case Study 1 -Transformer

Mfr. – ITE

Date -1972

kVA – 750

2400/480 D-Y

Routine maintenance

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	2.5	12.920	3.605	2.23	0.80	3426
2	CH	2.5	4.911	1.268	2.06	0.80	1302
3	CHL (UST)	2.5	8.018	2.338	2.34	0.80	2125
4	CHL		8.009	2.337	2.34	0.80	2124
5	CL + CHL	1.0	18.710	5.620	2.40	0.80	4963
6	CL	1.0	10.700	3.282	2.46	0.80	2838
7	CHL (UST)	1.0	8.018	2.336	2.33	0.80	2125
8	CHL		8.010	2.338	2.34	0.80	2125
9	CH'						
10	CL'						

- Wet Windings and contaminated oil
- Watts are now $1/10$ of the as found tests
- Current was affected by the dielectric of the oil

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	2.5	11.810	0.327	0.249	0.90	3134
2	CH	2.5	4.552	0.143	0.31	0.90	1207
3	CHL (UST)	2.5	7.271	0.182	0.25	0.90	1928
4	CHL		7.258	0.184	0.25	0.90	1927
5	CL + CHL	1.0	17.040	0.541	0.286	0.90	4521
6	CL	1.0	9.777	0.356	0.36	0.90	2593
7	CHL (UST)	1.0	7.271	0.179	0.25	0.90	1928
8	CHL		7.263	0.185	0.25	0.90	1928
9	CH'						
10	CL'						

After baking windings and new oil

Case Study 2 - Transformer

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	32.380	2.558	0.789	1.0	8591
2	CH	10	9.969	1.855	1.86	1.0	2644
3	CHL (UST)	10	22.390	0.694	0.31	1.0	5941
4	CHL		22.411	0.703	0.31	1.0	5947
5	CL + CHL	2	40.720	1.484	0.364	1.0	10803
6	CL	2	18.320	0.737	0.40	1.0	4860
7	CHL (UST)	2	22.400	0.734	0.33	1.0	5942
8	CHL		22.400	0.747	0.33	1.0	5943
9	CH'		7.753	-0.151	-0.19	1.0	2058.8
10	CL'						

C1 Tests

Test	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
H1	10	0.761	0.798	10.5	1.0	200.7
H2	10	0.736	0.653	8.87	1.0	194.5
H3	10	0.555	0.555	7.72	1.0	190

C2 Test

Test	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
H1	.5	2.203	2.634	13.02	1.0	532.2

The watts are higher for the C1 tests than for the CH which is 1.855 watts

$$0.798 + 0.653 + 0.555 = 2.006 \text{ watts}$$

$$1.855 - 2.006 = -0.151 \text{ watts}$$

Case Study 3 -Transformer

Mfr. – GE

Date -2001

kVA – 5000

12000/480 D-Y

Acceptance Tests

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	15.800	1.012	0.55	0.86	4192
2	CH	10	5.195	0.793	1.32	0.86	1377
3	CHL (UST)	10	10.610	0.252	0.21	0.86	2814
4	CHL		10.605	0.219	0.18	0.86	2815
5	CL + CHL	.5	44.050	2.232	0.43	0.86	11686
6	CL	.5	33.440	1.978	0.51	0.86	8871
7	CHL (UST)	.5	10.610	0.271	0.22	0.86	2814
8	CHL		10.610	0.254	0.21	0.86	2815
9	CH'						
10	CL'						

Hot Collar Tests

Test	Test mode	Skirt	Test kV	mA	watts
H1	Ground	1	10	0.094	0.175
H2	Ground	1	10	0.477	4.187
H3	Ground	1	10	0.095	0.072
Retest					
H1	Ground	1	10		
H2	Ground	1	10	0.098	0.189
H3	Ground	1	10		

Case Study 4 - Transformer

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	33.080	16.220		1.01	8765
2	CH	10	12.860	3.612	2.84	1.01	3411
3	CHL (UST)	10	20.210	12.610	6.30	1.01	5352
4	CHL		20.220	12.608	6.30	1.01	5354
5	CL + CHL	10	59.360	23.630		1.01	15734
6	CL	10	39.140	11.040	2.85	1.01	10380
7	CHL (UST)	10	20.210	12.610	6.30	1.01	5353
8	CHL		20.220	12.590	6.29	1.01	5354
9	CH'		8.133	3.495	4.34	1.01	2157.4
10	CL'		35.668	10.813	3.06	1.01	9459.3

C1

Test	C (pF)	% PF	Test kV	mA	Watts	Corr. PF	Meas. pF
H1	415	.24	10	1.573	0.042	0.27	417.2
H2	415	.24	10	1.572	0.037	0.24	416.8
H3	418	.24	10	1.582	0.038	0.24	419.6

C2

Test	C (pF)	% PF	Test kV	mA	Watts	Corr. PF	Meas. pF
H1	1833	.26	2.5	6.925	0.184	0.27	1836
H2	1808	.28	2.5	6.822	0.176	0.26	1809
H3	1845	.26	2.5	6.958	0.188	0.27	1845

Excellent example of “averaged power factor” as the power factor for the CH’ is 4.34% without the bushings and 2.84% with the bushings. The good bushings were masking the bad windings.

Case Study 5 - Transformer

Background

- High side bushings were replaced
- Load Tap Changer was open all week for maintenance
- Routine test after repairs

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	28.510	0.934	-----	1.08	7564
2	CH	10	10.110	-0.040	-.0	1.08	2683
3	CHL (UST)	10	18.400	0.988	0.58	1.08	4880
4	CHL		18.400	0.974	0.57	1.08	4881
5	CL + CHL	10	71.340	42.440	-----	1.08	18889
6	CL	10	52.960	41.420	8.45	1.08	14008
7	CHL (UST)	10	18.390	0.991	0.58	1.08	4879
8	CHL		18.380	1.020	0.59	1.08	4881
9	CH'						
10	CL'						

Mfr.: FPE

Year Mfr. 1976

Tank Type: N2 Blanketed

Phases: 3

Config: Delta – Wye

Coolant: Oil


KV: 138 / 69

MVA / 15/20/25

LTC: Y

Top Oil Temperature: 17 degree C

- Federal Pacific Electric tested with the Load Tap Changer (LTC) in the neutral position.
- This tap changer has resistors in the neutral position.
- Always test with LTC off neutral



Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	28.510	0.949	-----	0.96	7562
2	CH	10	10.090	0.316	0.30	0.96	2677
3	CHL (UST)	10	18.390	0.629	0.33	0.96	4883
4	CHL		18.430	0.633	0.33	0.96	4885
5	CL + CHL	10	72.160	3.144	-----	0.96	19148
6	CL	10	53.750	2.487	0.46	0.96	14263
7	CHL (UST)	10	18.410	0.629	0.34	0.96	4883
8	CHL		18.410	0.657	0.36	0.96	4885
9	CH'						
10	CL'						

Retest with LTC off neutral

Case Study 6 - Transformer

Background

- 2002 CL capacitance and 2004 capacitance do not match
- Routine tests

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	24.47	1.296	----	0.80	6492
2	CH	10	3.915	0.212	0.43	0.80	1038
3	CHL (UST)	10	20.56	1.080	0.42	0.80	5454
4	CHL		20.55	1.084	0.42	0.80	5454
5	CL + CHL	.24	44.87	2.398	----	0.80	11902
6	CL	.24	24.33	1.289	0.42	0.80	6454
7	CHL (UST)	.24	20.59	20.59	0.42	0.80	5461
8	CHL		20.54	20.54	0.42	0.80	5448
9	CH'						
10	CL'						

2002 Test

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	24.39	1.113	----	1.0	6471
2	CH	10	3.905	0.170	0.44	1.0	1035
3	CHL (UST)	10	20.49	0.942	0.46	1.0	5435
4	CHL		20.48	0.943	0.46	1.0	5436
5	CL + CHL	.24	24.38	1.151	----	1.0	6469
6	CL	.24	3.907	0.176	0.45	1.0	1036
7	CHL (UST)	.24	20.48	0.970	0.47	1.0	5434
8	CHL		20.47	0.970	0.48	1.0	5433
9	CH'						
10	CL'						

2002 capacitance was 6454 – 2004 capacitance 1036

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	24.39	1.113	----	1.0	6471
2	CH	10	3.905	0.170	0.44	1.0	1035
3	CHL (UST)	10	20.49	0.942	0.46	1.0	5435
4	CHL		20.48	0.943	0.46	1.0	5436
5	CL + CHL	.24	24.38	1.151	----	1.0	6469
6	CL	.24	3.907	0.176	0.45	1.0	1036
7	CHL (UST)	.24	20.48	0.970	0.47	1.0	5434
8	CHL		20.47	0.970	0.48	1.0	5433
9	CH'						
10	CL'						

Leads not changed – tested high side again

Case Study 7 - Transformer

Background

- Acceptance tests on new transformer
- Data called in by owner of equipment
- Owner questioned test report

Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	2	11.76	0.600	----	0.71	3121
2	CH	2	3.040	0.955	2.23	0.71	805.9
3	CHL (UST)	2	8.729	-0.350	-0.3	0.71	2315
4	CHL		8.720	-0.355	-0.3	0.71	2315
5	CL + CHL	1	15.23	1.634	----	0.71	4041
6	CL	1	6.514	1.952	2.13	0.71	1727
7	CHL (UST)	1	8.729	-0.330	-0.3	0.71	2315
8	CHL		8.716	-0.318	-0.3	0.71	2314

1st Testing Company

Test	Insulation	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	2	11.76	0.600	----	0.71	3121
2	CH	2	3.040	0.955	2.23	0.71	805.9
3	CHL (UST)	2	8.729	-0.350	-0.3	0.71	2315
4	CHL		8.720	-0.355	-0.3	0.71	2315
5	CL + CHL	1	15.23	1.634	----	0.71	4041
6	CL	1	6.514	1.952	2.13	0.71	1727
7	CHL (UST)	1	8.729	-0.330	-0.3	0.71	2315
8	CHL		8.716	-0.318	-0.3	0.71	2314

1st Testing Company – Test report submitted report to customer wit negative numbers

Test	Insulation	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	11.82	0.314	----	0.80	3135
2	CH	10	3.206	0.111	0.28	0.80	850.4
3	CHL (UST)	10	8.616	0.205	0.19	0.80	2285
4	CHL		8.614	0.203	0.19	0.80	2284.6
5	CL + CHL	1	15.49	0.335	----	0.80	4109
6	CL	1	6.874	0.123	0.14	0.80	1823
7	CHL (UST)	1	8.616	0.191	0.18	0.80	2285
8	CHL		8.616	0.212	0.20	0.80	2286

Retest by 2nd Testing Company

- Transformer was not grounded
- Diagnostics tester from 1st testing company did not question negative results
- Negative results questioned by owner
- Diagnostics tester from 2nd testing company grounded the transformer
- **Who would you use in the future!!!!!!**

Case Study 8 - Transformer

Mfr. – Efacec - USA

Configuration – Wye – Delta

Tank Type – Sealed conservator

MVA – 900

kV – 230 /25

Acceptance tests

Transformer 8

- Was informed that the first transformer received failed (no additional data)
- Owner had major concerns with data as testing company could not provide answers for the results obtained



Test	Measured	Test kV	mA	Watts	% PF	Corr. Fac.	Capacitance
1	CH + CHL	10	262.11	10.905	----	1.0	69525.8
2	CH	10	258.45	10.918	0.42	1.0	68555.6
3	CHL (UST)	10	3.633	0.021	0.06	1.0	963.55
4	CHL		3.660	-0.013	-0.04	1.0	970.20
5	CL + CHL	3.001	677.76	27.797	----	1.0	179779.7
6	CL	3.000	674.08	27.728	0.41	1.0	178803.1
7	CHL (UST)	2.999	3.639	0.0180	0.05	1.0	965.27
8	CHL		3.680	0.069	0.19	1.0	976.00
9	CH'		251.37	10.732	0.43	1.0	66678.49
10	CL'		640.06	26.768	0.42	1.0	169780.40

Acceptance tests


Windings	Test Voltage	Capacitance	Power Factor
HV / LV + Earth	10	69730.10	0.38
HV / Earth	10	68736.80	0.39
HV / LV	10	974.95	0.22
LV / HV + Earth	4	180580.50	0.38
LV / Earth	3	179551.50	0.38
LV / HV	3	975.32	0.25
HV + LV / Earth	3	248473.00	0.39

Factory tests

➤ Shielded transformer

- ❖ Very high voltage transformation

- ❖ Variable frequency drives on secondary



Case Study 9 - Transformer

Mfr. – Efacec - USA

Configuration – Wye – Wye – Delta

Tank Type – Sealed conservator

MVA – 900

kV – 230 / 36.5 / 13.2

Factory tests


Meas.	Test kV	mA	Watts	%PF	Corr Fctr	Cap(pF)
CH + CHL	10.001	46.790	1.692		1.00	12411.5
CH	10.000	15.628	0.8020	0.51	1.00	4145.4
CHL(UST)	10.001	31.148	0.8810	0.28	1.00	8262.1
CHL		31.162	0.890	0.29	1.00	8266.100
CL + CLT	10.001	62.773	2.508		1.00	16650.7
CL	10.001	25.510	1.211	0.47	1.00	6766.4
CLT(UST)	10.000	37.247	1.320	0.35	1.00	9880.1
CLT		37.263	1.297	0.35	1.00	9884.300
CT + CHT	10.001	66.249	2.199	0.33	1.00	17572.4
CT	10.001	65.953	2.111	0.32	1.00	17494.0
CHT(UST)	10.001	0.2860	0.0820	2.87	1.00	75.813
CHT		0.296	0.088	2.97	1.00	78.400
CH+CL+CT	10.001	107.22	4.122	0.38	1.00	28439.8

Meas.	Test kV	mA	Watts	%PF	Corr Fctr	Cap(pF)
CH + CHL	10.001	46.790	1.692		1.00	12411.5
CH	10.000	15.628	0.8020	0.51	1.00	4145.4
CHL(UST)	10.001	31.148	0.8810	0.28	1.00	8262.1
CHL		31.162	0.890	0.29	1.00	8266.100
CL + CLT	10.001	62.773	2.508		1.00	16650.7
CL	10.001	25.510	1.211	0.47	1.00	6766.4
CLT(UST)	10.000	37.247	1.320	0.35	1.00	9880.1
CLT		37.263	1.297	0.35	1.00	9884.300
CT + CHT	10.001	66.249	2.199	0.33	1.00	17572.4
CT	10.001	65.953	2.111	0.32	1.00	17494.0
CHT(UST)	10.001	0.2860	0.0820	2.87	1.00	75.813
CHT		0.296	0.088	2.97	1.00	78.400
CH+CL+CT	10.001	107.22	4.122	0.38	1.00	28439.8


We saw this type of results on a shielded transformer

- ❖ Is the transformer shielded?
- ❖ Do we have a defective low voltage lead?
- ❖ Do we have a defective test set?
- ❖ Do we have a test procedure issue?

Transformer tertiary configurations - Tertiary inside the low voltage winding closer to core not on same insulation tube



Transformer tertiary configurations - Tertiary stacked on top of low voltage winding on same insulation tube



Case Study 10 - Transformer

Mfr. – Westinghouse

Generator Step Up

kV – 69 / 13.8

Mfr. Date 1973

Routine

November 7, 2016 Tests

Test	Meas.	kV	mA	Watts	% PF	CF	Cap. pF
1	CH + CHL	10	34.150	1.503	0.441	1.002	10980.050
2	CH	10	9.768	0.450	0.461	1.002	3140.520
3	CHL (UST)	10	24.369	1.065	0.438	1.002	7835.110
4	CHL		24.383	1.053	0.432	1.002	7839.530
5	CL + CHL	10	57.800	16.908	2.930	1.002	18575.900
6	CL	10	33.434	14.876	4.456	1.002	10739.000
7	CHL (UST)	10	24.367	1.066	0.438	1.002	7835.105
8	CHL		24.366	2.032	0.835	1.002	7836.900

Retest - November 17, 2016 Tests

Test	Meas.	kV	mA	Watts	% PF	CF	Cap. pF
1	CH + CHL	10	41.343	1.875	0.454	1.0	10966.750
2	CH	10	11.855	0.656	0.554	1.0	3144.690
3	CHL (UST)	10	29.474	1.219	0.414	1.0	7818.370
4	CHL		29.488	1.219	0.413	1.0	7822.060
5	CL + CHL	10	69.555	5.080	0.730	1.0	18450.100
6	CL	10	40.069	3.888	0.970	1.0	10628.450
7	CHL (UST)	10	29.471	1.231	0.418	1.0	7817.520
8	CHL		29.486	1.192	0.404	1.0	7821.650

March 25, 2013 Tests

Test	Meas.	kV	mA	Watts	% PF	CF	Cap. pF
1	CH + CHL	10	41.358	1.848	0.45	1.0	10970.7
2	CH	10	11.809	0.5840	0.49	1.0	3132.6
3	CHL (UST)	10	29.533	1.273	0.43	1.0	7834.3
4	CHL		29.549	1.264	0.43	1.0	7838.1
5	CL + CHL	10	69.509	3.948	0.57	1.0	18438.0
6	CL	10	39.968	2.700	0.68	1.0	10601.6
7	CHL (UST)	10	29.529	1.277	0.43	1.0	7833.2
8	CHL		29.541	1.248	0.42	1.0	78

11-7-2016

11-17-2016

Measured	Ma	Watts	Cap	mA	Watts	Cap
CH + CHL	34.150	1.503	10980.050	41.343	1.875	10966.750
CH	9.768	0.450	3140.520	11.855	0.656	3144.690
CHL	24.369	1.065	7835.110	29.474	1.219	7818.370
CHL	24.383	1.053	7839.530	29.488	1.219	7822.060
CL + CHL	57.800	16.908	18575.900	69.555	5.080	18450.100
CL	33.434	14.876	10739.000	40.069	3.888	10628.450
CHL	24.367	1.066	7835.105	29.471	1.231	7817.520
CHL	24.366	2.032	7836.900	29.486	1.192	7821.650

3-25-2013

11-17-2016

Measured	Ma	Watts	Cap	mA	Watts	Cap
CH + CHL	41.343	1.848	10970.7	41.343	1.875	10966.750
CH	11.809	0.5840	3132.6	11.855	0.656	3144.690
CHL	29.533	1.273	7834.3	29.474	1.219	7818.370
CHL	29.549	1.264	7838.1	29.488	1.219	7822.060
CL + CHL	69.509	3.948	18438.0	69.555	5.080	18450.100
CL	39.968	2.700	10601.6	40.069	3.888	10628.450
CHL	29.529	1.277	7833.2	29.471	1.231	7817.520
CHL	29.541	1.248	7836.4	29.486	1.192	7821.650



CASE STUDIES

Exciting Current





Exciting Current

- Normally have 2 Highs and 1 Lower
- Middle winding is usually the lowest
- Open circuit test
- Have to observe a tap pattern and a phase pattern


77
S 65C RISE SELF COOLED

LV WINDING AL
HV WINDING AL
LV BIL 30 KV
HV BIL 45 KV



CH PER 10 C CHANGE IN


How would you perform exciting current tests on this transformer?



WINDING	VOLT(V)	6.6 MV
HV	14450	282.9
	14145	269.3
	13800	276.1
	13455	283.2
	13110	280.6

	VOLT(V)	6.6 MVA
	4616	825.5
	4584	831.2
	4553	836.9
	4522	842.6
	4492	848.2
	4462	853.9
	4432	859.7
	4403	865.4
	4374	871.1
	4345	876.7
	4318	882.4
	4289	888.2
	4263	893.8
	4236	899.5
	4209	905.3


This is a Delta – Wye with a H0 bushing



The Excitation Test

What it measures

- The Excitation Test measures the current needed to magnetize the core and generate the Magnetic Field in the Windings.
- A broader definition would be the current that flows when the transformer is energized with an ac voltage source under no-load conditions.



Case Study 11 – Transformer

Exciting Current

Mfr. – Westinghouse

Configuration – Delta – Wye

Tank Type – Sealed


Acceptance

		H1 – H2		H2 – H3		H3 – H1	
DETC	Test kV	mA	Watts	mA	Watts	mA	Watts
1	10	49.080	392.10	17.96	147.90	47.660	385.30
2	10	48.260	393.10	17.420	145.90	49.260	399.20
3	10	50.400	410.90	18.150	152.20	51.370	417.10
4	10	52.480	428.90	18.890	158.70	53.48	435.20
5	10	54.890	449.60	19.740	166.20	55.930	456.20

2 Highs and 1 Lower as expected – But do we have a good pattern?

		H1 – H2		H2 – H3		H3 – H1	
DETC	Test kV	mA	Watts	mA	Watts	mA	Watts
1	10	49.080	392.10	17.96	147.90	47.660	385.30
2	10	48.260	393.10	17.420	145.90	49.260	399.20
3	10	50.400	410.90	18.150	152.20	51.370	417.10
4	10	52.480	428.90	18.890	158.70	53.48	435.20
5	10	54.890	449.60	19.740	166.20	55.930	456.20

H2 – H3 is the lowest instead of H1 – H2



H3 – H2**H2 – H1****H1 – H3**

DETC	Test kV	H1 – H2		H2 – H3		H3 – H1	
		mA	Watts	mA	Watts	mA	Watts
1	10	49.080	392.10	17.96	147.90	47.660	385.30
2	10	48.260	393.10	17.420	145.90	49.260	399.20
3	10	50.400	410.90	18.150	152.20	51.370	417.10
4	10	52.480	428.90	18.890	158.70	53.48	435.20
5	10	54.890	449.60	19.740	166.20	55.930	456.20

H1 and H3 appear to be identified incorrectly

Case Study 12 - Transformer

Overall and Exciting Current

Mfr. – ABB

Configuration – Delta – Wye

Tank Type – Sealed


MVA – 20

kV – 34.5 / 4.16

Routine

Test	Measured	Test kV	mA	Watts	% PF	CF	Capacitance
1	CH + CHL	10	61.581	1.692	----	0.96	16334.7
2	CH	10	15.352	0.451	0.28	0.96	4072.2
3	CHL (UST)	10	46.226	1.227	0.26	0.96	12261.7
4	CHL		46.229	1.241	0.26	0.96	12262.5
5	CL + CHL	2	98.95	3.756	----	0.96	26246.9
6	CL	2	52.716	2.400	0.44	0.96	13983.1
7	CHL (UST)	2	46.237	1.391	0.29	0.96	12264.6
8	CHL		46.234	1.356	0.28	0.96	12263.8

Overall Power Factor Tests



Exciting Current Tests

DETC	Test kV	H3 – H1		H1 – H2		H2 – H3	
		mA	Watts	mA	Watts	mA	Watts
3	5	98.941	839.85	111.25	895.22	46.071	425.66
3	5	98.971	839.92	108.50	880.78	45.377	421.32

Exciting Current Tests

		H1 – H3		H3 – H2		H2 – H1	
		H3 – H1		H1 – H2		H2 – H3	
DETC	Test kV	mA	Watts	mA	Watts	mA	Watts
3	5	98.941	839.85	111.25	895.22	46.071	425.66
3	5	98.971	839.92	108.50	880.78	45.377	421.32

H


H


L


2 Highs and 1 Lower – but do we have a good pattern

What if bushings 1 and 3 were mis-labeled?

DYNI I








Exciting Current Tests

DETC	Test kV	H3 – H1		H1 – H2		H2 – H3	
		mA	Watts	mA	Watts	mA	Watts
3	5	98.941	839.85	111.25	895.22	46.071	425.66
3	5	98.971	839.92	108.50	880.78	45.377	421.32




Case Study 13 – Exciting Current


- Where are the “odd” currents
- Review the tap pattern and the phase pattern

			H2 - H3			H3 - H1			H1 - H2	
DETC	LTC	Test kV	mA	Watts	X	mA	Watts	X	mA	Watts
C	16R	10	12.296	78.44	L	12.658	79.492	L	5.687	34.371
C	15R	10	58.192	85.977	L	58.575	86.383	L	52.597	42.547
C	14R	10	12.041	76.574	L	12.346	77.386	L	5.592	33.684
C	13R	10.004	57.945	84.218	L	58.399	84.737	L	18.88	64.341
C	12R	10	11.806	74.91	L	12.095	75.705	L	5.508	33.08
C	11R	10	57.814	82.606	L	58.126	82.778	L	52.498	41.292
C	10R	10	11.603	73.513	L	11.793	73.903	L	5.431	32.559
C	9R	10	57.674	81.387	L	57.976	81.384	L	52.423	40.84
C	8R	10	11.427	72.348	L	11.614	72.692	L	5.367	32.118
C	7R	10	57.55	80.469	L	57.828	80.187	L	52.376	40.52
C	6R	10	11.315	71.439	L	11.455	71.578	L	5.314	31.765
C	5R	10	57.433	79.813	L	57.67	79.299	L	52.263	40.295
C	4R	10	11.202	70.714	L	11.33	70.783	L	5.272	31.504
C	3R	10.001	57.338	79.241	L	57.514	78.788	L	52.236	40.205
C	2R	10	11.124	70.27	L	11.227	70.238	L	5.245	31.299
C	1R	10	56.972	79.277	L	57.203	78.823	L	51.893	40.315
C	N	9.999	11.094	70.122	L	11.202	70.039	L	5.238	31.235
C	1L	10.001	57.121	78.981	L	57.364	78.354	L	52.068	39.925
C	2L	10	11.125	70.181	L	11.242	70.213	L	5.254	31.308
C	3L	10.001	57.334	78.933	L	57.467	78.394	L	52.258	39.901
C	4L	10	11.205	70.706	L	11.268	70.548	L	5.29	31.474
C	5L	10	57.415	79.564	L	57.586	78.935	L	18.82	63.081
C	6L	9.999	11.343	71.481	L	11.383	71.247	L	5.331	31.736
C	7L	10	57.626	80.416	L	57.687	79.703	L	52.381	40.389
C	8L	10	11.485	72.475	L	11.483	72.073	L	5.385	32.101
C	9L	10	57.764	81.568	L	57.845	80.774	L	52.433	40.806
C	10L	9.999	11.686	73.735	L	11.662	73.248	L	5.45	32.541
C	11L	10	57.95	83.104	L	57.978	82.156	L	52.499	41.374
C	12L	10	11.897	75.202	L	11.865	74.673	L	5.524	33.073
C	13L	10.001	58.079	84.821	L	58.088	83.689	L	52.469	42.037
C	14L	10	12.124	76.869	L	12.095	76.293	L	5.614	33.672
C	15L	10.001	58.259	86.606	L	58.257	85.577	L	52.552	42.763

DETC	LTC	Test kV	H2 - H3			H3 - H1			H1 - H2	
			mA	Watts	X	mA	Watts	X	mA	Watts
C	16R	10	12.296	78.44	L	12.658	79.492	L	5.687	34.371
C	15R	10	58.192	85.977	L	58.575	86.383	L	52.597	42.547
C	14R	10	12.041	76.574	L	12.346	77.386	L	5.592	33.684
C	13R	10.004	57.945	84.218	L	58.399	84.737	L	18.88	64.341
C	12R	10	11.806	74.91	L	12.095	75.705	L	5.508	33.08
C	11R	10	57.814	82.606	L	58.126	82.778	L	52.498	41.292
C	10R	10	11.603	73.513	L	11.793	73.903	L	5.431	32.559
C	9R	10	57.674	81.387	L	57.976	81.384	L	52.423	40.84
C	8R	10	11.427	72.348	L	11.614	72.692	L	5.367	32.118
C	7R	10	57.55	80.469	L	57.828	80.187	L	52.376	40.52
C	6R	10	11.315	71.439	L	11.455	71.578	L	5.314	31.765
C	5R	10	57.433	79.813	L	57.67	79.299	L	52.263	40.295
C	4R	10	11.202	70.714	L	11.33	70.783	L	5.272	31.504
C	3R	10.001	57.338	79.241	L	57.514	78.788	L	52.236	40.205
C	2R	10	11.124	70.27	L	11.227	70.238	L	5.245	31.299
C	1R	10	56.972	79.277	L	57.203	78.823	L	51.893	40.315
C	N	9.999	11.094	70.122	L	11.202	70.039	L	5.238	31.235
C	1L	10.001	57.121	78.981	L	57.364	78.354	L	52.068	39.925
C	2L	10	11.125	70.181	L	11.242	70.213	L	5.254	31.308
C	3L	10.001	57.334	78.933	L	57.467	78.394	L	52.258	39.901
C	4L	10	11.205	70.706	L	11.268	70.548	L	5.29	31.474
C	5L	10	57.415	79.564	L	57.586	78.935	L	18.82	63.081
C	6L	9.999	11.343	71.481	L	11.383	71.247	L	5.331	31.736
C	7L	10	57.626	80.416	L	57.687	79.703	L	52.381	40.389
C	8L	10	11.485	72.475	L	11.483	72.073	L	5.385	32.101
C	9L	10	57.764	81.568	L	57.845	80.774	L	52.433	40.806
C	10L	9.999	11.686	73.735	L	11.662	73.248	L	5.45	32.541
C	11L	10	57.95	83.104	L	57.978	82.156	L	52.499	41.374
C	12L	10	11.897	75.202	L	11.865	74.673	L	5.524	33.073
C	13L	10.001	58.079	84.821	L	58.088	83.689	L	52.469	42.037
C	14L	10	12.124	76.869	L	12.095	76.293	L	5.614	33.672
C	15L	10.001	58.259	86.606	L	58.257	85.577	L	52.552	42.763
C	16L	10.004	12.488	79.219	L	12.351	78.14	L	5.715	34.352

LTC Pattern Excitation Example 1





Odd Steps are Bridged Positions



CONTACT	POSITION																																
	LOWER														RAISE																		
	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	N	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
P1 (G) connects to	4	5	5	6	6	7	7	8	8	9	9	10	10	11	11	M	M	4	4	5	5	6	6	7	7	8	8	9	9	10	10	11	11
P3 (H) connects to	4	4	5	5	6	6	7	7	8	8	9	9	10	10	11	11	M	M	4	4	5	5	6	6	7	7	8	8	9	9	10	10	11
R connects to	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	

77

S 65C RISE SELF COOLED

LV WINDING AL
HV WINDING AL

LV BIL 30 KV
HV BIL 45 KV



CH PER 10 C CHANGE IN



CASE STUDIES

Bushings



Case Study 14 -Bushing

ABB O+C bushings

Mfr. 1995


kV – 138

Amp – 800

Type – Draw lead

C1 Nameplated data

H1	0.21 % PF	365 pF
H2	0.22 % PF	365 pF
H3	0.22 % PF	365 pF



1995

O+C

Nameplate

H1 .21 % PF 365 pF

H2 .22 % PF 365 pF

H3 .22 % PF 365 pF

Actual

H1 .212 % PF 357.5 pF

H2 .033 % PF 358.1 pF

H3 .213 % PF 359.2 pF

- Why is the C1 power factor lower than nameplate?
 - ❖ Contamination on lower porcelain
 - ❖ Internal contamination
 - ❖ Poor flange ground
- It helps to have prior test data / history of the bushings!!!!

C1 History – Bushing H1

History for C1

Display History for Bushing

H1

Date	Inputs			Results					Ask FRANK™
	Serial#	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	
7/31/2016	3704040195	10.002	1.05	1.348	0.027	0.202	0.212	357.5	 Good
3/9/2005	3704040195	10.000	0.95	1.342	0.008	0.060	0.057	356.0	 Investigate
4/12/2000	3704040195	10.000	1.00	1.348	0.027	0.200	0.200	357.4	 Good

C1 History – Bushing H2

History for C1										
Display History for Bushing									H2	
Date	Inputs			Results					Rating	
	Serial#	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™	
7/31/2016	3704040295	10.170	1.05	1.350	0.004	0.031	0.033	358.1	 Investigate	<input type="button" value="..."/>
3/9/2005	3704040295	10.000	0.95	1.313	-0.030	-0.228	-0.218	348.3	 Bad	<input type="button" value="..."/>
4/12/2000	3704040295	10.000	1.00	1.351	0.027	0.200	0.200	358.2	 Good	<input type="button" value="..."/>

C1 History – Bushing H3

History for C1										
Display History for Bushing									H3	
Date	Inputs			Results					Rating	
	Serial#	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	Ask FRANK™	
7/31/2016	3704040395	10.002	1.05	1.354	0.028	0.203	0.213	359.2	 Good	
3/9/2005	3704040395	10.000	0.95	1.350	0.024	0.178	0.170	358.0	 Good	
4/12/2000	3704040395	10.000	1.00	1.350	0.027	0.200	0.200	358.0	 Good	

- Is there a problem?
- Review history of this type of bushing
- **ABB Service Advisory May 31, 2000**

ABB Service Advisory May 31, 2000

ABB Alamo has received reports indicating that some O Plus C[™] bushings in service have shown staining on the lower porcelain area. Reported incidences to date of the stained bushings in oil are confined to O Plus C[™] 115 kV and below, manufactured **in the 1990 to 1994 timeframe**. Our investigation confirms the staining process originates at the gasket joint.

- This bushing was manufactured in 1995 so it is not within the dates for the service advisory
- What steps do we take?

Inspection of Bushing H2



Inspection of Bushing H2



After cleaning



C1 Test Before and After Cleaning

History for C1

Display History for Bushing

H2

Date	Inputs			Results					Ask FRANK™
	Serial#	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	
7/31/2016	3704040295	10.170	1.05	1.350	0.004	0.031	0.033	358.1	Investigate
3/9/2005	3704040295	10.000	0.95	1.313	-0.030	-0.228	-0.218	348.3	Bad
4/12/2000	3704040295	10.000	1.00	1.351	0.027	0.200	0.200	358.2	Good

Date	Inputs			Results					Ask FRANK™
	Serial#	Test kV	Corr. Factor	mA	Watts	PF (%)	PF Corr. (%)	Capacitance (pF)	
7/31/2016	3704040295	10.171	1.05	1.350	0.027	0.203	0.214	358.1	Deteriora...

Case Study 15 -Bushing

Mfr. – Westinghouse

Type - O

kV – 115

Amp – 1200

Mfr. Date 1967-1968

Routine

C1 Tests – As Found

Test	PF	Cap	kV	mA	Watts	% PF	Cap
H1	.45	349	10	1.327	0.063	0.49	351.89
H2	.43	349	10	1.329	0.064	0.50	352.52
H3	.45	350	10	1.326	0.064	0.50	351.83

C2 Tests – As Found

Test	PF	Cap	kV	mA	Watts	% PF	Cap
H1		2830	2	10.738	0.553	0.51	2848.4
H2		2745	2	10.438	1.637	1.57	2768.3
H3		2830	2	10.714	0.541	0.50	2841.9


C2 Tests – As Found

Test	PF	Cap	kV	mA	Watts	% PF	Cap
H1		2830	2	10.738	0.553	0.51	2848.4
H2		2745	2	10.438	1.637	1.57	2768.3
H3		2830	2	10.714	0.541	0.50	2841.9

Note the increase in watts
and power factor for H2

- The Westinghouse type O bushing has the tap compartment filled with oil
- Since there was an increase in watts the C2 compartment was suspected.
- Changed the fluid and cleaned up the covers and new gasket for the cover.





C2 Tests – As Left

Test	PF	Cap	kV	mA	Watts	% PF	Cap
H1		2830	2	10.71	0.572	0.53	2840.5
H2		2745	2	10.38	0.570	0.53	2754.4
H3		2830	2	10.69	0.566	0.53	2836.3